

Building	Space	Personal comfort modifications	Number of plants	Number of animals kept as pets	Clean cages, food stored in sealed containers, cages away from air vents	Room is clean and free of clutter	Food is stored properly	Room is free of water damage and excessive moisture	Provide location of water damage	Room is free of mold and mildew	Provide location of peeling or flaking paint	Room is free of peeling-flaking paint droppings, dead insects or insect traps)	Unusual odors	Chemicals stored properly	There is at least one supply diffuser	There is at least one return-transfer-exhaust vent	All air vents are clean and free of obstructions	HVAC equipment serving this room	Please describe the HVAC equipment	Exterior windows appear to be operable	Number of occupants present (excluding assessor)	Thermostat reading (F)	Room temperature (F)	Relative humidity (%)	Carbon dioxide (ppm)	Carbon monoxide (ppm)	Issues
J.J. Hill Montessori Magnet School	2200	None	None	None	TRUE	TRUE	TRUE		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	N/A	5	0	72	29	843	0		
J.J. Hill Montessori Magnet School	1301	None	None	None	TRUE	TRUE	TRUE		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	FALSE	4	67	72	27	824	0		
J.J. Hill Montessori Magnet School	1302	Open door	None	None	TRUE	TRUE	TRUE		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	FALSE	2	67	71	27	827	0		
J.J. Hill Montessori Magnet School	1103	Open door																Exhaust fan;Kitchen-dishroom exhaust									
J.J. Hill Montessori Magnet School	1102	Fan;Open door	None	None	TRUE	TRUE	TRUE		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE		N/A	3	0	71	26	1027	0		
J.J. Hill Montessori Magnet School	1013	Open door	None	None	TRUE	TRUE	TRUE		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	N/A	100	0	71	26	971	0		
J.J. Hill Montessori Magnet School	1012	Open door	None	None	TRUE	TRUE	False- MINOR		TRUE	False- MINOR		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	N/A	0	68	72	26	814	0		
J.J. Hill Montessori Magnet School	1402	Open door	None	None	TRUE	TRUE	TRUE		TRUE	False- MINOR		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	N/A	2	74	72	26	898	0		
J.J. Hill Montessori Magnet School	1401	None	4 - 9	None	TRUE	TRUE	TRUE		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	TRUE	20	69	70	27	970	0		
J.J. Hill Montessori Magnet School	1403	Fan;Open door	1 - 3	None	TRUE	TRUE	TRUE		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	TRUE	25	68	70	27	859	0		
J.J. Hill Montessori Magnet School	1305	None	1 - 3	None	TRUE	TRUE	TRUE		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	TRUE	20	66	70	26	875	0		
J.J. Hill Montessori Magnet School	1109	Fan	None	None	TRUE	TRUE	TRUE		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	N/A	0	67	72	28	917	0		
J.J. Hill Montessori Magnet School	1404	Open door	None	None	TRUE	TRUE	TRUE		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	N/A	20	0	70	26	801	0		
J.J. Hill Montessori Magnet School	1409	None	1 - 3	None	TRUE	TRUE	TRUE		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	TRUE	20	68	70	27	891	0		
J.J. Hill Montessori Magnet School	2212	Open door	10 or more	1 - 3	TRUE	TRUE	TRUE	TRUE	TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	TRUE	1	67	70	27	839	0		
J.J. Hill Montessori Magnet School	2204	None	1 - 3	1 - 3	TRUE	TRUE	TRUE	TRUE	TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	TRUE	25	68	72	29	1245	0		
J.J. Hill Montessori Magnet School	1407	Open door	4 - 9	None	TRUE	TRUE	TRUE		TRUE	False- MINOR		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	TRUE	25	67	72	28	1118	0		
J.J. Hill Montessori Magnet School	2215	Open door	10 or more	1 - 3	TRUE	TRUE	False- MINOR		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	TRUE	1	66	69	26	801	0		
J.J. Hill Montessori Magnet School	2207	None	None	None	TRUE	TRUE	TRUE		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	N/A	30	68	72	29	882	0		
J.J. Hill Montessori Magnet School	2208	Open door	1 - 3	None	TRUE	TRUE	TRUE		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	TRUE	25	67	73	29	1030	0		
J.J. Hill Montessori Magnet School	2201	Open door	None	None	TRUE	TRUE	TRUE		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	TRUE	0	66	72	28	902	0		
J.J. Hill Montessori Magnet School	2209	Fan	4 - 9	1 - 3	TRUE	TRUE	TRUE	TRUE	TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	N/A	30	69	73	28	1077	0		
J.J. Hill Montessori Magnet School	1308	Open door	None	None	TRUE	TRUE	TRUE		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	TRUE	25	67	73	29	1062	0		
J.J. Hill Montessori Magnet School	1309	Open door	None	None	TRUE	TRUE	False- MINOR		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	TRUE	30	68	70	27	949	0		
J.J. Hill Montessori Magnet School	1405	Open door	1 - 3	None	TRUE	TRUE	False- MINOR		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	TRUE	2	69	70	27	812	0		
J.J. Hill Montessori Magnet School	2213	Open door	None	None	TRUE	TRUE	TRUE		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	N/A	1	68	73	29	945	0		
J.J. Hill Montessori Magnet School	2202	Fan;Open door	None	None	TRUE	TRUE	TRUE		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	N/A	1	67	74	28	991	0		
J.J. Hill Montessori Magnet School	2203	Fan;Open door	None	None	TRUE	TRUE	TRUE		TRUE	False- MINOR		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	N/A	2	67	73	28	990	0		
J.J. Hill Montessori Magnet School	1304	Fan	None	None	TRUE	TRUE	TRUE		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	N/A	0	67	71	27	824	0		
J.J. Hill Montessori Magnet School	1011	Open door	None	None	TRUE	TRUE	TRUE		TRUE	False- MINOR		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	N/A	0	69	71	26	764	0		
J.J. Hill Montessori Magnet School	1108	Open door	None	None	TRUE	TRUE	TRUE		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	N/A	0	65	70	26	828	0		
J.J. Hill Montessori Magnet School	1001	Fan;Open door	None	None	TRUE	TRUE	TRUE		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	N/A	2	70	70	26	764	0		
J.J. Hill Montessori Magnet School	1014	Fan;Open door;Space heater	None	None	TRUE	TRUE	TRUE		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	N/A	2	74	73	26	894	0		

Building	Space																										Issues	
		Personal comfort modifications	Number of plants	Number of animals kept as pets	Clean cages, food stored in sealed containers, cages away from air vents	Room is clean and free of clutter	Food is stored properly	Room is free of water damage and excessive moisture	Provide location of water damage	Room is free of mold and mildew	Room is free of peeling or flaking paint	Provide location of peeling-flaking paint	Room is free of pests (mouse traps or droppings, dead insects or insect traps)	Unusual odors	Chemicals stored properly	There is at least one supply diffuser	There is at least one return-transfer-exhaust vent	All air vents are clean and free of obstructions	HVAC equipment serving this room	Please describe the HVAC equipment	Exterior windows appear to be operable	Number of occupants present (excluding assessor)	Thermostat reading (F)	Room temperature (F)	Relative humidity (%)	Carbon dioxide (ppm)		Carbon monoxide (ppm)
J.J. Hill Montessori Magnet School	2214	None	None	None	TRUE	TRUE	TRUE		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None										
J.J. Hill Montessori Magnet School	1105	Fan;Open door	None	None	TRUE	TRUE	TRUE		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	N/A	1	0	72	26	1163	0			
J.J. Hill Montessori Magnet School	1002	None	None	None	TRUE	TRUE	TRUE		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	N/A	0	67	70	26	700	0			
J.J. Hill Montessori Magnet School	1005	Fan	None	None	TRUE	TRUE	TRUE		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	TRUE	0	69	70	26	816	0			
J.J. Hill Montessori Magnet School	1009	Open door	None	None	TRUE	TRUE	False- MINOR		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	N/A	5	72	71	26	779	0			
J.J. Hill Montessori Magnet School	1209	Fan	None	None	TRUE	TRUE	TRUE		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	TRUE	10	67	70	31	906	0			
J.J. Hill Montessori Magnet School	1208	Fan;Open door	None	None	TRUE	TRUE	TRUE		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	TRUE	0	67	72	31	917	0			
J.J. Hill Montessori Magnet School	1207	None	None	None	TRUE	TRUE	TRUE		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	TRUE	25	67	72	31	960	0			
J.J. Hill Montessori Magnet School	1215	None	None	None	TRUE	TRUE	TRUE		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None										
J.J. Hill Montessori Magnet School	1200	Fan	None	None	TRUE	TRUE	TRUE		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	TRUE	0	68	73	31	798	0			
J.J. Hill Montessori Magnet School	1216	Fan;Open door	1 - 3	None	TRUE	TRUE	TRUE		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	N/A	25	68	70	32	998	0			
J.J. Hill Montessori Magnet School	1203	Humidifier; Open door	None	None	TRUE	TRUE	False- MINOR		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	N/A	25	66	73	30	996	0			
J.J. Hill Montessori Magnet School	1213	Fan	None	None	TRUE	TRUE	TRUE		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	N/A	1	70	72	31	894	0			
J.J. Hill Montessori Magnet School	1214	Fan;Humidifier	None	None	TRUE	TRUE	TRUE		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	N/A	25	70	71	32	861	0			
J.J. Hill Montessori Magnet School	1204	Open door	None	None	TRUE	TRUE	False- MINOR		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	N/A	5	67	72	30	852	0			
J.J. Hill Montessori Magnet School	1201	None	1 - 3	1 - 3	TRUE	TRUE	TRUE		TRUE	TRUE		TRUE	None	TRUE	TRUE	TRUE	TRUE	None	N/A	25	66	72	30	988	0			