

CLEAN

SAFE

HEALTHY

SCHOOLS

Amity Regional School
District No. 5

25 Newton Road

Woodbridge, CT 06525

Phone: 203-397-4817

Fax: 203-397-4864



Amity Regional School District No. 5

Facilities Department Monthly Report

Completed Projects:

- The new gym speakers at ARHS were installed.
- The gym roof and wall projects at AMSO and AMSB were completed.
- The three jump pits around the ARHS track had additional coats applied.
- A few roof leaks were addressed by Greenwood roofing at ARHS.
- Due to a partial power outage at ARHS, several motor starter contactors for HVAC equipment, sewage pumps and the walk in freezer had to be replaced. Work was done by our in house HVAC maintainer, in house electrician and our HVAC contractor.
- Receivers for a disc golf course were installed by our in house maintainer at AMSB.

Projects in Process:

- The lecture hall remodel at ARHS is approximately 95% completed. The space is usable, we are working on some punch list items with the contractor which will be wrapped up in a couple weeks.
- The gym floor at AMSO was repaired. They are currently in the process of final sanding, line painting and finishing. At the time of writing this report, it is scheduled for completion on November 8th.
- Re-lamping the Bethany indoor fixtures is still in progress with approximately 20% left to complete.
- The fixtures are in for several outdoor parking lot lights at ARHS. The LED strips are starting the fail, creating a low light condition. We are now working on scheduling an installation date.
- New shot clocks are being installed in the gym at ARHS by our in house maintainer and electrician.

Outstanding issues to be addressed:

We are working with Classic Turf on scheduling the warranted repairs to the track.