

Facilities & Grounds Liaison Report
September 14, 2023

- Our application, along with a traffic engineer study and State Police report, has been submitted to Leacock Twp who will then apply to Penn DOT on the District's behalf to have the flashing lights reinstated in front of the HS along both sides of Rt. 772. The application point of contact at Penn DOT is Eric Kinard, 717.787.9237
- The football shed was moved from the HS parking lot to field 13. This was at no cost to the District as we traded the old tennis court fence with a local company for shed moving services.
- The Salisbury VAV replacement project is approximately half-way completed, and we got through last week's heat with minimal room temp issues.
- The temporary water system that the contractors installed for the concession stand bathrooms had major flaws that became evident at our first football game. The sewer line has now been rerouted and tied into the main sewer line. The water supply system lost pressure and took approximately 12 minutes to recoup, which was not adequate for football halftime volume. The District installed a well pump in the 3,000 gallon water tank and re-plumbed the system. We tried to simulate the volume needed for halftime and we believe the system will now be adequate.
- The gray water system at Paradise had been bypassed for 3 years waiting for pumps to be built and installed. All of the final installs and connections were made two weeks ago, just in time for hot and dry weather. The gray water tank dried up. When it called for water from the main well to fill itself all the water pressure was taken away from the building. We bypassed the system to get immediate pressure back to the building and made adjustments to the current system which will hopefully avoid that scenario happening again.