

Below are pictures of finished samples of the brick and block for the 7-12 building.

DEP conducted water system inspections at Salisbury and PVIS. Salisbury had a water system bypass that is no longer allowed per code. We cut the bypass out but installed two ball valves in case the system would have to be bypassed for an emergency in the future.

The stadium concession stand and water well that fed it have been removed from DEP's books. Temporary water for the concession stand will be supplied by a temporary line out of the HS until final hookup is made to the Leacock system this Fall.

Silt and runoff has been getting into the HS sewer plant. We met with Boro Construction. They are regrading and making some other modifications. The plant had to be pumped out and re-seeded with product from New Holland. It still failed the sludge test but we hope it clears in the near future. If not, we will pump it out and re-seed again.

PVIS hot water heaters have brought the local fire departments in again. Four 150 gal. heaters service PVIS. When one of the pressure valves opens to relieve pressure in the tank it triggers the fire alarm. We have made a number of adjustments and consulted with two companies, but it still happened. So, we checked with fire code and we are able to move the fire alarm outside of the room which we will do this summer. ~ Gavin

