



Specialists in Drinking Water Testing Technologies ■ Residential ■ Industrial ■ Municipal

PRECISION ANALYTICAL SERVICES, INC.

2161 WHITESVILLE ROAD TOMS RIVER, NJ 08755 PHONE 732-914-1515 FAX 732-914-1616

NJ Lab Cert. # 15001

CERTIFICATE OF ANALYSIS

Customer : Strategic Environmental
25 Butternut Lane
Bayville, NJ 08721

Project ID : Deal BOE - Deal ES -201 Roseld Ave.
PAS Project ID : P23-09288

Matrix : Drinking Water
Report Date : 8/18/2023

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P23-09288-01	Deal Elem Field Blank	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/14/23 07:07	8/15/23 15:02
P23-09288-02	DS #1 NE Hall	Lead	1.15 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/14/23 07:08	8/15/23 15:06
P23-09288-03	DS #2 Locker Room	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/14/23 07:09	8/15/23 15:22
P23-09288-04	DS #5 Principals Office	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/14/23 07:11	8/15/23 15:26
P23-09288-05	DS #6 Teachers Break Room	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/14/23 07:13	8/15/23 15:38
P23-09288-06	DS #7 1st Grade	Lead	1.57 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/14/23 07:18	8/15/23 15:42
P23-09288-07	DS #13 Kitchen Sink	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	8/14/23 07:22	8/15/23 15:46

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director