



ANALYTICAL REPORT

Apex Laboratories, LLC
6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Friday, February 3, 2023
Otto Rice
Dayton School District
780 Ferry Street / PO Box 219
Dayton, OR 97114

RE: A3A0791 - Drinking Water - [none]

Thank you for using Apex Laboratories. We greatly appreciate your business and strive to provide the highest quality services to the environmental industry.

Enclosed are the results of analyses for work order A3A0791, which was received by the laboratory on 1/24/2023 at 10:34:00AM.

If you have any questions concerning this report or the services we offer, please feel free to contact me by email at: jwoodcock@apex-labs.com, or by phone at 503-718-2323.

Please note: All samples will be disposed of within 30 days of sample receipt, unless prior arrangements have been made.

Cooler Receipt Information

(See Cooler Receipt Form for details)

Default Cooler	18.0 degC
----------------	-----------

This Final Report is the official version of the data results for this sample submission, unless superseded by a subsequent, labeled amended report.

All other deliverables derived from this data, including Electronic Data Deliverables (EDDs), CLP-like forms, client requested summary sheets, and all other products are considered secondary to this report.



Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Jason Woodcock, Project Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Dayton School District 780 Ferry Street / PO Box 219 Dayton, OR 97114	Project: Drinking Water Project Number: [none] Project Manager: Otto Rice	Report ID: A3A0791 - 02 03 23 1548
--	--	--

ANALYTICAL REPORT FOR SAMPLES

SAMPLE INFORMATION

Client Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
22531291-09013F22C	A3A0791-01	Drinking Water	01/24/23 00:00	01/24/23 10:34
22531291-101SF22C	A3A0791-02	Drinking Water	01/24/23 00:00	01/24/23 10:34
22531291-008BF22C	A3A0791-03	Drinking Water	01/24/23 00:00	01/24/23 10:34
22531291-013CF22C	A3A0791-04	Drinking Water	01/24/23 00:00	01/24/23 10:34
22531291-014CF22C	A3A0791-05	Drinking Water	01/24/23 00:00	01/24/23 10:34
22531291-016CF22C	A3A0791-06	Drinking Water	01/24/23 00:00	01/24/23 10:34
22531291-018SF22C	A3A0791-07	Drinking Water	01/24/23 00:00	01/24/23 10:34
22531291-021CF22C	A3A0791-08	Drinking Water	01/24/23 00:00	01/24/23 10:34
22531291-024CF22C	A3A0791-09	Drinking Water	01/24/23 00:00	01/24/23 10:34

Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Jason Woodcock, Project Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Dayton School District 780 Ferry Street / PO Box 219 Dayton, OR 97114	Project: Drinking Water Project Number: [none] Project Manager: Otto Rice	Report ID: A3A0791 - 02 03 23 1548
--	---	---

ANALYTICAL SAMPLE RESULTS

Total Metals in Drinking Water by EPA 200.8 (ICPMS)

Analyte	Sample Result	Detection Limit	Reporting Limit	Units	Dilution	Date Analyzed	Method Ref.	Notes
22531291-09013F22C (A3A0791-01)				Matrix: Drinking Water				
<u>Batch: 23A0994</u>								
Lead	1.34	---	0.200	ug/L	1	02/01/23 13:49	EPA 200.8	
22531291-101SF22C (A3A0791-02)				Matrix: Drinking Water				
<u>Batch: 23A0994</u>								
Lead	3.91	---	0.200	ug/L	1	02/01/23 14:08	EPA 200.8	
22531291-008BF22C (A3A0791-03)				Matrix: Drinking Water				
<u>Batch: 23A0994</u>								
Lead	12.1	---	0.200	ug/L	1	02/01/23 14:12	EPA 200.8	
22531291-013CF22C (A3A0791-04)				Matrix: Drinking Water				
<u>Batch: 23A0994</u>								
Lead	9.56	---	0.200	ug/L	1	02/01/23 14:16	EPA 200.8	
22531291-014CF22C (A3A0791-05)				Matrix: Drinking Water				
<u>Batch: 23A0994</u>								
Lead	6.33	---	0.200	ug/L	1	02/01/23 14:20	EPA 200.8	
22531291-016CF22C (A3A0791-06)				Matrix: Drinking Water				
<u>Batch: 23A0994</u>								
Lead	7.48	---	0.200	ug/L	1	02/01/23 14:24	EPA 200.8	
22531291-018SF22C (A3A0791-07)				Matrix: Drinking Water				
<u>Batch: 23B0062</u>								
Lead	10.5	---	0.222	ug/L	1	02/02/23 13:08	EPA 200.8	DW-D
22531291-021CF22C (A3A0791-08)				Matrix: Drinking Water				
<u>Batch: 23A0994</u>								
Lead	7.18	---	0.200	ug/L	1	02/01/23 14:28	EPA 200.8	
22531291-024CF22C (A3A0791-09)				Matrix: Drinking Water				
<u>Batch: 23A0994</u>								
Lead	1.83	---	0.200	ug/L	1	02/01/23 14:32	EPA 200.8	

Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Jason Woodcock, Project Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Dayton School District 780 Ferry Street / PO Box 219 Dayton, OR 97114	Project: Drinking Water Project Number: [none] Project Manager: Otto Rice	Report ID: A3A0791 - 02 03 23 1548
--	---	--

QUALITY CONTROL (QC) SAMPLE RESULTS

Total Metals in Drinking Water by EPA 200.8 (ICPMS)

Analyte	Result	Detection Limit	Reporting Limit	Units	Dilution	Spike Amount	Source Result	% REC	% REC Limits	RPD	RPD Limit	Notes
Batch 23A0994 - EPA 200.8 Direct Analysis						Drinking Water						
Blank (23A0994-BLK1)		Prepared: 01/27/23 08:16 Analyzed: 02/01/23 13:41										
<u>EPA 200.8</u>												
Lead	ND	---	0.200	ug/L	1	---	---	---	---	---	---	---
LCS (23A0994-BS1)		Prepared: 01/27/23 08:16 Analyzed: 02/01/23 13:45										
<u>EPA 200.8</u>												
Lead	15.6	---	0.201	ug/L	1	15.0	---	104	85 - 115%	---	---	---
Duplicate (23A0994-DUP1)		Prepared: 01/27/23 08:16 Analyzed: 02/01/23 13:53										
<u>QC Source Sample: 22531291-09013F22C (A3A0791-01)</u>												
<u>EPA 200.8</u>												
Lead	1.34	---	0.200	ug/L	1	---	1.34	---	---	0.4	20%	---
Matrix Spike (23A0994-MS1)		Prepared: 01/27/23 08:16 Analyzed: 02/01/23 13:57										
<u>QC Source Sample: 22531291-09013F22C (A3A0791-01)</u>												
<u>EPA 200.8</u>												
Lead	16.3	---	0.201	ug/L	1	15.0	1.34	100	70 - 130%	---	---	---
Batch 23B0062 - EPA 3015A						Drinking Water						
Blank (23B0062-BLK1)		Prepared: 02/02/23 08:03 Analyzed: 02/02/23 12:59										
<u>EPA 200.8</u>												
Lead	ND	---	0.222	ug/L	1	---	---	---	---	---	---	---
LCS (23B0062-BS1)		Prepared: 02/02/23 08:03 Analyzed: 02/02/23 13:04										
<u>EPA 200.8</u>												
Lead	18.3	---	0.222	ug/L	1	16.7	---	110	85 - 115%	---	---	---
Duplicate (23B0062-DUP1)		Prepared: 02/02/23 08:03 Analyzed: 02/02/23 13:13										
<u>QC Source Sample: 22531291-018SF22C (A3A0791-07)</u>												
<u>EPA 200.8</u>												
Lead	10.4	---	0.222	ug/L	1	---	10.5	---	---	0.8	20%	DW-D
Matrix Spike (23B0062-MS1)		Prepared: 02/02/23 08:03 Analyzed: 02/02/23 13:18										
<u>QC Source Sample: 22531291-018SF22C (A3A0791-07)</u>												

Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Jason Woodcock, Project Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
 Tigard, OR 97223
 503-718-2323
 ORELAP ID: OR100062

Dayton School District 780 Ferry Street / PO Box 219 Dayton, OR 97114	Project: Drinking Water Project Number: [none] Project Manager: Otto Rice	Report ID: A3A0791 - 02 03 23 1548
--	---	---

QUALITY CONTROL (QC) SAMPLE RESULTS

Total Metals in Drinking Water by EPA 200.8 (ICPMS)

Analyte	Result	Detection Limit	Reporting Limit	Units	Dilution	Spike Amount	Source Result	% REC	% REC Limits	RPD	RPD Limit	Notes
Batch 23B0062 - EPA 3015A						Drinking Water						
Matrix Spike (23B0062-MS1)		Prepared: 02/02/23 08:03 Analyzed: 02/02/23 13:18										
QC Source Sample: 22531291-018SF22C (A3A0791-07)												
EPA 200.8												
Lead	27.7	---	0.222	ug/L	1	16.7	10.5	103	70 - 130%	---	---	DW-D

Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Jason Woodcock, Project Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323

ORELAP ID: OR100062

Dayton School District 780 Ferry Street / PO Box 219 Dayton, OR 97114	Project: Drinking Water Project Number: [none] Project Manager: Otto Rice	Report ID: A3A0791 - 02 03 23 1548
--	---	---

SAMPLE PREPARATION INFORMATION

Total Metals in Drinking Water by EPA 200.8 (ICPMS)

<u>Prep: EPA 200.8 Direct Analysis</u>					Sample	Default	RL Prep
Lab Number	Matrix	Method	Sampled	Prepared	Initial/Final	Initial/Final	Factor
<u>Batch: 23A0994</u>							
A3A0791-01	Drinking Water	EPA 200.8	01/24/23 00:00	01/27/23 08:16	10mL/10mL	10mL/10mL	1.00
A3A0791-02	Drinking Water	EPA 200.8	01/24/23 00:00	01/27/23 08:16	10mL/10mL	10mL/10mL	1.00
A3A0791-03	Drinking Water	EPA 200.8	01/24/23 00:00	01/27/23 08:16	10mL/10mL	10mL/10mL	1.00
A3A0791-04	Drinking Water	EPA 200.8	01/24/23 00:00	01/27/23 08:16	10mL/10mL	10mL/10mL	1.00
A3A0791-05	Drinking Water	EPA 200.8	01/24/23 00:00	01/27/23 08:16	10mL/10mL	10mL/10mL	1.00
A3A0791-06	Drinking Water	EPA 200.8	01/24/23 00:00	01/27/23 08:16	10mL/10mL	10mL/10mL	1.00
A3A0791-08	Drinking Water	EPA 200.8	01/24/23 00:00	01/27/23 08:16	10mL/10mL	10mL/10mL	1.00
A3A0791-09	Drinking Water	EPA 200.8	01/24/23 00:00	01/27/23 08:16	10mL/10mL	10mL/10mL	1.00

<u>Prep: EPA 3015A</u>					Sample	Default	RL Prep
Lab Number	Matrix	Method	Sampled	Prepared	Initial/Final	Initial/Final	Factor
<u>Batch: 23B0062</u>							
A3A0791-07	Drinking Water	EPA 200.8	01/24/23 00:00	02/02/23 08:03	45mL/50mL	10mL/10mL	1.11

Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Jason Woodcock, Project Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Dayton School District 780 Ferry Street / PO Box 219 Dayton, OR 97114	Project: Drinking Water Project Number: [none] Project Manager: Otto Rice	Report ID: A3A0791 - 02 03 23 1548
--	--	--

QUALIFIER DEFINITIONS

Client Sample and Quality Control (QC) Sample Qualifier Definitions:

Apex Laboratories

DW-D Turbidity greater than 1 NTU. Sample was digested per EPA Method 200.8.

Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Jason Woodcock, Project Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Dayton School District 780 Ferry Street / PO Box 219 Dayton, OR 97114	Project: Drinking Water Project Number: [none] Project Manager: Otto Rice	Report ID: A3A0791 - 02 03 23 1548
--	---	---

REPORTING NOTES AND CONVENTIONS:

Abbreviations:

- DET Analyte DETECTED at or above the detection or reporting limit.
- ND Analyte NOT DETECTED at or above the detection or reporting limit.
- NR Result Not Reported.
- RPD Relative Percent Difference. RPDs for Matrix Spikes and Matrix Spike Duplicates are based on concentration, not recovery.

Detection Limits: Limit of Detection (LOD)

Limits of Detection (LODs) are normally set at a level of one half the validated Limit of Quantitation (LOQ).
If no value is listed ('-----'), then the data has not been evaluated below the Reporting Limit.

Reporting Limits: Limit of Quantitation (LOQ)

Validated Limits of Quantitation (LOQs) are reported as the Reporting Limits for all analyses where the LOQ, MRL, PQL or CRL are requested. The LOQ represents a level at or above the low point of the calibration curve, that has been validated according to Apex Laboratories' comprehensive LOQ policies and procedures.

Reporting Conventions:

- Basis: Results for soil samples are generally reported on a 100% dry weight basis.
The Result Basis is listed following the units as "dry", "wet", or "" (blank) designation.
- "dry" Sample results and Reporting Limits are reported on a dry weight basis. (i.e. "ug/kg dry")
See Percent Solids section for details of dry weight analysis.
- "wet" Sample results and Reporting Limits for this analysis are normally dry weight corrected, but have not been modified in this case.
- " " Results without 'wet' or 'dry' designation are not normally dry weight corrected. These results are considered 'As Received'.

QC Source:

In cases where there is insufficient sample provided for Sample Duplicates and/or Matrix Spikes, a Lab Control Sample Duplicate (LCS Dup) may be analyzed to demonstrate accuracy and precision of the extraction batch.

Non-Client Batch QC Samples (Duplicates and Matrix Spike/Duplicates) are not included in this report. Please request a Full QC report if this data is required.

Miscellaneous Notes:

- " --- " QC results are not applicable. For example, % Recoveries for Blanks and Duplicates, % RPD for Blanks, Blank Spikes and Matrix Spikes, etc.
- " *** " Used to indicate a possible discrepancy with the Sample and Sample Duplicate results when the %RPD is not available. In this case, either the Sample or the Sample Duplicate has a reportable result for this analyte, while the other is Non Detect (ND).

Blanks:

Standard practice is to evaluate the results from Blank QC Samples down to a level equal to 1/2 the Reporting Limit (RL).
-For Blank hits falling between 1/2 the RL and the RL (J flagged hits), the associated sample and QC data will receive a 'B-02' qualifier.
-For Blank hits above the RL, the associated sample and QC data will receive a 'B' qualifier, per Apex Laboratories' Blank Policy.
For further details, please request a copy of this document.

Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Jason Woodcock, Project Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Table with 3 columns: Client (Dayton School District), Project (Drinking Water), and Report ID (A3A0791 - 02 03 23 1548)

REPORTING NOTES AND CONVENTIONS (Cont.):

Blanks (Cont.):

Sample results flagged with a 'B' or 'B-02' qualifier are potentially biased high if the sample results are less than ten times the level found in the blank for inorganic analyses, or less than five times the level found in the blank for organic analyses.

'B' and 'B-02' qualifications are only applied to sample results detected above the Reporting Level.

Preparation Notes:

Mixed Matrix Samples:

Water Samples:

Water samples containing significant amounts of sediment are decanted or separated prior to extraction, and only the water portion analyzed, unless otherwise directed by the client.

Soil and Sediment Samples:

Soil and Sediment samples containing significant amounts of water are decanted prior to extraction, and only the solid portion analyzed, unless otherwise directed by the client.

Sampling and Preservation Notes:

Certain regulatory programs, such as National Pollutant Discharge Elimination System (NPDES), require that activities such as sample filtration (for dissolved metals, orthophosphate, hexavalent chromium, etc.) and testing of short hold analytes (pH, Dissolved Oxygen, etc.) be performed in the field (on-site) within a short time window.

Data users should be aware of which regulations pertain to the samples they submit for testing. If related sample collection activities are not approved for a particular regulatory program, results should be considered estimates.

Samples that have been filtered and preserved at Apex Laboratories per client request are listed in the preparation section of the report with the date and time of filtration listed.

Apex Laboratories maintains detailed records on sample receipt, including client label verification, cooler temperature, sample preservation, hold time compliance and field filtration. Data is qualified as necessary, and the lack of qualification indicates compliance with required parameters.

Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Jason Woodcock, Project Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Dayton School District 780 Ferry Street / PO Box 219 Dayton, OR 97114	Project: Drinking Water Project Number: [none] Project Manager: Otto Rice	Report ID: A3A0791 - 02 03 23 1548
--	--	--

LABORATORY ACCREDITATION INFORMATION

ORELAP Certification ID: OR100062 (Primary Accreditation)
EPA ID: OR01039

All methods and analytes reported from work performed at Apex Laboratories are included on Apex Laboratories' ORELAP Scope of Certification, with the exception of any analyte(s) listed below:

Apex Laboratories

Matrix	Analysis	TNI_ID	Analyte	TNI_ID	Accreditation
<u>All reported analytes are included in Apex Laboratories' current ORELAP scope.</u>					

Secondary Accreditations

Apex Laboratories also maintains reciprocal accreditation with non-TNI states (Washington DOE), as well as other state specific accreditations not listed here.

Subcontract Laboratory Accreditations

Subcontracted data falls outside of Apex Laboratories' Scope of Accreditation. Please see the Subcontract Laboratory report for full details, or contact your Project Manager for more information.

Field Testing Parameters

Results for Field Tested data are provided by the client or sampler, and fall outside of Apex Laboratories' Scope of Accreditation.

Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Jason Woodcock, Project Manager



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Dayton School District 780 Ferry Street / PO Box 219 Dayton, OR 97114	Project: Drinking Water Project Number: [none] Project Manager: Otto Rice	Report ID: A3A0791 - 02 03 23 1548
--	---	--

APEX LABS
6700 SW Sandburg St., Tigard, OR 97223 Ph: 503-718-2323

CHAIN OF CUSTODY

Lab # A3A0791 of COC of

Company: Dayton Unified School District Project Mgr: Otto Rice Project Name: Lead Water

Address: PO Box 219, Dayton, OR, 97114 Phone: 702-437-5670 Email: otto.rice@dayton.k12.or.us

Sampled by: Otto Rice

Site Location: _____

OR WA CA _____

AK ID _____

SAMPLE ID	DATE	TIME	MATRIX	# OF CONTAINERS	NWTPH-CD	NWTPH-DX	NWTPH-GX	8260 BTEX	8260 RBDM VOCs	8260 Halo VOCs	8260 VOCs Full List	8270 SIM PAHs	8270 Semi-Vols Full List	8082 PCBs	8081 Pesticides	RCRA Metals (8)	Priority Metals (13)	Al, Sb, As, Ba, Be, Cd, Cr, Co, Cu, Fe, Pb, Hg, Mg, Mn, Mo, Ni, Se, Ag, Na, Tl, V, Zn, TCIP, DISS, TCIP	TCIP Metals (8)	Hold Sample	Frozen Archive	
																						ANALYSIS REQUEST
22531291-13F22C	1/24/23																					
22531291-0115F22C																						
22531291-0088F22C																						
22531291-0136F22C																						
22531291-0146F22C																						
22531291-0166F22C																						
22531291-0185F22C																						
22531291-0216F22C																						
22531291-0246F22C																						

Standard Turn Around Time (TAT) = 10 Business Days

TAT Requested (circle): 1 Day 2 Day 3 Day 5 Day Standard Other: _____

SPECIAL INSTRUCTIONS: _____

RELINQUISHED BY: Signature: <u>[Signature]</u> Date: <u>1/24/23</u>	RECEIVED BY: Signature: <u>[Signature]</u> Date: <u>1/24/23</u>	RECEIVED BY: Signature: _____ Date: _____
Printed Name: <u>Otto Rice</u> Company: _____	Printed Name: <u>[Signature]</u> Company: _____	Printed Name: _____ Company: _____

Apex Laboratories

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.



ANALYTICAL REPORT

Apex Laboratories, LLC

6700 S.W. Sandburg Street
Tigard, OR 97223
503-718-2323
ORELAP ID: OR100062

Dayton School District 780 Ferry Street / PO Box 219 Dayton, OR 97114	Project: Drinking Water Project Number: [none] Project Manager: Otto Rice	Report ID: A3A0791 - 02 03 23 1548
--	---	--

APEX LABS COOLER RECEIPT FORM

Client: Dayton Unified School Element WO#: A3A0791

Project/Project #: Lead Water

Delivery Info:
 Date/time received: 1/24/23 @ 10:34 By: JS
 Delivered by: Apex Client ESS FedEx UPS Radio Morgan SDS Evergreen Other

Cooler Inspection Date/time inspected: 1/24/23 @ 10:36 By: JS

Chain of Custody included? Yes No
 Signed/dated by client? Yes No

	Cooler #1	Cooler #2	Cooler #3	Cooler #4	Cooler #5	Cooler #6	Cooler #7
Temperature (°C)	<u>18.0</u>						
Custody seals? (Y/N)	<u>N</u>						
Received on ice? (Y/N)	<u>N</u>						
Temp. blanks? (Y/N)	<u>n</u>						
Ice type: (Gel/Real/Other)	<u>n/A</u>						
Condition (In/Out):	<u>Out</u>						

Cooler out of temp? (Y/N) Possible reason why: Drinking Waters
 Green dots applied to out of temperature samples? Yes No
 Out of temperature samples form initiated? Yes No

Sample Inspection: Date/time inspected: 1/24/23 @ 12:06 By: AAW

All samples intact? Yes No Comments: _____

Bottle labels/COCs agree? Yes No Comments: _____

COC/container discrepancies form initiated? Yes No

Containers/volumes received appropriate for analysis? Yes No Comments: _____

Do VOA vials have visible headspace? Yes No NA
 Comments: _____

Water samples: pH checked: Yes No NA pH appropriate? Yes No NA
 Comments: _____

Additional information:

Labeled by: AAW Witness: ORS Cooler Inspected by: AAW
Form Y-003 R-00

Apex Laboratories

Jason Woodcock, Project Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.