



MINNEAPOLIS
PUBLIC SCHOOLS

Urban Education. Global Citizens.

Environmental Health & Safety
Office: (612) 668-0310
Direct: (612)-668-0307
Cell: (612) 806-1394

Jason Karpe
Safety Specialist,
Environmental Health & Safety

MEMORANDUM

TO: Heather Nelson, Coordinator, Leasing Administrator-Davis Center

FROM: Jason Karpe, Safety Specialist, Environmental Health & Safety (EH&S)

DATE: April 20, 2022

SUBJECT: **MPS-Davis Center District Office
Lead in Water Testing**

As part of the Minneapolis Public Schools (MPS) Lead in Water Safety Plan, EH&S sampled drinking water fixtures at Davis Center on April 8, 2022. All water was collected on a first draw basis with a minimum of six-hour system stagnation. This method represents the worst-case scenario for lead in water concentrations. A total of eighteen (18) drinking sources were tested. All sample locations tested none-detected for lead (see attached laboratory report).

Based on the laboratory results and new plumbing materials installed at the facility, Davis Center is not required to perform MPS Daily Lead in Water Flushing Protocols. As a good practice, EH&S recommends and encourages that all staff and students run drinking sources until cool before drinking.

This memorandum and the laboratory analysis report will be maintained available to the public on the MPS website:

http://facilities.mpls.k12.mn.us/lead_in_water_safety_plan

If you have any questions, you may contact me at your convenience at 612-668-0307.

Attachment: Laboratory Analysis Report dated April 15, 2022

cc: Lee Setter, Shawn Lindell, James Tschida, Joseph Hayes

Twin City Water Clinic Laboratory Test Report

Minnesota State Laboratory ID# 027-053-119
 Wisconsin State Laboratory ID# 105-10117
 Wisconsin DNR Lab ID #399073400

X No samples were subcontracted; or the above test result(s) with '**' designation were produced by a subcontracted laboratory. [Laboratory name; address; MDH Lab ID#]. The subcontracted laboratory maintains MDH Certification for the field(s) of testing performed.

Client: Davis Center Building
 Minneapolis Public Schools
Address: 1225 North 7th Street
 Minneapolis, MN 55411

Report Number: 22-03215
Sample Receipt Date: 4/8/22
Sample Prep. Date: 4/8/22
Sample Prep. Time: 11:00
Report Issue Date: 4/15/22

Twin City Water Clinic Inc.
 617 13th Avenue South
 Hopkins, MN 55343
Phone: (952)935-3556
Fax: (952)935-5077

Laboratory	Analyte	Sample	Parameter	Sample Collection		Sample Analysis		Test	
Sample ID		Location		Date	Time	Date	Time	Results	Units
22-03215	Lead	N5 (DF) bottle filler	Drinking Water	4/8/2022	05:10	04/11/22	10:58	<2.0	µg/L
22-03216	Lead	N4 (DF) bottle filler	Drinking Water	4/8/2022	05:13	04/11/22	11:04	<2.0	µg/L
22-03217	Lead	N4-008 Sink	Drinking Water	4/8/2022	05:15	04/11/22	11:10	<2.0	µg/L
22-03218	Lead	N3 (DF) bottle filler	Drinking Water	4/8/2022	05:20	04/11/22	11:16	<2.0	µg/L
22-03219	Lead	N3-008 Sink	Drinking Water	4/8/2022	05:21	04/11/22	11:21	<2.0	µg/L
22-03220	Lead	N2-DF	Drinking Water	4/8/2022	05:23	04/11/22	11:27	<2.0	µg/L
22-03221	Lead	N2-008	Drinking Water	4/8/2022	05:25	04/11/22	11:33	<2.0	µg/L
22-03222	Lead	N1-DF	Drinking Water	4/8/2022	05:29	04/11/22	11:38	<2.0	µg/L
22-03223	Lead	C4 - Lounge Sink	Drinking Water	4/8/2022	05:31	04/11/22	11:44	<2.0	µg/L
22-03224	Lead	S4-DF	Drinking Water	4/8/2022	05:35	04/13/22	12:04	<2.0	µg/L
22-03225	Lead	S4 - Work Area Sink	Drinking Water	4/8/2022	05:38	04/13/22	12:09	<2.0	µg/L
22-03226	Lead	S3 - Lounge	Drinking Water	4/8/2022	05:41	04/13/22	12:15	<2.0	µg/L
22-03227	Lead	S3-DF	Drinking Water	4/8/2022	05:44	04/13/22	12:21	<2.0	µg/L
22-03228	Lead	S3 - Work Area Sink	Drinking Water	4/8/2022	05:50	04/13/22	12:26	<2.0	µg/L
22-03229	Lead	S2 - Lounge Sink	Drinking Water	4/8/2022	05:55	04/13/22	12:32	<2.0	µg/L
22-03230	Lead	S2-DF	Drinking Water	4/8/2022	05:58	04/13/22	12:37	<2.0	µg/L
22-03231	Lead	S2 - Work Area Sink	Drinking Water	4/8/2022	05:59	04/13/22	12:43	<2.0	µg/L
22-03232	Lead	S1-DF	Drinking Water	4/8/2022	05:59	04/15/22	12:49	<2.0	µg/L

Approved methods used in analyzing the samples listed above have the following reporting levels:
 SM3113 - Lead, 2.0 µg / L
 Maximum contaminant level: Lead, 15.0 µg/L

Sample Collected by: Client TCWC

Sample Temp.: 6° C

Notes:

Discussion: DF = Drinking Fountain

Approved By:



Bill Van Arsdale
 Laboratory Manager

The results listed in this report apply only to the above listed samples. All routine quality assurance procedures were followed, unless otherwise noted. This analytical report must be reported in its entirety. All methods are certified by the Minnesota Department of Health, unless otherwise noted.