

Twin City Water Clinic Laboratory Test Report

Minnesota State Laboratory ID# 027-053-119
 Wisconsin State Laboratory ID# 105-10117
 Wisconsin DNR Lab ID #399073400

X No samples were subcontracted; or the above test result(s) with '**' designation were produced by a subcontracted laboratory. [Laboratory name; address; MDH Lab ID#]. The subcontracted laboratory maintains MDH Certification for the field(s) of testing performed.

Client: Transportation Center Building
 Minneapolis Public Schools
Address: 1225 North 7th Street
 Minneapolis, MN 55411

Report Number: 22-03167
Sample Receipt Date: 4/7/22
Sample Prep. Date: 4/7/22
Sample Prep. Time: 9:00
Report Issue Date: 4/8/22

Twin City Water Clinic Inc.
617 13th Avenue South
Hopkins, MN 55343
Phone: (952)935-3556
Fax: (952)935-5077

Laboratory	Analyte	Sample	Parameter	Sample Collection		Sample Analysis		Test	
Sample ID		Location		Date	Time	Date	Time	Results	Units
22-03167	Lead	Hallway 16 (DF) bottle filler	Drinking Water	4/7/2022	05:10	04/08/22	10:43	<2.0	µg/L
22-03168	Lead	Drivers Lounge 102 Sink	Drinking Water	4/7/2022	05:13	04/08/22	10:49	<2.0	µg/L
22-03169	Lead	Engineers Office 43 sink	Drinking Water	4/7/2022	05:15	04/08/22	10:54	<2.0	µg/L
22-03170	Lead	Restroom 116 sink	Drinking Water	4/7/2022	05:20	04/08/22	11:00	<2.0	µg/L


Approved methods used in analyzing the samples listed above have the following reporting levels:
 SM3113 - Lead, 2.0 µg / L
 Maximum contaminant level: Lead, 15.0 µg/L

Sample Collected by: X Client TCWC

Sample Temp.: 10° C

Notes:

Discussion: DF = Drinking Fountain

Approved By: 
 Bill Van Arsdale
 Laboratory Manager

The results listed in this report apply only to the above listed samples. All routine quality assurance procedures were followed, unless otherwise noted. This analytical report must be reported in its entirety. All methods are certified by the Minnesota Department of Health, unless otherwise noted.