



DISTRICT OFFICE FLOORING PROJECT

No. 0006-23-24

ADDENDUM #1

**DISTRICT OFFICE FLOORING PROJECT
RE-BID/PROJECT No. 0006-23-24**

Project: District Office Flooring Project

Owner: Lawndale Elementary School District
4161 W 147th St, Lawndale, CA 90260

Date Issued: November 17th, 2023

The clarifications, modifications, changes, additions, and/or deletions contained herein shall be incorporated within the construction documents for the project. Such information shall take precedence over that previously published.

GENERAL

Item A - Addendum Acknowledgement

Acknowledge receipt of this addendum on the space provided in the bid form.

Item B – Contractor's Questions and Answers

1. What type of mastic removal method do you require? Chemical removal? Three dimensional, etc. ? -**Chemical**
2. Can all Demo work be performed in one phase? We can still phase out the new flooring install in multiple phases, but it would helpful to remove and abate everything at once.-
Yes
3. What type of testing and air clearances does the district require? TEM or PCM? Onsite reading or ongoing progress sampling?- **TEM**

Item C - Clarifications

- 1) **Bathroom Flooring material to be provided by the district**
 - a. **Urethane material and all associated materials for the bathroom flooring to be provided by the District 436 sf total with 6” Cove 120lf total**

The rest of this page is intentionally left blank