



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

A3K0956

GANNETT FLEMING, INC. - PITTSBURGH PA

ERIC BUZZA
Foster Plaza 8 Suite 400 730 Holiday DR
PITTSBURGH, PA 15220

Project Name: Butler Area Intermediate School

Lead Testing-Butler Area School District

Project / PO Number: N/A

Received: 11/02/2023

Reported: 11/15/2023

Analytical Testing Parameters

Client Sample ID:	Office Men Fountain	Collected By:	Eric Buzza
Sample Matrix:	Drinking Water	Collection Date:	11/02/2023 7:42
Lab Sample ID:	A3K0956-01		

Metals Total by ICPMS	Result	Limit(s) ⁽¹⁾	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		11/09/23 1728	11/09/23 1728	SEV

Client Sample ID:	Office Women Fountain	Collected By:	Eric Buzza
Sample Matrix:	Drinking Water	Collection Date:	11/02/2023 7:43
Lab Sample ID:	A3K0956-02		

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		11/09/23 1738	11/09/23 1738	SEV

Client Sample ID:	Security Desk Fountain	Collected By:	Eric Buzza
Sample Matrix:	Drinking Water	Collection Date:	11/02/2023 7:40
Lab Sample ID:	A3K0956-03		

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		11/09/23 1741	11/09/23 1741	SEV

Client Sample ID:	Nurse's Desk Sink	Collected By:	Eric Buzza
Sample Matrix:	Drinking Water	Collection Date:	11/02/2023 7:45
Lab Sample ID:	A3K0956-04		

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0178	0.015	0.000400	mg/L		11/09/23 1743	11/09/23 1743	SEV

(1) The 0.015 mg/L limit is based on 1 L first-draw samples
BASD follows US EPA 3Ts recommendation which uses 250 mL
first-draw samples and a recommended limit of 0.020 mg/L.



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

A3K0956

Client Sample ID: Aux Gym Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 7:44
Lab Sample ID: A3K0956-05	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		11/09/23 1746	11/09/23 1746	SEV

Client Sample ID: Pool Left Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 7:49
Lab Sample ID: A3K0956-06	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		11/09/23 1749	11/09/23 1749	SEV

Client Sample ID: Pool Right Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 7:50
Lab Sample ID: A3K0956-07	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000493	0.015	0.000400	mg/L		11/09/23 1751	11/09/23 1751	SEV

Client Sample ID: Weight Room Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 7:52
Lab Sample ID: A3K0956-08	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		11/09/23 1754	11/09/23 1754	SEV

Client Sample ID: Training Room Sink	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 7:54
Lab Sample ID: A3K0956-09	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		11/09/23 1756	11/09/23 1756	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

A3K0956

Client Sample ID: Training Room Ice	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 7:55
Lab Sample ID: A3K0956-10	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		11/09/23 1759	11/09/23 1759	SEV

Client Sample ID: 141 Men Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 8:01
Lab Sample ID: A3K0956-11	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		11/09/23 1809	11/09/23 1809	SEV

Client Sample ID: Cafe B Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 7:59
Lab Sample ID: A3K0956-12	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		11/09/23 1819	11/09/23 1819	SEV

Client Sample ID: Cafe A Sink	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 7:13
Lab Sample ID: A3K0956-13	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00296	0.015	0.000400	mg/L		11/09/23 1822	11/09/23 1822	SEV

Client Sample ID: 140 Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 8:02
Lab Sample ID: A3K0956-14	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		11/09/23 1824	11/09/23 1824	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

A3K0956

Client Sample ID: 126 Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 8:03
Lab Sample ID: A3K0956-15	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000890	0.015	0.000400	mg/L		11/09/23 1827	11/09/23 1827	SEV

Client Sample ID: 124 Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 8:06
Lab Sample ID: A3K0956-16	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		11/09/23 1830	11/09/23 1830	SEV

Client Sample ID: Cafe A Fountain Back	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 8:08
Lab Sample ID: A3K0956-17	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		11/09/23 1832	11/09/23 1832	SEV

Client Sample ID: 108 Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 7:28
Lab Sample ID: A3K0956-18	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		11/09/23 1835	11/09/23 1835	SEV

Client Sample ID: 103 Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 7:39
Lab Sample ID: A3K0956-19	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		11/09/23 1837	11/09/23 1837	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

A3K0956

Client Sample ID: Lounge Sink	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 7:36
Lab Sample ID: A3K0956-20	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00159	0.015	0.000400	mg/L		11/09/23 1840	11/09/23 1840	SEV

Client Sample ID: JROTC 1 Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 7:39
Lab Sample ID: A3K0956-21	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		11/09/23 1858	11/09/23 1858	SEV

Client Sample ID: Cafe D Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 8:17
Lab Sample ID: A3K0956-22	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		11/09/23 1908	11/09/23 1908	SEV

Client Sample ID: 207 Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 8:18
Lab Sample ID: A3K0956-23	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		11/09/23 1911	11/09/23 1911	SEV

Client Sample ID: English WRR Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 8:11
Lab Sample ID: A3K0956-24	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		11/09/23 1913	11/09/23 1913	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

A3K0956

Client Sample ID: Cafe C Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 8:22
Lab Sample ID: A3K0956-25	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		11/09/23 1916	11/09/23 1916	SEV

Client Sample ID: 246 Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 8:15
Lab Sample ID: A3K0956-26	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		11/09/23 1918	11/09/23 1918	SEV

Client Sample ID: 243 Fountain	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 8:16
Lab Sample ID: A3K0956-27	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.000400	0.015	0.000400	mg/L		11/09/23 1921	11/09/23 1921	SEV

Client Sample ID: Room 115 Sink 1	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 7:26
Lab Sample ID: A3K0956-28	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00248	0.015	0.000400	mg/L		11/09/23 1923	11/09/23 1923	SEV

Client Sample ID: Room 115 Sink 2	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 7:27
Lab Sample ID: A3K0956-29	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00109	0.015	0.000400	mg/L		11/09/23 1926	11/09/23 1926	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

A3K0956

Client Sample ID: Room 115 Sink 3	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 7:25
Lab Sample ID: A3K0956-30	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000658	0.015	0.000400	mg/L		11/09/23 1928	11/09/23 1928	SEV

Client Sample ID: Room 115 Sink 4	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 7:27
Lab Sample ID: A3K0956-31	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00169	0.015	0.000400	mg/L		11/09/23 1939	11/09/23 1939	SEV

Client Sample ID: Room 115 Sink 5	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 7:28
Lab Sample ID: A3K0956-32	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000987	0.015	0.000400	mg/L		11/09/23 1949	11/09/23 1949	SEV

Client Sample ID: Rm 116 Sink 1	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 7:23
Lab Sample ID: A3K0956-33	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000983	0.015	0.000400	mg/L		11/09/23 1952	11/09/23 1952	SEV

Client Sample ID: Rm 116 Sink 2	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 7:21
Lab Sample ID: A3K0956-34	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000620	0.015	0.000400	mg/L		11/09/23 1954	11/09/23 1954	SEV



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

A3K0956

Client Sample ID: Rm 116 Sink 3	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 7:20
Lab Sample ID: A3K0956-35	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000907	0.015	0.000400	mg/L		11/09/23 1957	11/09/23 1957	SEV

Client Sample ID: Rm 116 Sink 4	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 7:20
Lab Sample ID: A3K0956-36	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000829	0.015	0.000400	mg/L		11/09/23 1959	11/09/23 1959	SEV

Client Sample ID: Rm 116 Sink 5	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 7:19
Lab Sample ID: A3K0956-37	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00121	0.015	0.000400	mg/L		11/09/23 2002	11/09/23 2002	SEV

Client Sample ID: Rm 116 Sink 6	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 7:17
Lab Sample ID: A3K0956-38	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.000847	0.015	0.000400	mg/L		11/09/23 2004	11/09/23 2004	SEV

Client Sample ID: Rm 116 Sink 7	Collected By: Eric Buzza
Sample Matrix: Drinking Water	Collection Date: 11/02/2023 7:16
Lab Sample ID: A3K0956-39	

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.00103	0.015	0.000400	mg/L		11/09/23 2007	11/09/23 2007	SEV

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

A3K0956

Definitions

mg/L: Milligrams per Liter
RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories Inc., Pittsburgh Division
02-00257

Pennsylvania Department of Environmental Protection
Pennsylvania Department of Environmental Protection - PARULE

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.***

Reviewed and Approved By:

Carolyn Vollentine
Service Center Manager
Reported: 11/15/2023 13:07



A 3 K 0 9 5 6

Gannett Fleming, Inc. - Pittsburgh, PA
PM: Carolyn Volentine

Lab Report Address
Client Name: Gannett Fleming, Inc.
Address: Foster Plaza 8, Suite 400, 730 Holiday Dr
City, State, Zip: Pittsburgh, PA 15220
Contact: Eric Buzza
Telephone No.: (412) 503-4343

Invoice Address
Client Name: Same
Address:
City, State, Zip:
Contact:
Telephone No.:

Turnaround Time
 Routine (5 to 7 business da,
 RUSH* (notify lab)

(needed by)
Report Type
 Results Only Level 1 Level 2 Level 3 Level 4 EDD

Therm ID
Holding Time **16.4°C T436**
Samples Received on Ice? Yes No N/A
Custody Seals Intact? Yes No N/A

Send Report via: Mail Fax e-mail (address) *ebuzza@gfnet.com*

Send Invoice via: Mail Fax e-mail (address)

Project: *Bullas Area School Dist*

Location: *Intermediate*

PO No.:

Compliance Monitoring? Yes No
 Agency/Program

Sampled by (PRINT): *Eric Buzza*

Sampler Signature: *E. Buzza*

Sampler Phone No.: *412 503 4343*

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types **	Additional Notes
	<i>See Attached</i>	<i>11/2/23</i>			<i>OW G</i>	<i>acid</i>		<i>read</i>

HNO₃ Preserved
HNO₃: *A305840*
Date: *11/2/23*
Time: *17:40*
Initials: *JAC*

Possible Hazard Identification Comments

Hazardous Non-Hazardous Radioactive

Sample Disposition Dispose as appropriate Return Archive

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Date/Time

Date/Time

Date/Time

Received By (signature)

Received By (signature)

Received By (signature)

Date/Time

Date/Time

Date/Time



Gannett Fleming, Inc. - Pittsburgh, PA
 PW: Carolyn Valentine

Butler Area School District
 Intermediate High School - 42

Location	Date	Time
Office Men Fountain	10/21/23	7:41
Office Women Fountain		7:43
Security Desk Fountain		7:40
Nurse's Desk Sink		7:45
Aux Gym Fountain		7:49
Pool Left Fountain		7:49
Pool Right Fountain		7:50
Weight Room Fountain		7:52
Training Room Sink		7:54
Training Room Ice		7:53
JROTC 141 Men Fountain		8:01
Café B Event Fountain		7:59
Café A Sink		7:13
140 4 Fountain		7:13
126 Fountain		8:02
124 Fountain		8:03
Café A Back Fountain		8:06
Café A Sink		8:09
116 Fountain		
115 Sink 1		
108 Fountain		7:22
Wood Shop Fountain		
103 Fountain		7:30
Lounge Sink		7:30
JROTC 1 Fountain		7:39
Café D Back Fountain		8:17
207 Fountain		8:18
English WRR Fountain		8:11
Café C Back Fountain		8:22
246 Fountain		8:13
243 Fountain		8:16
Rm 18 Sink 1		7:26
Rm 18 Sink 2	Room 115	7:26
Rm 18 Sink 3	Room 115	7:27
Rm 18 Sink 4	Room 115	7:25
Rm 18 Sink 5	Room 115	7:27
Rm 18 Sink 6	Room 116 Sink 1	7:29
Rm 115 Sink 2		7:21
Rm 115 Sink 3		7:20
Rm 115 Sink 4		7:20
Rm 115 Sink 5		7:19
Rm 115 Sink 6		7:17
Rm 116 Sink 7		7:16