

Pool Daily Log Sheet

Building _____ **Pool Name** _____ **Month** _____ **Year** _____

Date	Chlorine				PH		Alkali nity	Calcium Hardness	Temp	Flow Rate	Filter Pressure		Drain covers secure		Comments: CPO Initials
	Free		Combined		AM	PM					High	Low	Yes	No	
	AM	PM	AM	PM											
1															
2															
3															
4															
5															
6															
7															
8															
9															
10															
11															
12															
13															
14															
15															
16															
17															
18															
19															
20															
21															
22															
23															
24															
25															
26															
27															
28															
29															
30															
31															

Test emergency (911) phone _____ First aid kit in order _____

Ideal Ranges: Free chlorine (FAC): **1.0 - 5.0** Alkalinity: **80 - 120** Calcium hardness: **200 - 400**
 Combined chlorine: **<0.5** PH: **7.4 - 7.6** Total dissolved solids (TDS): **<2,000**

Scan to Facility Operation at the end of each month.