

DOCUMENT 00 90 01

ADDENDUM NO. 2

Date: November 27, 2023
Re: MILLBURY SCHOOL DOOR REPLACEMENT & SECURITY UPGRADES
To: PROSPECTIVE BIDDERS
From: DIXON SALO ARCHITECTS, INC.
300 Main Street, 1st Floor
Worcester, Massachusetts 01608-1505
Bid No.: #0186-2402

This Addendum forms part of and modifies the Bidding and Contract Documents dated November 1, 2023 for construction of the Millbury School Door Replacement & Security Upgrade project for the TOWN OF MILLBURY. Acknowledge receipt of this Addendum on the applicable Bid Form (Document 00 31 00, FORM FOR GENERAL BID and Document 00 35 00, FORM FOR SUB-BID).

This Addendum consists of two (2) pages.

Where any original item called for in the Project Manual or indicated on the Drawings is supplemented hereby, the supplemental requirements shall be considered as added thereto.

Where any original item is amended, voided, or superseded hereby, the other provisions of such items not specifically amended, voided, or superseded shall remain in effect.

This Addendum modifies, amends, revises, and supplements designated parts of the Drawings and Specifications and become part of the Contract Documents. It shall be the responsibility of the Contractor to notify all sub-contractors and suppliers of any changes or modifications contained in the Addendum relating to their work. No claim for additional compensation will be granted.

Contractor Questions:

Q1. Under A1 it states that the GC shall run all conduits per the drawings. The Electrical specs call for the EC to run it. Please clarify.

A1. The Electrical contractor shall be responsible for installation of all conduits per the electrical specifications. The General Contractor shall be responsible for coordination of the work.

Q2. Section 08110 3.01 B indicates that new frames shall be grouted before installation, but the details on the drawings do not indicate it.

A2. The new frames do not have to be grouted into the existing openings. The frames shall utilize masonry anchors (either existing if in reusable condition, or new) for the doors.

MILLBURY PUBLIC SCHOOLS
BID #0186-2402

MILLBURY SCHOOL DOOR REPLACEMENT & SECURITY UPGRADE
Millbury Jr./Sr. High School, 12 Martin Street, Millbury, MA 01527
Elmwood Street Elementary School, 40 Elmwood Street, Millbury, MA 01527

BID DUE DATE MODIFICATION:

1. This addendum shall modify the due date for filed sub-bids to **December 5th at 2 PM**. All other information for filed sub-bids shall remain the same.
2. This addendum shall modify the due date for general contractor bids to **December 12th at 2 PM**. All other information for general contractor bids shall remain the same.

END OF ADDENDUM NO. 2