Lead in School Drinking Water Report

Maltby Elementary School - Post-remediation

Date(s) collected: 2023-09-30
Date(s) analyzed: 2023-10-16

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
374166	Building C	Sink	Library Office	Only sink	Tap	5
374170	Building B	Sink	Music Room	Only sink	Tap	2
374172	Building B	Sink	Kitchen	Sink closest to cafeteria exit/entrance	Tap	2
374164	Building C	Sink	Room C-6	Only sink	Tap	1
374162	Building C	Sink	Room C-9	Only sink	Water Fountain	<1
374168	Building A	Sink	Room A-8	Only sink	Tap	<1
374174	Building B	Sink - Multi-Compartment	Kitchen	Closest to outdoor exit door	Sprayer	<1
374176	Building B	Sink - Multi-Compartment	Kitchen	Across from dishwasher	Tap	<1

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **leadfreekids@doh.wa.gov**