Lead in School Drinking Water Report

Monroe High School - Revisit

Date(s) collected: 2023-09-30
Date(s) analyzed: 2023-10-13

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
374093	Main Building	Fountain - Multi-Level	Next To Mens Restroom	Lower fountain	Water Fountain	4
374092	Main Building	Fountain - Multi-Level	Next To Womens Restroom	Lower fountain	Water Fountain	2
374094	Main Building	Sink	Student Store	Closest to classroom door	Tap	<1
374095	Main Building	Sink - Multi-Compartment	Student Store	Closest to drop down door	Tap	<1

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and

testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **leadfreekids@doh.wa.gov**