Lead in School Drinking Water Report

Chain Lake Elementary School - Post-remediation

Date(s) collected: 2023-09-30
Date(s) analyzed: 2023-10-20

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
374084	Administration Building	Sink	Kitchen	Across from dishwasher	Sprayer	1
374083	Administration Building	Sink	Kitchen	Closest to dish washer	Sprayer	<1
374085	Administration Building	Sink	Kitchen	Across from dishwasher	Tap	<1

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **leadfreekids@doh.wa.gov**