Lead in School Drinking Water Report

Hidden River Middle School - Post-remediation

Date(s) collected: 2023-09-30
Date(s) analyzed: 2023-10-20

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
374158	Main Building	Sink - Multi-Compartment	Band Room	Only sink right outlet	Tap	3
374154	Main Building	Sink	Room 103	Only sink	Water Fountain	1
374156	Main Building	Sink - Multi-Compartment	Band Room	Only sink	Tap	1
374160	Main Building	Sink	Choral Room	Only sink	Tap	1

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **leadfreekids@doh.wa.gov**