



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

James Eberts
Epic Environmental Services, LLC
80 Fork Bridge Road
Pittsgrove, NJ 08318

4/28/2022

Phone: (856) 205-1077
Fax: (856) 205-0413

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 4/19/2022. The results are tabulated on the attached data pages for the following client designated project:

Project ID: NJ DOE
Haddon Twp. BOE District Office

The reference number for these samples is EMSL Order #012206113. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Owen McKenna, Chemistry Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order:	012206113
CustomerID:	EPIC62
CustomerPO:	NJ-DOE
ProjectID:	NJ DOE

Attn: **James Eberts**
Epic Environmental Services, LLC
80 Fork Bridge Road
Pittsgrove, NJ 08318

Phone: (856) 205-1077
 Fax: (856) 205-0413
 Received: 4/19/2022 09:15 AM

Project: **Haddon Twp. BOE District Office**

Analytical Results

Client Sample Description BDOF-FB **Collected:** 4/15/2022 8:05:00 AM **Lab ID:** 012206113-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	4/25/2022 VD	4/25/2022 VD 16:00

Client Sample Description BDOF-SO-RR1 **Collected:** 4/15/2022 8:07:00 AM **Lab ID:** 012206113-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.17	1.00 ppb	4/25/2022 VD	4/25/2022 VD 16:04

Client Sample Description BDOF-SO-RR2 **Collected:** 4/15/2022 8:08:00 AM **Lab ID:** 012206113-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 ppb	4/25/2022 VD	4/25/2022 VD 16:06

Client Sample Description BDOF-WC-HALL **Collected:** 4/15/2022 8:10:00 AM **Lab ID:** 012206113-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.84	1.00 ppb	4/25/2022 VD	4/25/2022 VD 16:08

Client Sample Description BDOF-SO-BOARD **Collected:** 4/15/2022 8:11:00 AM **Lab ID:** 012206113-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.06	1.00 ppb	4/25/2022 VD	4/25/2022 VD 16:20



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>

EnvChemistry2@emsl.com

EMSL Order:	012206113
CustomerID:	EPIC62
CustomerPO:	NJ-DOE
ProjectID:	NJ DOE

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results