

ALL R.A. REG. TO HAVE FIRE DAMPERS
SEE GEN. NOTES DWG. M-8

LOCATIONS - WHERE DUCTS RUN THRU BAR JOISTS &
DUCT IS TOO LARGE TO PASS THRU. CUT BAR OR BARS TO
ACCOMMODATE. REINFORCE IF NECESSARY.

