

UNIT A
UNIT D

UNIT C
UNIT D

FOR SECTION THRU
AUDITORIUM SEE
HVAC DED. M-8

GENERAL NOTES:

1. ALL DUCT SIZES SHOWN ARE CLEAR INTERNAL DIMS.
2. ALL DUCTS SHALL HAVE 12" INTERNAL SMOOTHING.
3. ALL DUCTS SHALL RUN BETWEEN OR THROUGH JOISTS IN AERO AREA.
4. ALL DUCT CONDUITS TO LIGHT TESTERS SHALL BE PARALLEL DUCT.
5. FOR DETAILS OF CONTROLS, STARTERS, PANELS, ETC. ABOVE CORRIDOR C-3 SEE DED. M-9.
6. RADIATION TO WARE CONTAINERS COVERED AS INDICATED ELEMENT LENGTHS AS SCHEDULED.
7. SEE ELECTRICAL SPECIFICATIONS FOR LIGHT TESTERS.
8. FILTERS IN DOORS OF ENGLISH ROOM SHALL BE VICIOUS IMPINGEMENT TYPE AS AIR MAZE PER ORTUAL.
9. SEE DED. M-7 FOR SCHEDULES OF EQUIP. & DUTIES.
10. SEE DED. M-5 FOR DETAILS OF EQUIP.
11. SEE DED. M-6 FOR GENERAL NOTES.
12. SEE DED. M-6 FOR HVAC ZONE PLAN.

THIS DUCT RUN TO BE
TYPICAL OF DUCT RUNS
IN AERO AREA

ALL CONDUITS TO LIGHT TESTERS TO BE 3/4" FLUX.
ALL LIGHT TESTERS RATED AT 100 CFM EACH.

ALL CONDUITS TO LIGHT TESTERS TO BE 3/4" FLUX.
ALL LIGHT TESTERS RATED AT 100 CFM EACH.

UNIT E
UNIT D

HVAC FLOOR PLAN. UNIT D	
THE PARTNERSHIP OF LYONS · MATHER · LECHNER Architects	
BRIDGEPORT CONNECTICUT	
MIDDLE SCHOOL — HIGH SCHOOL	
SHEPAUG VALLEY REGIONAL SCHOOL DISTRICT NO. 12	
DATE 7-22-73	JOB NO. 055
DRAWN A.J.T.	CHECKED S.F.
REVISIONS	
M 4	