



Date: 2/19/20

Performed by: Andrew Tinklenberg

Location: Andersen School

RE: Radon Testing

INTRODUCTION

From February 10 – 13, 2020, radon testing was performed within Andersen School. The testing was performed in frequently-occupied ground contact rooms and rooms immediately above unoccupied spaces (crawl spaces and tunnels) that are in contact with the ground per the Environmental Protection Agency (EPA) and Minnesota Department of Health (MDH) guidelines.

SUMMARY OF FINDINGS

All of the areas that were tested were found to have radon gas levels below 4.0 picocuries per liter of air (pCi/L), which is the EPA and MDH action level. (Note: Rooms A, B, C & D were the blank samples.)

Please refer to the attached AirChek radon testing report and sample diagram for further information concerning the radon testing, areas that were tested, and the radon levels that were found to be present. Per MDH requirements, this information will be shared with the local regulatory agency (MDH). The information will also be posted on the EH&S webpage available through the main MPS website and maintained on file by EH&S.

If you have any questions regarding this information, please feel free to contact me. Thank you,

Andrew Tinklenberg
Safety Specialist, Environmental Health & Safety
Minneapolis Public Schools
Environmental Health & Safety - Facilities Dept.
andrew.tinklenberg@mpls.k12.mn.us
612-668-0306 Phone
612-668-0310 EH & S General Office
612-668-0275 Fax



I5554 / ANDREW TINKLENBERG / MINNEAPOLIS PUBLIC SCHOOLS

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
9360432	2020-02-10	7:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	OFFICE B101	ANDERSEN	1	1.2
9360433	2020-02-10	7:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	OFFICE B103	ANDERSEN	1	1.0
9360434	2020-02-10	7:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	OFFICE B126	ANDERSEN	1	2.2
9360435	2020-02-10	7:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	OFFICE B122	ANDERSEN	1	1.3
9360436	2020-02-10	7:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	CLASS B120	ANDERSEN	1	1.1
9360437	2020-02-10	7:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	CLASS B119	ANDERSEN	1	1.1
9360438	2020-02-10	7:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	CLASS B118	ANDERSEN	1	1.6
9360439	2020-02-10	7:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	CLASS B117	ANDERSEN	1	2.7
9360440	2020-02-10	7:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	MULTIPURPOSE B115	ANDERSEN	1	0.8
9360441	2020-02-10	7:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	OFFICE B132	ANDERSEN	1	0.8
9360442	2020-02-10	7:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	CLASS B110	ANDERSEN	1	1.7
9360443	2020-02-10	7:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	CLASS B107	ANDERSEN	1	0.9
9360444	2020-02-10	7:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	CLASS B106	ANDERSEN	1	1.7
9360445	2020-02-10	7:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	CLASS B105	ANDERSEN	1	1.7
9360446	2020-02-10	7:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	CLASS G108	ANDERSEN	1	1.1
9360447	2020-02-10	7:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	CLASS G110	ANDERSEN	1	1.1
9360448	2020-02-10	7:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	OFFICE/STOR. G112	ANDERSEN	1	0.9
9360449	2020-02-10	7:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	OFFICE G103	ANDERSEN	1	0.7
9360450	2020-02-10	7:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	GYM G100	ANDERSEN	1	0.6
9360451	2020-02-10	7:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	OFFICE C122	ANDERSEN	1	1.1
9360452	2020-02-10	8:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	CLASS C120	ANDERSEN	1	0.8
9360453	2020-02-10	8:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	CLASS C119	ANDERSEN	1	1.3
9360454	2020-02-10	8:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	CLASS C118	ANDERSEN	1	1.3
9360455	2020-02-10	8:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	CLASS C117	ANDERSEN	1	1.7
9360456	2020-02-10	8:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	CLASS C116	ANDERSEN	1	1.0
9360457	2020-02-10	8:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	MULTIPURPOSE C115	ANDERSEN	1	1.5
9360458	2020-02-10	8:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	OFFICE C132	ANDERSEN	1	0.9
9360459	2020-02-10	8:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	CLASS C112	ANDERSEN	1	1.5
9360460	2020-02-10	8:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	CLASS C107	ANDERSEN	1	1.8
9360461	2020-02-10	8:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	CLASS C106	ANDERSEN	1	1.5
9360462	2020-02-10	8:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	CLASS C105	ANDERSEN	1	1.2
9360463	2020-02-10	8:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	OFFICE C105A	ANDERSEN	1	1.5
9360464	2020-02-10	8:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	OFFICE C105C	ANDERSEN	1	1.0
9360465	2020-02-10	8:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	OFFICE F111	ANDERSEN	1	0.6
9360466	2020-02-10	8:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	CLASS F108	ANDERSEN	1	0.5


I5554 / ANDREW TINKLENBERG / MINNEAPOLIS PUBLIC SCHOOLS

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
9360467	2020-02-10	8:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	OFFICE F108B	ANDERSEN	1	0.8
9360468	2020-02-10	8:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	OFFICE F103	ANDERSEN	1	0.9
9360469	2020-02-10	8:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	GYM F100	ANDERSEN	1	1.9
9360470	2020-02-10	8:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	OFFICE A101	ANDERSEN	1	< 0.3
9360471	2020-02-10	8:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	OFFICE A103	ANDERSEN	1	0.7
9360472	2020-02-10	8:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	CLASS A105	ANDERSEN	1	1.6
9360473	2020-02-10	8:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	CLASS A106	ANDERSEN	1	1.6
9360474	2020-02-10	8:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	CLASS A107	ANDERSEN	1	1.3
9360475	2020-02-10	8:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	CLASS A112	ANDERSEN	1	1.2
9360476	2020-02-10	8:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	MULTIPURPOSE A115	ANDERSEN	1	1.5
9360477	2020-02-10	8:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	CLASS A117	ANDERSEN	1	1.8
9360478	2020-02-10	8:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	CLASS A118	ANDERSEN	1	1.0
9360479	2020-02-10	8:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	CLASS A119	ANDERSEN	1	0.8
9360480	2020-02-10	8:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	CLASS A 120	ANDERSEN	1	1.1
9360481	2020-02-10	8:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	OFFICE A122	ANDERSEN	1	1.1
9360482	2020-02-10	8:00 am	2020-02-13	3:00 pm	70	MPS	ANDERSEN	OFFICE A126	ANDERSEN	1	2.0
9360483	2020-02-10	9:00 am	2020-02-13	4:00 pm	70	MPS	ANDERSEN	CLASS 165	ANDERSEN	1	0.7
9360484	2020-02-10	9:00 am	2020-02-13	4:00 pm	70	MPS	ANDERSEN	STAFF H114	ANDERSEN	1	0.7
9360485	2020-02-10	9:00 am	2020-02-13	4:00 pm	70	MPS	ANDERSEN	LOBBY 128/COMP. 130	ANDERSEN	1	1.2
9360486	2020-02-10	9:00 am	2020-02-13	4:00 pm	70	MPS	ANDERSEN	OFFICE 129	ANDERSEN	1	1.2
9360487	2020-02-10	9:00 am	2020-02-13	4:00 pm	70	MPS	ANDERSEN	OFFICE 132	ANDERSEN	1	1.6
9360488	2020-02-10	9:00 am	2020-02-13	4:00 pm	70	MPS	ANDERSEN	OFFICE 133	ANDERSEN	1	0.8
9360489	2020-02-10	9:00 am	2020-02-13	4:00 pm	70	MPS	ANDERSEN	OFFICE 134	ANDERSEN	1	< 0.3
9360490	2020-02-10	9:00 am	2020-02-13	4:00 pm	70	MPS	ANDERSEN	CLASS 136	ANDERSEN	1	1.6
9360491	2020-02-10	9:00 am	2020-02-13	4:00 pm	70	MPS	ANDERSEN	CLASS 135	ANDERSEN	1	0.6
9360492	2020-02-10	9:00 am	2020-02-13	4:00 pm	70	MPS	ANDERSEN	HEALTH OFFICE 109	ANDERSEN	1	1.5
9360493	2020-02-10	9:00 am	2020-02-13	4:00 pm	70	MPS	ANDERSEN	OFFICE 116	ANDERSEN	1	1.2
9360494	2020-02-10	9:00 am	2020-02-13	4:00 pm	68	MPS	ANDERSEN	OPEN OFFICE 118	ANDERSEN	1	1.0
9360495	2020-02-10	9:00 am	2020-02-13	4:00 pm	70	MPS	ANDERSEN	OFFICE 123	ANDERSEN	1	0.8
9360496	2020-02-10	9:00 am	2020-02-13	4:00 pm	70	MPS	ANDERSEN	OFFICE 122	ANDERSEN	1	0.9
9360497	2020-02-10	9:00 am	2020-02-13	4:00 pm	70	MPS	ANDERSEN	OFFICE 121	ANDERSEN	1	1.4
9360498	2020-02-10	9:00 am	2020-02-13	4:00 pm	72	MPS	ANDERSEN	OFFICE 107	ANDERSEN	1	1.3
9360499	2020-02-10	9:00 am	2020-02-13	4:00 pm	70	MPS	ANDERSEN	OFFICE 106	ANDERSEN	1	1.8
9360500	2020-02-10	9:00 am	2020-02-13	4:00 pm	72	MPS	ANDERSEN	OFFICE 104	ANDERSEN	1	0.9
9360501	2020-02-10	9:00 am	2020-02-13	4:00 pm	70	MPS	ANDERSEN	MAIN OFFICE 102	ANDERSEN	1	1.4

I5554 / ANDREW TINKLENBERG / MINNEAPOLIS PUBLIC SCHOOLS

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
9360502	2020-02-10	9:00 am	2020-02-13	4:00 pm	70	MPS	ANDERSEN	OFFICE E102	ANDERSEN	1	1.9
9360503	2020-02-10	10:00 am	2020-02-13	4:00 pm	70	MPS	ANDERSEN	OFFICE E103	ANDERSEN	1	0.8
9360504	2020-02-10	10:00 am	2020-02-13	4:00 pm	70	MPS	ANDERSEN	CLASS E107	ANDERSEN	1	1.0
9360505	2020-02-10	10:00 am	2020-02-13	4:00 pm	70	MPS	ANDERSEN	OFFICE E108	ANDERSEN	1	0.9
9360506	2020-02-10	10:00 am	2020-02-13	4:00 pm	70	MPS	ANDERSEN	OFFICE E110	ANDERSEN	1	< 0.3
9360507	2020-02-10	10:00 am	2020-02-13	4:00 pm	70	MPS	ANDERSEN	CLASS E110B	ANDERSEN	1	0.6
9360508	2020-02-10	10:00 am	2020-02-13	4:00 pm	70	MPS	ANDERSEN	OFFICE E115	ANDERSEN	1	1.8
9360509	2020-02-10	10:00 am	2020-02-13	4:00 pm	70	MPS	ANDERSEN	OFFICE E118	ANDERSEN	1	1.6
9360510	2020-02-10	10:00 am	2020-02-13	4:00 pm	70	MPS	ANDERSEN	OFFICE E119	ANDERSEN	1	0.9
9360511	2020-02-10	10:00 am	2020-02-13	4:00 pm	70	MPS	ANDERSEN	OFFICE E120	ANDERSEN	1	0.8
9360512	2020-02-10	10:00 am	2020-02-13	4:00 pm	70	MPS	ANDERSEN	OFFICE M102	ANDERSEN	1	< 0.3
9360513	2020-02-10	10:00 am	2020-02-13	4:00 pm	70	MPS	ANDERSEN	ROOM A	ANDERSEN	1	< 0.3
9360514	2020-02-10	10:00 am	2020-02-13	4:00 pm	70	MPS	ANDERSEN	ROOM B	ANDERSEN	1	< 0.3
9360515	2020-02-10	10:00 am	2020-02-13	4:00 pm	70	MPS	ANDERSEN	ROOM C	ANDERSEN	1	< 0.3
9360516	2020-02-10	10:00 am	2020-02-13	4:00 pm	70	MPS	ANDERSEN	ROOM D	ANDERSEN	1	< 0.3

DIAGRAM #1 - RADON SAMPLE LOCATIONS



FIRST FLOOR PLAN

PREPARED ON: 2/10/20
BY: ANDREW TINKLENBERG
EH&S SAFETY SPECIALIST

ANDERSEN SCHOOL
1098 ANDERSON LANE
MINNEAPOLIS, MN 55407

MINNEAPOLIS
PUBLIC SCHOOLS
Urban Education. Global Citizens.

