



---

**Date:** 12/2/19  
**Performed by:** Andrew Tinklenberg  
**Location:** Sullivan-Anishinabe School  
**RE:** Radon Testing

## INTRODUCTION

From November 19 – 22, 2019, radon testing was performed within Sullivan-Anishinabe School. The testing was performed in frequently-occupied ground contact rooms and rooms immediately above unoccupied spaces (crawl spaces and tunnels) that are in contact with the ground per the Environmental Protection Agency (EPA) and Minnesota Department of Health (MDH) guidelines.

## SUMMARY OF FINDINGS

All of the areas that were tested were found to have radon gas levels below 4.0 picocuries per liter of air (pCi/L), which is the EPA and MDH action level. The test kit in Room 146 was tampered with/destroyed and could not be submitted for analysis. Since the radon levels throughout the building were found to be very low, re-testing in the space is not necessary. (Note: Rooms B, BB & BBB were the blank samples.)

Please refer to the attached AirChek radon testing report and sample diagrams for further information concerning the radon testing, areas that were tested, and the radon levels that were found to be present. Per MDH requirements, this information will be shared with the local regulatory agency (MDH). The information will also be posted on the EH&S webpage available through the main MPS website and maintained on file by EH&S.

If you have any questions regarding this information, please feel free to contact me. Thank you,

Andrew Tinklenberg  
Safety Specialist, Environmental Health & Safety  
Minneapolis Public Schools  
Environmental Health & Safety - Facilities Dept.  
[andrew.tinklenberg@mpls.k12.mn.us](mailto:andrew.tinklenberg@mpls.k12.mn.us)  
612-668-0306 Phone  
612-668-0310 EH & S General Office  
612-668-0275 Fax



## I5554 / ANDREW TINKLENBERG / MINNEAPOLIS PUBLIC SCHOOLS

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
9259344	2019-11-19	7:00 am	2019-11-22	7:00 am	67	MPS	SULLIVAN/ANISHINABE	STAFF 103	SULLIVAN/ANISHINABE	1	0.8
9259345	2019-11-19	7:00 am	2019-11-22	7:00 am	70	MPS	SULLIVAN/ANISHINABE	CLASS 104	SULLIVAN/ANISHINABE	1	0.6
9259346	2019-11-19	7:00 am	2019-11-22	7:00 am	70	MPS	SULLIVAN/ANISHINABE	COMPUTER 105	SULLIVAN/ANISHINABE	1	< 0.3
9259347	2019-11-19	7:00 am	2019-11-22	7:00 am	70	MPS	SULLIVAN/ANISHINABE	CLASS 106/108	SULLIVAN/ANISHINABE	1	0.7
9259348	2019-11-19	7:00 am	2019-11-22	7:00 am	70	MPS	SULLIVAN/ANISHINABE	CLASS 107	SULLIVAN/ANISHINABE	1	< 0.3
9259349	2019-11-19	7:00 am	2019-11-22	7:00 am	70	MPS	SULLIVAN/ANISHINABE	CLASS 109	SULLIVAN/ANISHINABE	1	< 0.3
9259350	2019-11-19	7:00 am	2019-11-22	7:00 am	70	MPS	SULLIVAN/ANISHINABE	CLASS 110	SULLIVAN/ANISHINABE	1	0.8
9259351	2019-11-19	7:00 am	2019-11-22	7:00 am	69	MPS	SULLIVAN/ANISHINABE	CLASS 112	SULLIVAN/ANISHINABE	1	< 0.3
9259352	2019-11-19	7:00 am	2019-11-22	7:00 am	72	MPS	SULLIVAN/ANISHINABE	CLASS 116/118	SULLIVAN/ANISHINABE	1	< 0.3
9259353	2019-11-19	7:00 am	2019-11-22	7:00 am	70	MPS	SULLIVAN/ANISHINABE	CLASS 114	SULLIVAN/ANISHINABE	1	< 0.3
9259354	2019-11-19	7:00 am	2019-11-22	7:00 am	70	MPS	SULLIVAN/ANISHINABE	MEDIA 115	SULLIVAN/ANISHINABE	1	< 0.3
9259355	2019-11-19	7:00 am	2019-11-22	7:00 am	73	MPS	SULLIVAN/ANISHINABE	CLASS 120	SULLIVAN/ANISHINABE	1	< 0.3
9259356	2019-11-19	7:00 am	2019-11-22	7:00 am	69	MPS	SULLIVAN/ANISHINABE	CLASS 122	SULLIVAN/ANISHINABE	1	< 0.3
9259357	2019-11-19	7:00 am	2019-11-22	7:00 am	70	MPS	SULLIVAN/ANISHINABE	CLASS 123	SULLIVAN/ANISHINABE	1	< 0.3
9259358	2019-11-19	7:00 am	2019-11-22	7:00 am	68	MPS	SULLIVAN/ANISHINABE	CLASS 125	SULLIVAN/ANISHINABE	1	< 0.3
9259359	2019-11-19	7:00 am	2019-11-22	7:00 am	70	MPS	SULLIVAN/ANISHINABE	CLASS 124	SULLIVAN/ANISHINABE	1	< 0.3
9259360	2019-11-19	7:00 am	2019-11-22	7:00 am	70	MPS	SULLIVAN/ANISHINABE	CLASS 126	SULLIVAN/ANISHINABE	1	0.7
9259361	2019-11-19	7:00 am	2019-11-22	7:00 am	70	MPS	SULLIVAN/ANISHINABE	CLASS 128	SULLIVAN/ANISHINABE	1	< 0.3
9259362	2019-11-19	7:00 am	2019-11-22	7:00 am	70	MPS	SULLIVAN/ANISHINABE	CLASS 130	SULLIVAN/ANISHINABE	1	< 0.3
9259363	2019-11-19	7:00 am	2019-11-22	7:00 am	70	MPS	SULLIVAN/ANISHINABE	CLASS 134	SULLIVAN/ANISHINABE	1	< 0.3
9259364	2019-11-19	7:00 am	2019-11-22	7:00 am	70	MPS	SULLIVAN/ANISHINABE	CLASS 136	SULLIVAN/ANISHINABE	1	0.6
9259365	2019-11-19	7:00 am	2019-11-22	7:00 am	68	MPS	SULLIVAN/ANISHINABE	CLASS 138	SULLIVAN/ANISHINABE	1	< 0.3
9259366	2019-11-19	7:00 am	2019-11-22	7:00 am	70	MPS	SULLIVAN/ANISHINABE	CLASS 140	SULLIVAN/ANISHINABE	1	< 0.3
9259367	2019-11-19	7:00 am	2019-11-22	7:00 am	70	MPS	SULLIVAN/ANISHINABE	CLASS 142	SULLIVAN/ANISHINABE	1	< 0.3
9259368	2019-11-19	7:00 am	2019-11-22	7:00 am	70	MPS	SULLIVAN/ANISHINABE	CLASS 144	SULLIVAN/ANISHINABE	1	< 0.3
9259370	2019-11-19	7:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	CLASS 150	SULLIVAN/ANISHINABE	1	< 0.3
9259371	2019-11-19	7:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	CLASS 152	SULLIVAN/ANISHINABE	1	< 0.3
9259372	2019-11-19	7:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	CLASS 141	SULLIVAN/ANISHINABE	1	< 0.3
9259373	2019-11-19	8:00 am	2019-11-22	8:00 am	71	MPS	SULLIVAN/ANISHINABE	OFFICE 141A	SULLIVAN/ANISHINABE	1	< 0.3
9259374	2019-11-19	8:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	CLASS 143	SULLIVAN/ANISHINABE	1	< 0.3
9259375	2019-11-19	8:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	COMPUTER 145	SULLIVAN/ANISHINABE	1	< 0.3
9259376	2019-11-19	8:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	CLASS 154	SULLIVAN/ANISHINABE	1	< 0.3
9259377	2019-11-19	8:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	CLASS 156	SULLIVAN/ANISHINABE	1	< 0.3
9259378	2019-11-19	8:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	CLASS 158	SULLIVAN/ANISHINABE	1	< 0.3
9259379	2019-11-19	8:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	CLASS 160	SULLIVAN/ANISHINABE	1	< 0.3

## I5554 / ANDREW TINKLENBERG / MINNEAPOLIS PUBLIC SCHOOLS

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
9259380	2019-11-19	8:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	CLASS 162	SULLIVAN/ANISHINABE	1	< 0.3
9259381	2019-11-19	8:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	MEDIA 083	SULLIVAN/ANISHINABE	1	0.6
9259382	2019-11-19	8:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	083A/B OFFICE	SULLIVAN/ANISHINABE	1	0.7
9259383	2019-11-19	8:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	HEALTH 085	SULLIVAN/ANISHINABE	1	< 0.3
9259384	2019-11-19	8:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	OFFICE 087	SULLIVAN/ANISHINABE	1	< 0.3
9259385	2019-11-19	8:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	OFFICE 089	SULLIVAN/ANISHINABE	1	< 0.3
9259386	2019-11-19	8:00 am	2019-11-22	8:00 am	73	MPS	SULLIVAN/ANISHINABE	CUSTODIAN 068	SULLIVAN/ANISHINABE	1	< 0.3
9259387	2019-11-19	8:00 am	2019-11-22	8:00 am	72	MPS	SULLIVAN/ANISHINABE	BREAK RM. 064	SULLIVAN/ANISHINABE	1	< 0.3
9259388	2019-11-19	8:00 am	2019-11-22	8:00 am	72	MPS	SULLIVAN/ANISHINABE	OFFICE 080A	SULLIVAN/ANISHINABE	1	< 0.3
9259389	2019-11-19	8:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	CAFETERIA 092	SULLIVAN/ANISHINABE	1	< 0.3
9259390	2019-11-19	8:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	CAFETERIA 413	SULLIVAN/ANISHINABE	1	< 0.3
9259391	2019-11-19	8:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	OFFICE 094	SULLIVAN/ANISHINABE	1	< 0.3
9259392	2019-11-19	8:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	OFFICE 094B	SULLIVAN/ANISHINABE	1	< 0.3
9259393	2019-11-19	8:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	OFFICE 094D	SULLIVAN/ANISHINABE	1	< 0.3
9259394	2019-11-19	8:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	BREAK RM. 094C	SULLIVAN/ANISHINABE	1	< 0.3
9259395	2019-11-19	8:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	OFFICE 094F	SULLIVAN/ANISHINABE	1	< 0.3
9259396	2019-11-19	8:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	OFFICE 394	SULLIVAN/ANISHINABE	1	0.6
9259397	2019-11-19	8:00 am	2019-11-22	8:00 am	68	MPS	SULLIVAN/ANISHINABE	OFFICE 394A	SULLIVAN/ANISHINABE	1	< 0.3
9259398	2019-11-19	8:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	OFFICE 394C	SULLIVAN/ANISHINABE	1	< 0.3
9259399	2019-11-19	8:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	OFFICE 394D	SULLIVAN/ANISHINABE	1	< 0.3
9259400	2019-11-19	8:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	OFFICE 398B	SULLIVAN/ANISHINABE	1	1.2
9259401	2019-11-19	8:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	AUDITORIUM 398	SULLIVAN/ANISHINABE	1	1.1
9259402	2019-11-19	8:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	GYM 402	SULLIVAN/ANISHINABE	1	0.5
9259403	2019-11-19	9:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	GYM 403	SULLIVAN/ANISHINABE	1	< 0.3
9259404	2019-11-19	9:00 am	2019-11-22	8:00 am	71	MPS	SULLIVAN/ANISHINABE	OFFICE 404	SULLIVAN/ANISHINABE	1	< 0.3
9259405	2019-11-19	9:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	GYM 405	SULLIVAN/ANISHINABE	1	0.5
9259406	2019-11-19	9:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	GYM 406	SULLIVAN/ANISHINABE	1	0.6
9259407	2019-11-19	9:00 am	2019-11-22	8:00 am	72	MPS	SULLIVAN/ANISHINABE	OFFICE 408	SULLIVAN/ANISHINABE	1	0.6
9259408	2019-11-19	9:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	OFFICE 100	SULLIVAN/ANISHINABE	1	0.7
9259409	2019-11-19	9:00 am	2019-11-22	8:00 am	68	MPS	SULLIVAN/ANISHINABE	OFFICE 100C	SULLIVAN/ANISHINABE	1	1.1
9259410	2019-11-19	9:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	OFFICE 100K	SULLIVAN/ANISHINABE	1	0.6
9259411	2019-11-19	9:00 am	2019-11-22	8:00 am	69	MPS	SULLIVAN/ANISHINABE	OFFICE 100D	SULLIVAN/ANISHINABE	1	0.8
9259412	2019-11-19	9:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	OFFICE 100E	SULLIVAN/ANISHINABE	1	0.6
9259413	2019-11-19	9:00 am	2019-11-22	8:00 am	72	MPS	SULLIVAN/ANISHINABE	OFFICE 100F	SULLIVAN/ANISHINABE	1	0.5
9259414	2019-11-19	9:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	ROOM B	SULLIVAN/ANISHINABE	1	< 0.3

**I5554 / ANDREW TINKLENBERG / MINNEAPOLIS PUBLIC SCHOOLS**


---

<b>Kit Number</b>	<b>Start Date</b>	<b>Start Time</b>	<b>End Date</b>	<b>End Time</b>	<b>Temp.</b>	<b>Facility</b>	<b>Building</b>	<b>Room</b>	<b>Project ID</b>	<b>Floor</b>	<b>Result</b>
9259415	2019-11-19	9:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	ROOM BB	SULLIVAN/ANISHINABE	1	< 0.3
9259416	2019-11-19	9:00 am	2019-11-22	8:00 am	70	MPS	SULLIVAN/ANISHINABE	ROOM BBB	SULLIVAN/ANISHINABE	1	< 0.3

---

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498

# DIAGRAM #1 - RADON SAMPLE LOCATIONS



FIRST FLOOR PLAN

PREPARED ON: 11/19/19  
 BY: ANDREW TINKLENBERG  
 EH&S SAFETY SPECIALIST

SULLIVAN/ANISHINABE  
 3100 E. 28th STREET  
 MINNEAPOLIS, MN 55406

MINNEAPOLIS  
 PUBLIC SCHOOLS  
 Urban Education. Global Citizens.

