



Date: 11/19/19

Performed by: Andrew Tinklenberg

Location: Waite Park School

RE: Radon Testing

INTRODUCTION

From November 12 – 15, 2019, radon testing was performed within Waite Park School. The testing was performed in frequently-occupied ground contact rooms and rooms immediately above unoccupied spaces (crawl spaces and tunnels) that are in contact with the ground per the Environmental Protection Agency (EPA) and Minnesota Department of Health (MDH) guidelines.

SUMMARY OF FINDINGS

All of the areas that were tested were found to have radon gas levels below 4.0 picocuries per liter of air (pCi/L), which is the EPA and MDH action level. (Note: Rooms B & BB were the blank samples.)

Please refer to the attached AirChek radon testing report and sample diagrams for further information concerning the radon testing, areas that were tested, and the radon levels that were found to be present. Per MDH requirements, this information will be shared with the local regulatory agency (MDH). The information will also be posted on the EH&S webpage available through the main MPS website and maintained on file by EH&S.

If you have any questions regarding this information, please feel free to contact me. Thank you,


Andrew Tinklenberg
Safety Specialist, Environmental Health & Safety
Minneapolis Public Schools
Environmental Health & Safety - Facilities Dept.
andrew.tinklenberg@mpls.k12.mn.us
612-668-0306 Phone
612-668-0310 EH & S General Office
612-668-0275 Fax



I5554 / ANDREW TINKLENBERG

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
9259244	2019-11-12	7:00 am	2019-11-15	7:00 am	68	MPS	WAITE PARK	CLASS 03	WAITE PARK	0	2.0
9259249	2019-11-12	7:00 am	2019-11-15	7:00 am	72	MPS	WAITE PARK	CLASS 101	WAITE PARK	1	< 0.3
9259252	2019-11-12	8:00 am	2019-11-15	7:00 am	68	MPS	WAITE PARK	CLASS 108	WAITE PARK	1	2.0
9259271	2019-11-12	8:00 am	2019-11-15	8:00 am	69	MPS	WAITE PARK	CLASS 124	WAITE PARK	1	0.6
9259257	2019-11-12	8:00 am	2019-11-15	7:00 am	69	MPS	WAITE PARK	MEDIA 103C	WAITE PARK	1	0.7
9259263	2019-11-12	8:00 am	2019-11-15	8:00 am	68	MPS	WAITE PARK	CLASS 118	WAITE PARK	1	< 0.3
9259268	2019-11-12	8:00 am	2019-11-15	8:00 am	69	MPS	WAITE PARK	CLASS 122	WAITE PARK	1	0.6
9259266	2019-11-12	8:00 am	2019-11-15	8:00 am	69	MPS	WAITE PARK	CLASS 120	WAITE PARK	1	< 0.3
9259247	2019-11-12	7:00 am	2019-11-15	7:00 am	71	MPS	WAITE PARK	BOOK ROOM 06	WAITE PARK	0	1.9
9259269	2019-11-12	8:00 am	2019-11-15	8:00 am	69	MPS	WAITE PARK	CLASS 123	WAITE PARK	1	< 0.3
9259255	2019-11-12	8:00 am	2019-11-15	7:00 am	69	MPS	WAITE PARK	CLASS 105	WAITE PARK	1	1.3
9259261	2019-11-12	8:00 am	2019-11-15	8:00 am	69	MPS	WAITE PARK	CLASS 115	WAITE PARK	1	0.7
9259242	2019-11-12	7:00 am	2019-11-15	7:00 am	70	MPS	WAITE PARK	CLASS 01	WAITE PARK	0	1.7
9259245	2019-11-12	7:00 am	2019-11-15	7:00 am	69	MPS	WAITE PARK	LUNCH 019	WAITE PARK	0	1.7
9259250	2019-11-12	7:00 am	2019-11-15	7:00 am	69	MPS	WAITE PARK	CLASS 102	WAITE PARK	1	0.7
9259253	2019-11-12	8:00 am	2019-11-15	7:00 am	67	MPS	WAITE PARK	CLASS 107	WAITE PARK	1	1.5
9259259	2019-11-12	8:00 am	2019-11-15	8:00 am	69	MPS	WAITE PARK	CLASS 114	WAITE PARK	1	< 0.3
9259258	2019-11-12	8:00 am	2019-11-15	8:00 am	69	MPS	WAITE PARK	CLASS 112	WAITE PARK	1	0.6
9259264	2019-11-12	8:00 am	2019-11-15	8:00 am	69	MPS	WAITE PARK	CLASS 117	WAITE PARK	1	0.5
9259243	2019-11-12	7:00 am	2019-11-15	7:00 am	68	MPS	WAITE PARK	SENSORY 02	WAITE PARK	0	1.2
9259251	2019-11-12	8:00 am	2019-11-15	7:00 am	70	MPS	WAITE PARK	CUSTODIAN 126	WAITE PARK	1	3.6
9259248	2019-11-12	7:00 am	2019-11-15	7:00 am	68	MPS	WAITE PARK	COMPUTER 04	WAITE PARK	0	3.0
9259270	2019-11-12	8:00 am	2019-11-15	8:00 am	68	MPS	WAITE PARK	CLASS 123A	WAITE PARK	1	< 0.3
9259256	2019-11-12	8:00 am	2019-11-15	7:00 am	68	MPS	WAITE PARK	CLASS 104	WAITE PARK	1	0.9
9259262	2019-11-12	8:00 am	2019-11-15	8:00 am	68	MPS	WAITE PARK	CLASS 116	WAITE PARK	1	< 0.3
9259267	2019-11-12	8:00 am	2019-11-15	8:00 am	69	MPS	WAITE PARK	CLASS 121	WAITE PARK	1	< 0.3
9259265	2019-11-12	8:00 am	2019-11-15	8:00 am	68	MPS	WAITE PARK	CLASS 119	WAITE PARK	1	0.6
9259246	2019-11-12	7:00 am	2019-11-15	7:00 am	72	MPS	WAITE PARK	AUDITORIUM 08	WAITE PARK	0	1.0
9259273	2019-11-12	8:00 am	2019-11-15	8:00 am	70	MPS	WAITE PARK	ROOM BB	WAITE PARK	1	< 0.3
9259254	2019-11-12	8:00 am	2019-11-15	7:00 am	68	MPS	WAITE PARK	CLASS 106	WAITE PARK	1	1.6
9259260	2019-11-12	8:00 am	2019-11-15	8:00 am	69	MPS	WAITE PARK	CLASS 113	WAITE PARK	1	0.7
9259272	2019-11-12	8:00 am	2019-11-15	8:00 am	70	MPS	WAITE PARK	ROOM B	WAITE PARK	1	< 0.3

DIAGRAM #2 - RADON SAMPLE LOCATION



FIRST FLOOR PLAN

PREPARED ON: 11/12/19
 BY: ANDREW TINKLENBERG
 EH&S SAFETY SPECIALIST

WAITE PARK SCHOOL
 1800 34TH AVE. N.
 MINNEAPOLIS, MN 55418

MINNEAPOLIS
 PUBLIC SCHOOLS
 Urban Education. Global Citizens.

