



Date: 11/13/19

Performed by: Andrew Tinklenberg

Location: Wenonah School

RE: Radon Testing

INTRODUCTION

From November 4 – 7, 2019, radon testing was performed within Wenonah School. The testing was performed in frequently-occupied ground contact rooms and rooms immediately above unoccupied spaces (crawl spaces and tunnels) that are in contact with the ground per the Environmental Protection Agency (EPA) and Minnesota Department of Health (MDH) guidelines.

SUMMARY OF FINDINGS

All of the areas that were tested were found to have radon gas levels below 4.0 picocuries per liter of air (pCi/L), which is the EPA and MDH action level. (Note: Rooms B & BB were the blank samples.)

Please refer to the attached AirChek radon testing report and sample diagram for further information concerning the radon testing, areas that were tested, and the radon levels that were found to be present. Per MDH requirements, this information will be shared with the local regulatory agency (MDH). The information will also be posted on the EH&S webpage available through the main MPS website and maintained on file by EH&S.

If you have any questions regarding this information, please feel free to contact me. Thank you,


Andrew Tinklenberg
Safety Specialist, Environmental Health & Safety
Minneapolis Public Schools
Environmental Health & Safety - Facilities Dept.
andrew.tinklenberg@mpls.k12.mn.us
612-668-0306 Phone
612-668-0310 EH & S General Office
612-668-0275 Fax



I5554 / ANDREW TINKLENBERG / MINNEAPOLIS PUBLIC SCHOOLS

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
9175560	2019-11-04	7:00 am	2019-11-07	7:00 am	68	WENONAH SCHOOL	N/A	CUSTODIAN OFFICE 127		1	< 0.3
9175561	2019-11-04	7:00 am	2019-11-07	7:00 am	70	WENONAH SCHOOL		CAFETERIA 122		1	< 0.3
9175562	2019-11-04	7:00 am	2019-11-07	7:00 am	70	WENONAH SCHOOL		OFFICE 121		1	< 0.3
9175563	2019-11-04	7:00 am	2019-11-07	7:00 am	67	WENONAH SCHOOL		GYM 119		1	0.7
9175564	2019-11-04	7:00 am	2019-11-07	7:00 am	67	WENONAH SCHOOL		GYM OFFICE 119A		1	< 0.3
9175565	2019-11-04	7:00 am	2019-11-07	7:00 am	68	WENONAH SCHOOL		OFFICE 118C		1	0.9
9175566	2019-11-04	7:00 am	2019-11-07	7:00 am	68	WENONAH SCHOOL		OFFICE 118		1	1.8
9175567	2019-11-04	7:00 am	2019-11-07	7:00 am	68	WENONAH SCHOOL		OFFICE 118B		1	1.5
9175568	2019-11-04	7:00 am	2019-11-07	7:00 am	68	WENONAH SCHOOL		OFFICE 118E		1	1.8
9175569	2019-11-04	7:00 am	2019-11-07	7:00 am	68	WENONAH SCHOOL		OFFICE 118F		1	2.0
9175570	2019-11-04	7:00 am	2019-11-07	7:00 am	68	WENONAH SCHOOL		STAFF 116		1	2.0
9175571	2019-11-04	7:00 am	2019-11-07	7:00 am	70	WENONAH SCHOOL		SPEECH 117B		1	0.9
9175572	2019-11-04	7:00 am	2019-11-07	7:00 am	70	WENONAH SCHOOL		117 MEDIA CENTER		1	0.8
9175573	2019-11-04	7:00 am	2019-11-07	7:00 am	70	WENONAH SCHOOL		CLASSROOM 104		1	1.3
9175574	2019-11-04	8:00 am	2019-11-07	7:00 am	70	WENONAH SCHOOL		CLASSROOM 102		1	1.7
9175575	2019-11-04	8:00 am	2019-11-07	7:00 am	70	WENONAH SCHOOL		CLASSROOM 105		1	2.0
9175576	2019-11-04	8:00 am	2019-11-07	7:00 am	70	WENONAH SCHOOL		CLASSROOM 103		1	1.6
9175577	2019-11-04	8:00 am	2019-11-07	7:00 am	70	WENONAH SCHOOL		CLASSROOM 100		1	1.7
9175578	2019-11-04	8:00 am	2019-11-07	7:00 am	70	WENONAH SCHOOL		CLASSROOM 101		1	2.0
9175579	2019-11-04	8:00 am	2019-11-07	7:00 am	70	WENONAH SCHOOL		122A MPLS. KIDS		1	< 0.3
9175580	2019-11-04	8:00 am	2019-11-07	7:00 am	70	WENONAH SCHOOL		CLASSROOM 106		1	1.5
9175581	2019-11-04	8:00 am	2019-11-07	7:00 am	70	WENONAH SCHOOL		CLASSROOM 107		1	1.6
9175582	2019-11-04	8:00 am	2019-11-07	7:00 am	70	WENONAH SCHOOL		CLASSROOM 109		1	1.6
9175583	2019-11-04	8:00 am	2019-11-07	7:00 am	70	WENONAH SCHOOL		CLASSROOM 108		1	2.4
9175584	2019-11-04	8:00 am	2019-11-07	7:00 am	70	WENONAH SCHOOL		CLASSROOM 110		1	1.4
9175585	2019-11-04	8:00 am	2019-11-07	7:00 am	70	WENONAH SCHOOL		CLASSROOM 111		1	1.6
9175586	2019-11-04	8:00 am	2019-11-07	7:00 am	70	WENONAH SCHOOL		OFFICE 110A		1	0.9
9175587	2019-11-04	8:00 am	2019-11-07	7:00 am	68	WENONAH SCHOOL		CLASSROOM 113		1	0.9
9175588	2019-11-04	8:00 am	2019-11-07	7:00 am	68	WENONAH SCHOOL		CLASSROOM 115		1	1.0
9175589	2019-11-04	8:00 am	2019-11-07	7:00 am	70	WENONAH SCHOOL		CLASSROOM 114		1	1.3
9175590	2019-11-04	8:00 am	2019-11-07	7:00 am	70	WENONAH SCHOOL		CLASSROOM 112A		1	0.8
9175591	2019-11-04	8:00 am	2019-11-07	7:00 am	70	WENONAH SCHOOL		CLASSROOM 112		1	1.7
9175592	2019-11-04	8:00 am	2019-11-07	7:00 am	70	WENONAH SCHOOL		B		1	< 0.3
9175593	2019-11-04	8:00 am	2019-11-07	7:00 am	70	WENONAH SCHOOL		BB		1	< 0.3

DIAGRAM #1 - RADON SAMPLE LOCATIONS



FIRST FLOOR PLAN

PREPARED ON: 11/4/19
 BY: ANDREW TINKLENBERG
 EH&S SAFETY SPECIALIST

WENONAH SCHOOL
 5625 23rd AVE. S.
 MINNEAPOLIS, MN 55417

MINNEAPOLIS
 PUBLIC SCHOOLS
 Urban Education. Global Citizens.

