



Date: 1/29/20

Performed by: Andrew Tinklenberg

Location: Bancroft School

RE: Radon Testing

INTRODUCTION

From January 21 – 24, 2020, radon testing was performed within Bancroft School. The testing was performed in frequently-occupied ground contact rooms and rooms immediately above unoccupied spaces (crawl spaces and tunnels) that are in contact with the ground per the Environmental Protection Agency (EPA) and Minnesota Department of Health (MDH) guidelines.

SUMMARY OF FINDINGS

All of the areas that were tested were found to have radon gas levels below 4.0 picocuries per liter of air (pCi/L), which is the EPA and MDH action level. (Note: Rooms B & BB were the blank samples.)

Please refer to the attached AirChek radon testing report and sample diagrams for further information concerning the radon testing, areas that were tested, and the radon levels that were found to be present. Per MDH requirements, this information will be shared with the local regulatory agency (MDH). The information will also be posted on the EH&S webpage available through the main MPS website and maintained on file by EH&S.

If you have any questions regarding this information, please feel free to contact me. Thank you,


Andrew Tinklenberg
Safety Specialist, Environmental Health & Safety
Minneapolis Public Schools
Environmental Health & Safety - Facilities Dept.
andrew.tinklenberg@mpls.k12.mn.us
612-668-0306 Phone
612-668-0310 EH & S General Office
612-668-0275 Fax



I5554 / ANDREW TINKLENBERG / MINNEAPOLIS PUBLIC SCHOOLS

Kit Number	Start Date	Start Time	End Date	End Time	Temp.	Facility	Building	Room	Project ID	Floor	Result
9259872	2020-01-21	8:00 am	2020-01-24	7:00 am	68	BANCROFT	BANCROFT	OFFICE 46C	BANCROFT	1	1.0
9259873	2020-01-21	8:00 am	2020-01-24	7:00 am	69	BANCROFT	BANCROFT	OFFICE 46B	BANCROFT	1	1.0
9259874	2020-01-21	8:00 am	2020-01-24	7:00 am	70	BANCROFT	BANCROFT	OFFICE 46A	BANCROFT	1	1.5
9259875	2020-01-21	8:00 am	2020-01-24	7:00 am	68	BANCROFT	BANCROFT	CLASS 45	BANCROFT	1	< 0.3
9259876	2020-01-21	8:00 am	2020-01-24	7:00 am	70	BANCROFT	BANCROFT	CLASS 44	BANCROFT	1	2.4
9259877	2020-01-21	8:00 am	2020-01-24	7:00 am	69	BANCROFT	BANCROFT	CLASS 43	BANCROFT	1	0.5
9259878	2020-01-21	8:00 am	2020-01-24	7:00 am	68	BANCROFT	BANCROFT	CLASS 41	BANCROFT	1	1.5
9259879	2020-01-21	8:00 am	2020-01-24	7:00 am	69	BANCROFT	BANCROFT	CLASS 39	BANCROFT	1	2.4
9259880	2020-01-21	8:00 am	2020-01-24	7:00 am	68	BANCROFT	BANCROFT	CLASS 37	BANCROFT	1	2.3
9259881	2020-01-21	8:00 am	2020-01-24	7:00 am	68	BANCROFT	BANCROFT	STAFF 32	BANCROFT	1	1.5
9259882	2020-01-21	8:00 am	2020-01-24	7:00 am	67	BANCROFT	BANCROFT	CLASS 29	BANCROFT	1	3.2
9259883	2020-01-21	8:00 am	2020-01-24	7:00 am	67	BANCROFT	BANCROFT	CLASS 27	BANCROFT	1	3.5
9259884	2020-01-21	8:00 am	2020-01-24	7:00 am	70	BANCROFT	BANCROFT	OFFICE 25	BANCROFT	1	2.3
9259885	2020-01-21	8:00 am	2020-01-24	7:00 am	72	BANCROFT	BANCROFT	CLASS 23	BANCROFT	1	2.0
9259886	2020-01-21	8:00 am	2020-01-24	8:00 am	72	BANCROFT	BANCROFT	CLASS 21	BANCROFT	1	0.8
9259887	2020-01-21	8:00 am	2020-01-24	8:00 am	68	BANCROFT	BANCROFT	GYM 17	BANCROFT	1	1.1
9259888	2020-01-21	8:00 am	2020-01-24	8:00 am	67	BANCROFT	BANCROFT	OFFICE 15A	BANCROFT	1	1.1
9259889	2020-01-21	9:00 am	2020-01-24	8:00 am	68	BANCROFT	BANCROFT	CAFETERIA 16	BANCROFT	1	0.9
9259890	2020-01-21	9:00 am	2020-01-24	8:00 am	67	BANCROFT	BANCROFT	OFFICE 16A	BANCROFT	1	1.2
9259891	2020-01-21	9:00 am	2020-01-24	8:00 am	69	BANCROFT	BANCROFT	MAIN OFFICE 12	BANCROFT	1	1.1
9259892	2020-01-21	9:00 am	2020-01-24	8:00 am	68	BANCROFT	BANCROFT	OFFICE 12A	BANCROFT	1	1.2
9259893	2020-01-21	9:00 am	2020-01-24	8:00 am	68	BANCROFT	BANCROFT	OFFICE 12B	BANCROFT	1	0.6
9259894	2020-01-21	9:00 am	2020-01-24	8:00 am	72	BANCROFT	BANCROFT	OFFICE 12C	BANCROFT	1	1.4
9259895	2020-01-21	9:00 am	2020-01-24	8:00 am	69	BANCROFT	BANCROFT	OFFICE 14	BANCROFT	1	1.6
9259896	2020-01-21	9:00 am	2020-01-24	8:00 am	69	BANCROFT	BANCROFT	OFFICE 14A	BANCROFT	1	1.1
9259897	2020-01-21	9:00 am	2020-01-24	8:00 am	70	BANCROFT	BANCROFT	ROOM B	BANCROFT	1	< 0.3
9259898	2020-01-21	9:00 am	2020-01-24	8:00 am	70	BANCROFT	BANCROFT	ROOM BB	BANCROFT	1	< 0.3

DIAGRAM #1 - RADON SAMPLE LOCATIONS



FIRST FLOOR PLAN

PREPARED ON: 1/21/20
 BY: ANDREW TINKLENBERG
 EH&S SAFETY SPECIALIST

BANCROFT SCHOOL
 3829 13TH AVE. S.
 MINNEAPOLIS, MN 55407

MINNEAPOLIS
 PUBLIC SCHOOLS
 Urban Education. Global Citizens.

