

## Radon Testing

The following summary provides results of radon testing performed at this location.

Room	Start	Stop	Result	Variance	Comment
BLANK	2017-04-17	2017-04-20	< 0.3	0.3	
MAIN OFFICE	2017-04-17	2017-04-20	< 0.3	0.3	
FACULTY ROOM	2017-04-17	2017-04-20	0.5	0.3	
FACULTY-DUP	2017-04-17	2017-04-20	< 0.3	0.3	
CUSTODIAL OFFICE	2017-04-17	2017-04-20	0.8	0.3	
COMMONS-1	2017-04-17	2017-04-20	0.5	0.3	
COMMONS-2	2017-04-17	2017-04-20	< 0.3	0.2	
OFFICE MAN.	2017-04-17	2017-04-20	0.7	0.3	
RECORDS ROOM	2017-04-17	2017-04-20	0.6	0.3	
COUNSELING SEC.	2017-04-17	2017-04-20	0.7	0.3	
CONFERENCE	2017-04-17	2017-04-20	< 0.3	0.3	
OFFICE FISHBOWL	2017-04-17	2017-04-20	< 0.3	0.3	
STUDENT MANAGER	2017-04-17	2017-04-20	0.6	0.3	
HEALTH	2017-04-17	2017-04-20	0.6	0.3	
MAIL/WORKROOM	2017-04-17	2017-04-20	< 0.3	0.3	
PRINCIPAL	2017-04-17	2017-04-20	< 0.3	0.3	
ASST. PRINCIPAL	2017-04-17	2017-04-20	0.7	0.3	
1	2017-04-17	2017-04-20	0.8	0.3	

Room	Start	Stop	Result	Variance	Comment
2	2017-04-17	2017-04-20	< 0.3	0.3	
3	2017-04-17	2017-04-20	0.8	0.3	
4	2017-04-17	2017-04-20	0.6	0.3	
5	2017-04-17	2017-04-20	< 0.3	0.3	
6	2017-04-17	2017-04-20	< 0.3	0.3	
7	2017-04-17	2017-04-20	< 0.3	0.3	
8	2017-04-17	2017-04-20	0.7	0.3	
9	2017-04-17	2017-04-20	< 0.3	0.3	
10	2017-04-17	2017-04-20	< 0.3	0.3	
11	2017-04-17	2017-04-20	0.5	0.3	
12-VOID (Tamper-Kit closed)	2017-04-17		N/A	N/A	
13	2017-04-17	2017-04-20	< 0.3	0.3	
16	2017-04-17	2017-04-20	0.6	0.3	
14-TESTING No Access	2017-04-17		N/A	N/A	
18	2017-04-17	2017-04-20	0.7	0.3	
SCIENCE RESOURCE	2017-04-17	2017-04-20	0.6	0.3	
19	2017-04-17	2017-04-20	< 0.3	0.3	
20	2017-04-17	2017-04-20	< 0.3	0.3	
21	2017-04-17	2017-04-20	0.6	0.3	
22	2017-04-17	2017-04-20	< 0.3	0.3	

Room	Start	Stop	Result	Variance	Comment
23	2017-04-17	2017-04-20	< 0.3	0.3	
24	2017-04-17	2017-04-20	0.8	0.3	
25	2017-04-17	2017-04-20	0.8	0.3	
17	2017-04-17	2017-04-20	0.5	0.3	
17-DUP.	2017-04-17	2017-04-20	< 0.3	0.3	
15	2017-04-17	2017-04-20	< 0.3	0.3	
26	2017-04-17	2017-04-20	0.5	0.3	
27	2017-04-17	2017-04-20	0.9	0.3	
28	2017-04-17	2017-04-20	0.9	0.3	
29	2017-04-17	2017-04-20	0.7	0.3	
30	2017-04-17	2017-04-20	< 0.3	0.3	
STAGE	2017-04-17	2017-04-20	0.6	0.3	
MAIN GYM-1	2017-04-17	2017-04-20	0.8	0.3	
MAIN GYM-2	2017-04-17	2017-04-20	0.5	0.3	
AUX GYM-1	2017-04-17	2017-04-20	0.6	0.3	
AUX GYM-2	2017-04-17	2017-04-20	< 0.3	0.3	
BOYS PE OFFICE	2017-04-17	2017-04-20	0.6	0.3	
GIRLS PE OFFICE	2017-04-17	2017-04-20	< 0.3	0.3	
LIBRARY-1	2017-04-17	2017-04-20	0.9	0.3	
LIBRARY-2	2017-04-17	2017-04-20	0.9	0.3	

Room	Start	Stop	Result	Variance	Comment
IT HELP DESK	2017-04-17	2017-04-20	< 0.3	0.3	
IT - KING	2017-04-17	2017-04-20	< 0.3	0.3	
IT - MARSH	2017-04-17	2017-04-20	< 0.3	0.3	
IT ADMIN.	2017-04-17	2017-04-20	< 0.3	0.3	
IT - FRUTIGER	2017-04-17	2017-04-20	< 0.3	0.3	
IT - PIERCE	2017-04-17	2017-04-20	< 0.3	0.3	
IT - DEWITZ	2017-04-17	2017-04-20	< 0.3	0.3	
IT - M3	2017-04-17	2017-04-20	< 0.3	0.3	
IT - M4	2017-04-17	2017-04-20	< 0.3	0.3	
IT - M5	2017-04-17	2017-04-20	0.6	0.3	
IT - M6	2017-04-17	2017-04-20	< 0.3	0.2	
32	2017-04-17	2017-04-20	< 0.3	0.3	
33	2017-04-17	2017-04-20	0.6	0.3	
34	2017-04-17	2017-04-20	0.7	0.3	
35	2017-04-17	2017-04-20	0.6	0.3	
36	2017-04-17	2017-04-20	0.8	0.3	
37	2017-04-17	2017-04-20	0.7	0.3	
38	2017-04-17	2017-04-20	< 0.3	0.3	
33 OFFICE	2017-04-17	2017-04-20	0.7	0.3	
32 OFFICE	2017-04-17	2017-04-20	0.8	0.3	