

Radon Testing

The following summary provides results of radon testing performed at this location.

Room	Start	Stop	Result	Variance	Comment
8	2017-04-10	2017-04-13	0.9	0.2	
11	2017-04-10	2017-04-13	0.5	0.2	
10	2017-04-10	2017-04-13	1.7	0.2	
9	2017-04-10	2017-04-13	1.7	0.2	
12	2017-04-10	2017-04-13	< 0.3	0.2	
4	2017-04-10	2017-04-13	< 0.3	0.2	
3	2017-04-10	2017-04-13	1.1	0.2	
2	2017-04-10	2017-04-13	< 0.3	0.2	
13	2017-04-10	2017-04-13	< 0.3	0.2	
1	2017-04-10	2017-04-13	< 0.3	0.2	
7	2017-04-10	2017-04-13	< 0.3	0.2	
6	2017-04-10	2017-04-13	< 0.3	0.2	
5	2017-04-10	2017-04-13	< 0.3	0.2	
16	2017-04-10	2017-04-13	< 0.3	0.2	
15	2017-04-10	2017-04-13	0.9	0.2	
14	2017-04-10	2017-04-13	0.8	0.2	
MUSIC	2017-04-10	2017-04-13	0.6	0.2	
STAGE	2017-04-10	2017-04-13	0.6	0.2	

Room	Start	Stop	Result	Variance	Comment
ELL	2017-04-10	2017-04-13	< 0.3	0.2	
SPEECH	2017-04-10	2017-04-13	0.5	0.2	
LIBRARY DUP	2017-04-10	2017-04-13	0.7	0.2	
MAIN OFFICE	2017-04-10	2017-04-13	< 0.3	0.2	
LIBRARY	2017-04-10	2017-04-13	0.7	0.2	
MAIN OFFICE DUP	2017-04-10	2017-04-13	< 0.3	0.2	
CONFERENCE ROOM	2017-04-10	2017-04-13	< 0.3	0.2	
CUSTODIAN DUP	2017-04-10	2017-04-13	< 0.3	0.2	
CUSTODIAN	2017-04-10	2017-04-13	< 0.3	0.2	
PRINCIPAL	2017-04-10	2017-04-13	0.8	0.2	
STAFF ROOM	2017-04-10	2017-04-13	1	0.2	
17	2017-04-10	2017-04-13	< 0.3	0.2	
GYM 1	2017-04-10	2017-04-13	< 0.3	0.2	
KITCHEN	2017-04-10	2017-04-13	0.6	0.2	
CAFETERIA	2017-04-10	2017-04-13	0.7	0.2	
18	2017-04-10	2017-04-13	< 0.3	0.2	
20	2017-04-10	2017-04-13	0.7	0.2	
WORK ROOM	2017-04-10	2017-04-13	0.5	0.2	
COMPUTER LAB	2017-04-10	2017-04-13	1	0.2	
GYM 2	2017-04-10	2017-04-13	0.5	0.2	