

Radon Testing

The following summary provides results of radon testing performed at this location.

Room	Start	Stop	Result	Variance	Comment
21	2017-03-27	2017-03-30	< 0.3	0.2	
22	2017-03-27	2017-03-30	< 0.3	0.2	
18	2017-03-27	2017-03-30	2.0	0.3	
NE ACTIVITY	2017-03-27	2017-03-30	3.7	0.4	
FACULTY BREAK	2017-03-27	2017-03-30	5.2	0.5	
FAC. BREAK-DUP	2017-03-27	2017-03-30	5.2	0.5	
POWERS	2017-03-27	2017-03-30	3.6	0.4	
COUNSELORS	2017-03-27	2017-03-30	2.9	0.3	
MEDIA/PRODUCTION	2017-03-27	2017-03-30	3.6	0.4	
SPEECH	2017-03-27	2017-03-30	3.5	0.4	
FOCUS	2017-03-27	2017-03-30	3.4	0.4	
MEDIA-1	2017-03-27	2017-03-30	4.0	0.4	
MEDIA-2	2017-03-27	2017-03-30	3.7	0.4	
19	2017-03-27	2017-03-30	< 0.3	0.2	
20	2017-03-27	2017-03-30	< 0.3	0.2	
9	2017-03-27	2017-03-30	3.0	0.3	
10	2017-03-27	2017-03-30	3.1	0.4	
11	2017-03-27	2017-03-30	2.5	0.3	

Room	Start	Stop	Result	Variance	Comment
12	2017-03-27	2017-03-30	3.1	0.3	
13	2017-03-27	2017-03-30	3.9	0.4	
NW COMMONS	2017-03-27	2017-03-30	4.1	0.4	
14	2017-03-27	2017-03-30	2.7	0.3	
15	2017-03-27	2017-03-30	2.4	0.3	
16	2017-03-27	2017-03-30	2.3	0.3	
17	2017-03-27	2017-03-30	2.3	0.3	
PRINCIPAL	2017-03-27	2017-03-30	7.5	0.6	
1	2017-03-27	2017-03-30	3.2	0.4	
2	2017-03-27	2017-03-30	3.5	0.4	
3	2017-03-27	2017-03-30	3.0	0.3	
4	2017-03-27	2017-03-30	3.1	0.4	
5	2017-03-27	2017-03-30	3.3	0.4	
6	2017-03-27	2017-03-30	4.2	0.4	
SPECIAL SERVICES	2017-03-27	2017-03-30	2.9	0.3	
7	2017-03-27	2017-03-30	2.6	0.3	
8	2017-03-27	2017-03-30	2.9	0.3	
BLANK	2017-03-27	2017-03-30	< 0.3	0.2	
CUST.OFFICE	2017-03-27	2017-03-30	3.2	0.3	
SUN OFFICE	2017-03-27	2017-03-30	2.2	0.2	

Room	Start	Stop	Result	Variance	Comment
CAFETERIA	2017-03-27	2017-03-30	2.0	0.2	
CAFETERIA	2017-03-27	2017-03-30	2.3	0.2	
GYM-1	2017-03-27	2017-03-30	2.9	0.3	
GYM-2	2017-03-27	2017-03-30	2.4	0.2	
MUSIC	2017-03-27	2017-03-30	8.7	0.4	
MAIN OFFICE	2017-03-27	2017-03-30	6.6	0.3	
MAIN OFFICE-DUP	2017-03-27	2017-03-30	6.6	0.3	