

Lewis and Clark Montessori Charter School


Gresham-Barlow School District

DCC	TEST# 1 First Flow	TEST# 2 30 Sec Flush	TES#T 3 After action	Action required Y/N	Passed Below 20/ppl Y/N	Remediation	SAMPLE NAME	BUILDING LOCATION/USE	Lab Name	LAB SAMP ID	SAMP DATE	BATCH	Result	target
													<20ppb detect	ND= non detect
DCC	X			N	Y		DCC 1	Library North Hall/Drinking Fountain	Apex Labora	A6F0139-17	6/2/16	6060336	1.20	
DCC	X			N	Y		DCC 2	Rm. 7/Drinking Fountain	Apex Labora	A6F0139-18	6/2/16	6060336	2.50	
DCC	X			N	Y		DCC 3	Rm. 8/Drinking Fountain	Apex Labora	A6F0139-19	6/2/16	6060336	1.36	
DCC	X			N	Y		DCC 4	Rm. 9/Drinking Fountain	Apex Labora	A6F0139-20	6/2/16	6060336	1.02	
DCC	X			N	Y		DCC 5	Rm. 10/Drinking Fountain	Apex Labora	A6F0139-21	6/2/16	6060336	1.40	
DCC	X			N	Y		DCC 6	Rm. 12/Drinking Fountain	Apex Labora	A6F0139-22	6/2/16	6060336	1.48	
DCC	X			N	Y		DCC 7	Rm. 14/Drinking Fountain	Apex Labora	A6F0139-23	6/2/16	6060336	0.403	
DCC	X			N	Y		DCC 8	Rm. 15/Drinking Fountain	Apex Labora	A6F0139-24	6/2/16	6060336	0.539	
DCC	X			N	Y		DCC 9	Rm. 16/Drinking Fountain	Apex Labora	A6F0139-25	6/2/16	6060336	0.784	
DCC	X			N	Y		DCC 10	Rm. 17/Drinking Fountain	Apex Labora	A6F0139-26	6/2/16	6060336	0.877	
DCC	X			N	Y		DCC 11	Rm. 18/Drinking Fountain	Apex Labora	A6F0139-27	6/2/16	6060336	0.831	
DCC	X			N	Y		DCC 12	Rm. 19/Drinking Fountain	Apex Labora	A6F0139-28	6/2/16	6060336	10.6	
DCC		X		Y	Y		DCC 12 6/16F	Rm. 19/Drinking Fountain	Apex Labora	A6F0629-60	6/2/16	6060796	6.66	
DCC	X			N	Y		DCC 13	Kitchen Prep Sink/Consumption	Apex Labora	A6F0139-29	6/2/16	6060336	1.24	
DCC	X			N	Y		DCC 14	Staff Break Rm./Consumption	Apex Labora	A6F0139-30	6/2/16	6060336	1.32	
DCC	X			N	Y		DCC 15	Health Rm./Drinking Fountain	Apex Labora	A6F0139-31	6/2/16	6060336	9.50	
DCC	X			N	Y		DCC 16	Fountain - Commons//Drinking Fountain	Apex Labora	A6F0139-32	6/2/16	6060336	ND	
DCC	X			N	Y		DCC 17	Rm. 6//Drinking Fountain	Apex Labora	A6F0139-33	6/2/16	6060336	1.96	
DCC	X			N	Y		DCC 18	Rm. 11//Drinking Fountain	Apex Labora	A6F0139-34	6/2/16	6060336	0.940	
DCC	X			N	Y		DCC 19	Gym South/Drinking Fountain	Apex Labora	A6F0139-35	6/2/16	6060338	ND	
DCC	X			N	Y		DCC 20L	Café Fountain/Drinking Fountain	Apex Labora	A6F0629-57	6/20/16	6060796	ND	
DCC		X		N	Y		DCC 20LF	Café Fountain/Drinking Fountain	Apex Labora	A6F0629-59	6/20/16	6060796	ND	
DCC	X			N	Y		DCC 20R	Café Fountain/Drinking Fountain	Apex Labora	A6F0629-56	6/20/16	6060796	ND	
DCC		X		N	Y		DCC 20RF	Café/Drinking Fountain	Apex Labora	A6F0629-58	6/20/16	6060796	ND	
DCC	X			Y	N		DCC 21	Rm. 1 (Storage Room)/Drinking Fountain	Apex Labora	A6F0629-61	6/20/16	6060796	23.6	
DCC		X		N	Y	Replaced faucet	DCC 21F	Rm. 1 (Storage Room)/Drinking Fountain	Apex Labora	A6F0629-62	6/20/16	6060796	18.8	
DCC	X			N	Y		DCC 22	Rm. 2/Drinking Fountain	Apex Labora	A6F0629-63	6/20/16	6060796	8.6	
DCC		X		N	Y		DCC 22F	Rm. 2/Drinking Fountain	Apex Labora	A6F0629-64	6/20/16	6060796	11.9	
DCC	X			N	Y		DCC 23	Rm. 3/Drinking Fountain	Apex Labora	A6F0629-65	6/20/16	6060796	2.67	
DCC		X		N	Y		DCC 23F	Rm. 3/Drinking Fountain	Apex Labora	A6F0629-66	6/20/16	6060796	2.24	
DCC	X			N	Y		DCC 24	Rm. 4/Drinking Fountain	Apex Labora	A6F0629-67	6/20/16	6060796	7.41	
DCC		X		N	Y		DCC 24F	Rm. 4/Drinking Fountain	Apex Labora	A6F0629-68	6/20/16	6060796	5.87	
DCC	X			N	Y		DCC 25	Rm. 5/Drinking Fountain	Apex Labora	A6F0629-69	6/20/16	6060796	3.71	
DCC		X		N	Y		DCC 25F	Rm. 5/Drinking Fountain	Apex Labora	A6F0629-70	6/20/16	6060796	1.43	
DCC	X			N	Y		DCC 50	Ext Hose Bib - West of Front Entrance/Gardening Drinking	Apex Labora	A6J0075-12	9/2/16	6100386	9.82	
DCC		X		N	Y		DCC 50F	Ext Hose Bib - West of Front Entrance/Gardening Drinking	Apex Labora	A6J0075-14	9/2/16	6100255	0.989	
DCC	X			Y	Y	Labeled not for Drinking	DCC 52	Ext Hose Bib - Outside Rm. 9/Gardening Drinking	Apex Labora	A6J0075-13	9/2/16	6100386	115	
DCC		X		N	Y		DCC 52F	Ext Hose Bib - Outside Rm. 9/Gardening Drinking	Apex Labora	A6J0075-15	9/2/16	6100255	4.00	
DCC	X			Y	N	Labeled not for Drinking	DCC 53	Ext Hose Bib - Outside Rm. 12/Gardening Drinking	Apex Labora	A6J0075-16	9/2/16	6100255	21.4	

DCC		X		N	Y		DCC 53F	Ext Hose Bib - Outside Rm. 12/Gardening Drinking	Apex Labora	A6J0075-18	9/2/16	6100255	1.24
DCC	X			N	Y		DCC 55	Ext Hose Bib - Outside Rm. 18/Gardening Drinking	Apex Labora	A6J0075-17	9/2/16	6100255	2.32
DCC		X		N	Y		DCC 55F	Ext Hose Bib - Outside Rm. 18/Gardening Drinking	Apex Labora	A6J0075-19	9/2/16	6100255	ND
DCC	X			N	Y		DCC 56	Ext Hose Bib - East under covered play area/Gardening Drinking	Apex Labora	A6J0075-20	9/2/16	6100255	9.73
DCC		X		N	Y		DCC 56F	Ext Hose Bib - East under covered play area/Gardening Drinking	Apex Labora	A6J0075-24	9/2/16	6100256	ND
DCC	X			N	Y		DCC 57	Ext Hose Bib - NE corner by playground/Gardening Drinking	Apex Labora	A6J0075-21	9/2/16	6100255	3.33
DCC		X		N	Y		DCC 57F	Ext Hose Bib - NE corner by playground/Gardening Drinking	Apex Labora	A6J0075-25	9/2/16	6100256	ND
DCC	X			Y	N	Labeled not for Drinking	DCC 58	Ext Hose Bib - NE ccorner by Sprinkler Rm./Gardening Drinking	Apex Labora	A6J0075-22	9/2/16	6100255	83.8
DCC		X		N	Y		DCC 58F	Ext Hose Bib - NE ccorner by Sprinkler Rm./Gardening Drinking	Apex Labora	A6J0075-26	9/2/16	6100256	ND
DCC	X			N	Y		DCC 59	Ext Hose Bib - North side, East of Main Entry/Gardening Drinking	Apex Labora	A6J0075-23	9/2/16	6100256	3.18
DCC		X		N	Y		DCC 59F	Ext Hose Bib - North side, East of Main Entry/Gardening Drinking	Apex Labora	A6J0075-27	9/2/16	6100256	ND

ug/L	\$25.00
ug/L	\$25.00
ug/L	\$25.00
ug/L	\$25.00
ug/L	\$25.00
ug/L	\$25.00
ug/L	\$25.00
ug/L	\$25.00
ug/L	\$25.00
ug/L	\$25.00
ug/L	\$25.00
ug/L	\$25.00

\$910.00



- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25
- 26
- 27
- 28
- 29
- 30
- 31
- 32
- 33
- 34
- 35
- 36
- 37
- 38
- 39

40
41
42
43
44
45
46
47
48
49
50