

TEST# 1 First Flow	TEST# 2 30 Sec Flush	TEST# 3 After action	Action required Y/N	Passed Below 20/ppl Y/N	Remediation	SAMPLE NAME	BUILDING		LOCATION/USE					Result target <20ppb		COST PER SAMPLE
							Lab Name	LAB SAMP ID	SAMPLE DATE	PREP DATE	ANA DATE	BATCH	ND= non detect	UNITS		
DCDK8	X			Y		DCMS 1	Main Entrance/Drinking Fountain	Apex Laborat	A6F0139-36	6/2/16	6/10/16	6/13/16	6060338	0.554	ug/L	\$15.00
DCDK8	X			Y		DCMS 2	Staff Lounge/Drinking Fountain	Apex Laborat	A6F0139-37	6/2/16	6/10/16	6/13/16	6060338	1.11	ug/L	\$15.00
DCDK8	X			Y		DCMS 3	Blue Computer Lab/Drinking Fountain	Apex Laborat	A6F0139-38F	6/2/16	6/10/16	6/14/16	6060338	4.54	ug/L	\$15.00
DCDK8	X			Y		DCMS 4	Hall Fountain next to Rm. 9/Drinking Fountain	Apex Laborat	A6F0139-39	6/2/16	6/10/16	6/13/16	6060338	0.854	ug/L	\$15.00
DCDK8	X			Y		DCMS 5	Rm. 9/Drinking Fountain	Apex Laborat	A6F0139-40	6/2/16	6/10/16	6/13/16	6060338	1.42	ug/L	\$15.00
DCDK8	X			Y		DCMS 6	Rm. 7/Drinking Fountain	Apex Laborat	A6F0139-41	6/2/16	6/10/16	6/13/16	6060338	0.391	ug/L	\$15.00
DCDK8	X			Y		DCMS 7	Rm. 3/Drinking Fountain	Apex Laborat	A6F0139-42	6/2/16	6/10/16	6/13/16	6060338	0.426	ug/L	\$15.00
DCDK8	X			Y		DCMS 8	Rm. 1/Drinking Fountain	Apex Laborat	A6F0139-43	6/2/16	6/10/16	6/13/16	6060338	0.572	ug/L	\$15.00
DCDK8	X			Y		DCMS 9	Rm. 2/Drinking Fountain	Apex Laborat	A6F0139-44	6/2/16	6/10/16	6/13/16	6060338	1.88	ug/L	\$15.00
DCDK8	X			Y		DCMS 10	Rm. 4/Drinking Fountain	Apex Laborat	A6F0139-45	6/2/16	6/10/16	6/13/16	6060338	2.79	ug/L	\$15.00
DCDK8	X			Y		DCMS 11	Health Rm./Consumption	Apex Laborat	A6F0139-46	6/2/16	6/10/16	6/13/16	6060338	2.10	ug/L	\$15.00
DCDK8	X			Y		DCMS 12	Rm. 18/Drinking Fountain	Apex Laborat	A6F0139-47	6/2/16	6/10/16	6/13/16	6060338	2.83	ug/L	\$15.00
DCDK8	X			Y		DCMS 13	Rm. 21/Drinking Fountain	Apex Laborat	A6F0139-48	6/2/16	6/10/16	6/13/16	6060338	1.71	ug/L	\$15.00
DCDK8	X			Y		DCMS 14	Hall Bubbler next to Rm. 21/Drinking Fountain	Apex Laborat	A6F0139-49	6/2/16	6/10/16	6/13/16	6060338	0.679	ug/L	\$15.00
DCDK8	X			Y		DCMS 15	Rm. 22/Drinking Fountain	Apex Laborat	A6F0139-50	6/2/16	6/10/16	6/13/16	6060338	1.93	ug/L	\$15.00
DCDK8	X			Y		DCMS 16	Rm. 23/Drinking Fountain	Apex Laborat	A6F0139-51	6/2/16	6/10/16	6/13/16	6060338	3.40	ug/L	\$15.00
DCDK8	X			Y		DCMS 17	Rm. 26/Drinking Fountain	Apex Laborat	A6F0139-52	6/2/16	6/10/16	6/13/16	6060338	5.90	ug/L	\$15.00
DCDK8	X			Y		DCMS 18	Kitchen prep sink/Consumption	Apex Laborat	A6F0139-53	6/2/16	6/10/16	6/13/16	6060338	1.33	ug/L	\$15.00
DCDK8	X			Y		DCMS 19	Bubbler next to Library/Drinking Fountain	Apex Laborat	A6F0139-54	6/2/16	6/10/16	6/13/16	6060338	6.29	ug/L	\$15.00
DCDK8	X			Y		DCMS 20	Rm. 38/Drinking Fountain	Apex Laborat	A6F0139-55	6/2/16	6/10/16	6/13/16	6060341	1.02	ug/L	\$15.00
DCDK8	X			Y		DCMS 21	Rm. 40/Drinking Fountain	Apex Laborat	A6F0139-56	6/2/16	6/10/16	6/13/16	6060341	1.15	ug/L	\$15.00
DCDK8	X			Y		DCMS 22	Rm. 41/Drinking Fountain	Apex Laborat	A6F0139-57	6/2/16	6/10/16	6/13/16	6060341	0.843	ug/L	\$15.00
DCDK8	X			Y		DCMS 23	Rm. 39/Drinking Fountain	Apex Laborat	A6F0139-58	6/2/16	6/10/16	6/13/16	6060341	1.31	ug/L	\$15.00
DCDK8	X			Y		DCDMS 50	Exterior Hose Bib - Outside Rm. 1/Gardening and Drinking	Apex Laborat	A6I0953-94	09/02/2016	10/05/2016	10/05/2016	6100246	14.5	ug/L	\$25.00
DCDK8		X		Y		DCDMS 50F	Exterior Hose Bib - Outside Rm. 1/Gardening and Drinking	Apex Laborat	A6I0953-98	09/02/2016	10/05/2016	10/05/2016	6100246	0.949	ug/L	\$25.00
DCDK8	X			Y		DCDMS 51	Exterior Hose Bib - Outside Rm. 7/Gardening and Drinking	Apex Laborat	A6I0953-95	09/02/2016	10/05/2016	10/05/2016	6100246	14.3	ug/L	\$25.00
DCDK8		X		Y		DCDMS 51F	Exterior Hose Bib - Outside Rm. 7/Gardening and Drinking	Apex Laborat	A6I0953-99	09/02/2016	10/05/2016	10/06/2016	6100255	0.800	ug/L	\$25.00
DCDK8	X			N	Labeled not for Drinking	DCDMS 53	Exterior Hose Bib - Outside Rm. 18/Gardening and Drinking	Apex Laborat	A6I0953-96	09/02/2016	10/05/2016	10/05/2016	6100246	43.2	ug/L	\$25.00
DCDK8		X		Y		DCDMS 53F	Exterior Hose Bib - Outside Rm. 18/Gardening and Drinking	Apex Laborat	A6I0953-AA	09/02/2016	10/05/2016	10/06/2016	6100255	2.66	ug/L	\$25.00
DCDK8	X			N	Labeled not for Drinking	DCDMS 54	Exterior Hose Bib - Outside Rm. 23/Gardening and Drinking	Apex Laborat	A6I0953-97	09/02/2016	10/10/2016	10/11/2016	6100386	116	ug/L	\$25.00
DCDK8		X		Y		DCDMS 54 F	Exterior Hose Bib - Outside Rm. 23/Gardening and Drinking	Apex Laborat	A6J0075-01	09/02/2016	10/05/2016	10/06/2016	6100255	3.57	ug/L	\$25.00
DCDK8	X			N	Labeled not for Drinking	DCDMS 55	Exterior Hose Bib - Outside Rm. 24/Gardening and Drinking	Apex Laborat	A6J0075-02	09/02/2016	10/10/2016	10/11/2016	6100386	63.0	ug/L	\$25.00
DCDK8		X		Y		DCDMS 55F	Exterior Hose Bib - Outside Rm. 24/Gardening and Drinking	Apex Laborat	A6J0075-06	09/02/2016	10/05/2016	10/06/2016	6100255	3.52	ug/L	\$25.00
DCDK8	X			N	Labeled not for Drinking	DCDMS 56	Exterior Hose Bib - Outside Rm. 26/Gardening and Drinking	Apex Laborat	A6J0075-03	09/02/2016	10/10/2016	10/11/2016	6100386	345	ug/L	\$25.00



- 1
- 2
- 3

- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13

- 14
- 15
- 16
- 17
- 18

- 19
- 20
- 21
- 22
- 23

- 24

- 25

- 26

- 27

- 28

- 29

- 30

- 31

- 32

- 33

- 34

35

36

37

38

39

40

41