

GRMS	TEST# 1 First Flow	TEST# 2 30 Sec Flush	TEST# 3 After action	Action required Y/N	Passed Below 20/ppb Y/N	Remediation	SAMPLE NAME	BUILDING LOCATION	Lab Name	LAB SAMP ID	SAMPLE DATE	PREP DATE	ANA DATE	BATCH	Result target <20ppb		
															ND= non detect	UNITS	COST PER SAMPLE
GRMS	X				Y		GR 901A	Fountain West Wing Left	Apex Labora	A6F0138-26	6/2/16	6/10/16	6/10/16	6060321	0.471	ug/L	\$15.00
GRMS	X				Y		GR 901B	Fountain West Wing Right	Apex Labora	A6F0138-27	6/2/16	6/10/16	6/10/16	6060321	ND	ug/L	\$15.00
GRMS	X				Y		GR 902	Classroom 31	Apex Labora	A6F0138-28	6/2/16	6/10/16	6/10/16	6060321	0.267	ug/L	\$15.00
GRMS	X				Y		GR 903	Classroom 26	Apex Labora	A6F0138-29	6/2/16	6/10/16	6/10/16	6060321	0.163	ug/L	\$15.00
GRMS	X				Y		GR 904	Commons / Café West	Apex Labora	A6F0138-30	6/2/16	6/10/16	6/10/16	6060321	6.21	ug/L	\$15.00
GRMS	X				Y		GR 905	Commons / East	Apex Labora	A6F0138-31	6/2/16	6/10/16	6/10/16	6060321	4.95	ug/L	\$15.00
GRMS	X				Y		GR 906	Kitchen	Apex Labora	A6F0138-32	6/2/16	6/10/16	6/10/16	6060321	3.68	ug/L	\$15.00
GRMS	X				Y		GR 907	Kitchen	Apex Labora	A6F0138-33	6/2/16	6/10/16	6/10/16	6060321	0.310	ug/L	\$15.00
GRMS	X				Y		GR 908	Kitchen	Apex Labora	A6F0138-34	6/2/16	6/10/16	6/10/16	6060321	3.53	ug/L	\$15.00
GRMS	X				Y		GR 909	Kitchen	Apex Labora	A6F0138-35	6/2/16	6/10/16	6/10/16	6060322	5.52	ug/L	\$15.00
GRMS		X			Y		GR-909	Kitchen	N Lab	A6H0465-14	8/8/16	8/16/16	8/16/16		0.32	ug/L	\$25.00
GRMS	X				Y	Replaced Faucet	GR 910	Kitchen	Apex Labora	A6F0138-36	6/2/16	6/10/16	6/10/16	6060322	12.6	ug/L	\$15.00
GRMS		X			N		GR 910 6/16F	Kitchen	Apex Labora	A6F0629-37	6/2/16	6/27/16	6/28/16	6060795	33.5	ug/L	\$15.00
GRMS	X				Y		GR-910	Kitchen	N Lab	A6H0465-13	8/8/16	8/16/16	8/16/16		0.38	ug/L	\$25.00
GRMS	X				Y	Replaced Faucet	GR 911	Kitchen	Apex Labora	A6F0138-37	6/2/16	6/10/16	6/10/16	6060322	10.8	ug/L	\$15.00
GRMS		X			Y		GR 911 6/16F	Kitchen	Apex Labora	A6F0629-38	6/20/16	6/27/16	6/28/16	6060795	0.478	ug/L	\$15.00
GRMS	X				Y		GR 912	Fountain Delivery Entry	Apex Labora	A6F0138-38	6/2/16	6/10/16	6/10/16	6060322	8.05	ug/L	\$15.00
GRMS	X				Y		GR 913	Gym East	Apex Labora	A6F0138-39	6/2/16	6/10/16	6/10/16	6060322	0.772	ug/L	\$15.00
GRMS	X				Y		GR 914	Gym West	Apex Labora	A6F0138-40	6/2/16	6/10/16	6/10/16	6060322	1.04	ug/L	\$15.00
GRMS	X				Y		GR 915	Girls Locker Rm.	Apex Labora	A6F0138-41	6/2/16	6/10/16	6/10/16	6060322	9.90	ug/L	\$15.00
GRMS	X				Y	Replaced Faucet	GR 916	Boys Locker Rm.	Apex Labora	A6F0138-42	6/2/16	6/10/16	6/10/16	6060322	10.7	ug/L	\$15.00
GRMS		X			N		GR 916 6/16F	Boys Locker Rm.	Apex Labora	A6F0629-39	6/20/16	6/27/16	6/28/16	6060795	21.1	ug/L	\$15.00
GRMS	X				Y		GR-916	Boys Locker Rm.	N Lab	A6H0465-15	8/8/16	8/16/16	8/16/16		0.32	ug/L	\$25.00
GRMS	X				Y		GR 918	Pod 2	Apex Labora	A6F0138-44	6/3/16	6/10/16	6/10/16	6060322	3.41	ug/L	\$15.00
GRMS	X				Y		GR 919	Pod 3	Apex Labora	A6F0138-45	6/3/16	6/10/16	6/10/16	6060322	3.91	ug/L	\$15.00
GRMS	X				Y		GR 920	Pod 4	Apex Labora	A6F0138-46	6/3/16	6/10/16	6/10/16	6060322	3.92	ug/L	\$15.00
GRMS	X				Y		GR 921	Library	Apex Labora	A6F0138-47	6/3/16	6/10/16	6/10/16	6060322	6.95	ug/L	\$15.00
GRMS	X				N	Replaced Faucet	GR 922	Faculty Rm.	Apex Labora	A6F0138-48	6/3/16	6/10/16	6/10/16	6060322	93.7	ug/L	\$15.00
GRMS		X			N		GR 922 6/16F	Faculty Rm.	Apex Labora	A6F0629-36	6/20/16	6/30/16	6/30/16	6060933	47.5	ug/L	\$15.00
GRMS		X			Y	Installed Lead Filter labeled not for drinking	GR 922 6/16FF	Faculty Rm.	Apex Labora	A6F0629-40	6/20/16	6/30/16	6/30/16	6060933	19.3	ug/L	\$15.00
GRMS	X				Y		GR-922	Faculty Rm.	N Lab	A6H0465-12	8/8/16	8/16/16	8/16/16		0.97	ug/L	\$25.00
GRMS	X				Y		GR 923	Art Wing South	Apex Labora	A6F0138-49	6/3/16	6/10/16	6/10/16	6060322	1.81	ug/L	\$15.00
GRMS	X				Y		GR 950	Ice Machine - Kitchen	Apex Labora	A6J0075-89	9/2/16	10/6/16	10/6/16	6100271	1.77	ug/L	\$25.00
GRMS	X				N	Labeled not for Drinking	GR 951	Ext Hose Bib - Outside Rm. 13	Apex Labora	A6J0075-90	9/2/16	10/10/16	10/11/16	6100399	52.8	ug/L	\$25.00
GRMS		X			Y		GR 951F	Ice Machine - Kitchen	Apex Labora	A6J0083-01	9/2/16	10/6/16	10/6/16	6100291	15.2	ug/L	\$25.00
GRMS	X				Y		GR 952	Ext Hose Bib - Outside Rm. 21	Apex Labora	A6J0075-91	9/2/16	10/6/16	10/6/16	6100271	13.2	ug/L	\$25.00
GRMS		X			Y		GR 952F	Ext Hose Bib - Outside Rm. 13	Apex Labora	A6J0083-02	9/2/16	10/10/16	10/11/16	6100399	133	ug/L	\$25.00
GRMS	X				N	Labeled not for Drinking	GR 953	Ext Hose Bib - Outside Rm. 25	Apex Labora	A6J0075-92	9/2/16	10/10/16	10/11/16	6100399	48.7	ug/L	\$25.00
GRMS		X			N		GR 953F	Ext Hose Bib - Outside Rm. 21	Apex Labora	A6J0083-03	9/2/16	10/10/16	10/11/16	6100399	134	ug/L	\$25.00
GRMS	X				Y		GR 954	Ext Hose Bib - Outside Loft	Apex Labora	A6J0075-93	9/2/16	10/6/16	10/6/16	6100271	13.0	ug/L	\$25.00
GRMS		X			Y		GR 954F	Ext Hose Bib - Outside Rm. 25	Apex Labora	A6J0083-04	9/2/16	10/6/16	10/6/16	6100291	0.663	ug/L	\$25.00
GRMS	X				N	Labeled not for Drinking	GR 955	Ext Hose Bib - Outside Staff Rm.	Apex Labora	A6J0075-94	9/2/16	10/6/16	10/6/16	6100271	54.5	ug/L	\$25.00
GRMS		X			Y		GR 955F	Ext Hose Bib - Outside Loft	Apex Labora	A6J0083-05	9/2/16	10/6/16	10/6/16	6100291	3.10	ug/L	\$25.00
GRMS	X				Y	Labeled not for Drinking	GR 956	Ext Hose Bib - South Outside Rm. 35	Apex Labora	A6J0075-95	9/2/16	10/6/16	10/6/16	6100271	27.2	ug/L	\$25.00



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29

30
31
32
33
34
35
36
37
38
39
40
41
42
43
44

45
46
47
48
49
50
51
52
53
54
55