

	TEST# 1 First Flow	TEST# 2 30 Sec Flush	TEST# 3 After action	Action required Y/N	Passed Below 20/ppb Y/N	Remediation	SAMPLE NAME	BUILDING LOCATION	Lab Name	LAB SAMP ID	SAMPLE DATE	PREP DATE	ANA DATE	BATCH	Result target <20ppb			
															ND= non detect	UNITS	COST PER SAMPLE	
HI	X			N			HI 1	Custodial Office	Apex Labora	A6F0137-24	6/1/16	6/7/16	6/8/16	6060203	6.28	ug/L	\$15.00	1
HI	X			N			HI 2	Gym Lobby	Apex Labora	A6F0137-25	6/1/16	6/7/16	6/8/16	6060203	0.913	ug/L	\$15.00	2
HI	X			N			HI 3	Gym	Apex Labora	A6F0137-26	6/1/16	6/7/16	6/8/16	6060203	3.39	ug/L	\$15.00	3
HI	X			N			HI 4	Café NE	Apex Labora	A6F0137-27	6/1/16	6/7/16	6/8/16	6060203	5.11	ug/L	\$15.00	4
HI	X			N			HI 5	Rm. 20	Apex Labora	A6F0137-28	6/1/16	6/7/16	6/8/16	6060203	1.15	ug/L	\$15.00	5
HI	X			N			HI 6	Rm. 19	Apex Labora	A6F0137-29	6/1/16	6/7/16	6/8/16	6060203	1.29	ug/L	\$15.00	6
HI	X			N			HI 7	Rm. 18	Apex Labora	A6F0137-30	6/1/16	6/7/16	6/8/16	6060203	1.26	ug/L	\$15.00	7
HI	X			N			HI 8	Rm. 17	Apex Labora	A6F0137-31	6/1/16	6/7/16	6/8/16	6060203	1.75	ug/L	\$15.00	8
HI	X			N			HI 9	Fountain N. Hall	Apex Labora	A6F0137-32	6/1/16	6/7/16	6/8/16	6060203	0.827	ug/L	\$15.00	9
HI	X						HI 10	Speech	Apex Labora	A6F0137-33	6/1/16	6/7/16	6/8/16	6060203	31.3	ug/L	\$15.00	10
HI		X		Y			HI 10 6/16F	Speech	Apex Labora	A6F0629-19	6/20/16	6/27/16	6/28/16	6060794	2.1	ug/L	\$15.00	11
HI	X			N			HI 11	Rm. 16	Apex Labora	A6F0137-34	6/1/16	6/7/16	6/8/16	6060203	2.08	ug/L	\$15.00	12
HI	X			N			HI 12	Rm. 15	Apex Labora	A6F0137-35	6/1/16	6/7/16	6/8/16	6060203	4.08	ug/L	\$15.00	13
HI	X			N			HI 13	Rm. 14	Apex Labora	A6F0137-36	6/1/16	6/7/16	6/8/16	6060203	1.30	ug/L	\$15.00	14
HI	X			N			HI 14	Rm. 13	Apex Labora	A6F0137-37	6/1/16	6/7/16	6/8/16	6060203	2.33	ug/L	\$15.00	15
HI	X			N			HI 15	Fountain E. Hall	Apex Labora	A6F0137-38	6/1/16	6/7/16	6/8/16	6060203	1.58	ug/L	\$15.00	16
HI	X			N			HI 16	Rm. 12	Apex Labora	A6F0137-39	6/1/16	6/7/16	6/8/16	6060203	2.08	ug/L	\$15.00	17
HI	X			N			HI 17	Rm. 11	Apex Labora	A6F0137-40	6/1/16	6/7/16	6/8/16	6060203	1.35	ug/L	\$15.00	18
HI	X			N			HI 18	Rm. 10	Apex Labora	A6F0137-41	6/1/16	6/7/16	6/8/16	6060204	0.936	ug/L	\$15.00	19
HI	X			N			HI 19	Rm. 9	Apex Labora	A6F0137-42	6/1/16	6/7/16	6/8/16	6060204	1.23	ug/L	\$15.00	20
HI	X			N			HI 20	Rm. 8	Apex Labora	A6F0137-43	6/1/16	6/7/16	6/8/16	6060204	2.47	ug/L	\$15.00	21
HI	X			N			HI 21	Rm. 7	Apex Labora	A6F0137-44	6/1/16	6/7/16	6/8/16	6060204	1.62	ug/L	\$15.00	22
HI	X			N			HI 22	Rm. 6	Apex Labora	A6F0137-45	6/1/16	6/7/16	6/8/16	6060204	0.775	ug/L	\$15.00	23
HI	X			N			HI 23	Rm. 5	Apex Labora	A6F0137-46	6/1/16	6/7/16	6/8/16	6060204	0.703	ug/L	\$15.00	24
HI	X			N			HI 24	Fountain W. Hall	Apex Labora	A6F0137-47	6/1/16	6/7/16	6/8/16	6060204	1.23	ug/L	\$15.00	25
HI	X						HI 25	Rm. 4	Apex Labora	A6F0137-48	6/1/16	6/7/16	6/8/16	6060204	1.20	ug/L	\$15.00	26
HI	X						HI 26	Rm. 3	Apex Labora	A6F0137-49	6/1/16	6/7/16	6/8/16	6060204	1.57	ug/L	\$15.00	27
HI	X						HI 27	Rm. 2	Apex Labora	A6F0137-50	6/1/16	6/7/16	6/8/16	6060204	0.966	ug/L	\$15.00	28
HI	X						HI 28	Rm. 1	Apex Labora	A6F0137-51	6/1/16	6/7/16	6/8/16	6060204	1.02	ug/L	\$15.00	29
HI	X						HI 29	Resource Rm.	Apex Labora	A6F0137-52	6/1/16	6/7/16	6/8/16	6060204	5.35	ug/L	\$15.00	30
HI	X						HI 30	Staff Lounge	Apex Labora	A6F0137-53	6/1/16	6/7/16	6/8/16	6060204	2.12	ug/L	\$15.00	31
HI	X						HI 31	Office Work Rm.	Apex Labora	A6F0137-54	6/1/16	6/7/16	6/8/16	6060204	4.80	ug/L	\$15.00	32
HI	X						HI 32	Health Room	Apex Labora	A6F0137-55	6/1/16	6/7/16	6/8/16	6060204	16.9	ug/L	\$15.00	33
HI		X					HI 32 6/16F	Health Room	Apex Labora	A6F0629-20	6/20/16	6/27/16	6/28/16	6060794	1.14	ug/L	\$15.00	34
HI	X			N		Labeled not for Drinking	HI 33	Health Rm. RR	Apex Labora	A6F0137-56	6/1/16	6/7/16	6/8/16	6060204	2.81	ug/L	\$15.00	35
HI	X			N		Labeled not for Drinking	HI 50	Ext Hose Bib - Outside Boys Restroom	Apex Labora	A6J0083-12	9/2/16	10/6/16	10/6/16	6100291	38.0	ug/L	\$25.00	36
HI		X		Y			HI 50F	Ext Hose Bib - Outside Custodial Closet	Apex Labora	A6J0083-24	9/2/16	10/6/16	10/6/16	6100293	0.252	ug/L	\$25.00	37
HI	X			N		Labeled not for Drinking	HI 51	Ext Hose Bib - West outside Music Rm.	Apex Labora	A6J0083-13	9/2/16	10/6/16	10/6/16	6100291	89.9	ug/L	\$25.00	38
HI		X		Y			HI 51F	Ext Hose Bib - West outside Music Rm.	Apex Labora	A6J0083-25	9/2/16	10/6/16	10/6/16	6100293	1.52	ug/L	\$25.00	39
HI	X			Y			HI 52	Ext Hose Bib - Outside Work Rm.	Apex Labora	A6J0083-14	9/2/16	10/10/16	10/11/16	6100399	9.74	ug/L	\$25.00	40
HI		X		Y			HI 52F	Ext Hose Bib - Outside Work Rm.	Apex Labora	A6J0083-26	9/2/16	10/6/16	10/6/16	6100293	0.499	ug/L	\$25.00	41
HI	X			N		Labeled not for Drinking	HI 53	Ext Hose Bib - Outside Main Entry	Apex Labora	A6J0083-15	9/2/16	10/6/16	10/6/16	6100291	31.3	ug/L	\$25.00	42
HI		X		Y			HI 53F	Ext Hose Bib - Outside Main Entry	Apex Labora	A6J0083-27	9/2/16	10/6/16	10/6/16	6100293	0.494	ug/L	\$25.00	43
HI	X			N		Labeled not for Drinking	HI 54	Ext Hose Bib - Outside Rm. 2	Apex Labora	A6J0083-16	9/2/16	10/10/16	10/11/16	6100399	82.5	ug/L	\$25.00	44
HI		X		Y			HI 54F	Ext Hose Bib - Outside Rm. 2	Apex Labora	A6J0083-28	9/2/16	10/6/16	10/6/16	6100293	0.895	ug/L	\$25.00	45

HI	X			N	Labeled not for Drinking	HI 55	Ext Hose Bib - Outside Rm. 3	Apex Labora	A6J0083-17	9/2/16	10/6/16	10/6/16	6100291	31.9	ug/L	\$25.00
HI		X		Y		HI 55F	Ext Hose Bib - Outside Rm. 3	Apex Labora	A6J0083-29	9/2/16	10/6/16	10/6/16	6100293	0.318	ug/L	\$25.00
HI	X			N	Labeled not for Drinking	HI 56	Ext Hose Bib - Outside Rm. 7	Apex Labora	A6J0083-18	9/2/16	10/10/16	10/11/16	6100399	178	ug/L	\$25.00
HI		X		Y		HI 56F	Ext Hose Bib - Outside Rm. 7	Apex Labora	A6J0083-30	9/2/16	10/6/16	10/6/16	6100293	5.69	ug/L	\$25.00
HI	X			N	Labeled not for Drinking	HI 57	Ext Hose Bib - Outside ELL Rm.	Apex Labora	A6J0083-19	9/2/16	10/6/16	10/6/16	6100291	196	ug/L	\$25.00
HI		X		Y		HI 57F	Ext Hose Bib - Outside ELL Rm.	Apex Labora	A6J0083-31	9/2/16	10/6/16	10/6/16	6100293	10.0	ug/L	\$25.00
HI	X			Y		HI 59	Ext Hose Bib - Outside Rm. 14	Apex Labora	A6J0083-20R	9/2/16	10/10/16	10/11/16	6100399	18.3	ug/L	\$25.00
HI		X		Y		HI 59F	Ext Hose Bib - Outside Rm. 14	Apex Labora	A6J0083-32	9/2/16	10/6/16	10/6/16	6100293	1.75	ug/L	\$25.00
HI	X			N	Labeled not for Drinking	HI 60	Ext Hose Bib - Outside Rm. 18	Apex Labora	A6J0083-21R	9/2/16	10/10/16	10/11/16	6100399	73.7	ug/L	\$25.00
HI		X		Y		HI 60F	Ext Hose Bib - Outside Rm. 18	Apex Labora	A6J0083-33	9/2/16	10/6/16	10/6/16	6100293	0.603	ug/L	\$25.00
HI	X			N	Labeled not for Drinking	HI 61	Ext Hose Bib - Outside Rm. 20	Apex Labora	A6J0083-22	9/2/16	10/6/16	10/6/16	6100291	79.4	ug/L	\$25.00
HI		X		Y		HI 61F	Ext Hose Bib - Outside Rm. 20	Apex Labora	A6J0083-34	9/2/16	10/6/16	10/6/16	6100293	1.63	ug/L	\$25.00
HI	X			N	Labeled not for Drinking	HI 62	Ext Hose Bib - North Corner Outside Gyn	Apex Labora	A6J0083-23	9/2/16	10/6/16	10/6/16	6100293	25.5	ug/L	\$25.00
HI		X		Y		HI 62F	Ext Hose Bib - North Corner Outside Gyn	Apex Labora	A6J0083-35	9/2/16	10/6/16	10/6/16	6100293	0.721	ug/L	\$25.00
																\$1,125.00

46
47
48
49
50
51
52
53
54
55
56
57
58
59