


	TEST# 1 First Flow	TEST# 2 30 Sec Flush	TEST# 3 After action	Action required Y/N	Passed Below 20/ppi Y/N	Remediation	SAMPLE NAME	BUILDING LOCATION	Lab Name	LAB SAMP ID	SAMPLE DATE	PREP DATE	ANA DATE	BATCH	Result target <20ppb		
															ND= non detect	UNITS	COST PER SAMPLE
NG	X				Y		NG 1	Utility	Apex Laboratories	A6F0118-34	6/1/16	6/6/16	6/8/16	6060154	1.82	ug/L	\$15.00
NG	X				Y		NG 2	Faculty Rm.	Apex Laboratories	A6F0118-35	6/1/16	6/6/16	6/8/16	6060154	2.92	ug/L	\$15.00
NG	X				Y	Replaced Faucet	NG 3	Kitchen Sink Left	Apex Laboratories	A6F0118-36	6/1/16	6/6/16	6/8/16	6060154	12.3	ug/L	\$15.00
NG		X			Y		NG 3 6/16F	Kitchen Sink Left	Apex Laboratories	A6F0629-32	6/20/16	6/27/16	6/28/16	6060794	9.39	ug/L	\$15.00
NG	X				N	Replaced Faucet	NG 4	Kitchen South wall Right	Apex Laboratories	A6F0118-37	6/1/16	6/6/16	6/8/16	6060154	49.0	ug/L	\$15.00
NG		X			Y		NG 4 6/16F	Kitchen South wall Right	Apex Laboratories	A6F0629-31	6/20/16	6/27/16	6/28/16	6060794	1.19	ug/L	\$15.00
NG	X				Y		NG 5	Kitchen Hand Wash Sink	Apex Laboratories	A6F0118-38	6/1/16	6/6/16	6/8/16	6060154	2.63	ug/L	\$15.00
NG	X				Y		NG 6	Café	Apex Laboratories	A6F0118-39	6/1/16	6/6/16	6/8/16	6060154	2.01	ug/L	\$15.00
NG	X				Y		NG 7	Gym	Apex Laboratories	A6F0118-40	6/1/16	6/6/16	6/8/16	6060154	1.59	ug/L	\$15.00
NG	X				Y		NG 8	Rm. 16	Apex Laboratories	A6F0118-41	6/1/16	6/6/16	6/8/16	6060155	2.16	ug/L	\$15.00
NG	X				Y		NG 9	Rm. 15	Apex Laboratories	A6F0118-42	6/1/16	6/6/16	6/8/16	6060155	1.82	ug/L	\$15.00
NG	X				Y		NG 10	Rm. 14	Apex Laboratories	A6F0118-43	6/1/16	6/6/16	6/8/16	6060155	0.954	ug/L	\$15.00
NG	X				Y		NG 11	Rm. 17	Apex Laboratories	A6F0118-44	6/1/16	6/6/16	6/8/16	6060155	3.78	ug/L	\$15.00
NG	X				Y		NG 12	Rm. 18	Apex Laboratories	A6F0118-45	6/1/16	6/6/16	6/8/16	6060155	1.31	ug/L	\$15.00
NG	X				Y		NG 13	Rm. 13	Apex Laboratories	A6F0118-46	6/1/16	6/6/16	6/8/16	6060155	0.963	ug/L	\$15.00
NG	X				Y		NG 14	Rm. 12	Apex Laboratories	A6F0118-47	6/1/16	6/6/16	6/8/16	6060155	0.970	ug/L	\$15.00
NG	X				Y		NG 15	Rm. 19	Apex Laboratories	A6F0118-48	6/1/16	6/6/16	6/8/16	6060155	1.48	ug/L	\$15.00
NG	X				Y		NG 16	Rm. 20	Apex Laboratories	A6F0118-49	6/1/16	6/6/16	6/8/16	6060155	1.12	ug/L	\$15.00
NG	X				Y		NG 17	Rm. 11	Apex Laboratories	A6F0118-50	6/1/16	6/6/16	6/8/16	6060155	1.87	ug/L	\$15.00
NG	X				Y		NG 18	Fountain NE	Apex Laboratories	A6F0118-51	6/1/16	6/6/16	6/8/16	6060155	3.06	ug/L	\$15.00
NG	X				Y		NG 19	Health Rm. Sink	Apex Laboratories	A6F0118-52	6/1/16	6/6/16	6/8/16	6060155	8.98	ug/L	\$15.00
NG	X				Y		NG 20	Health Rm. RR	Apex Laboratories	A6F0118-53	6/1/16	6/6/16	6/8/16	6060155	14.4	ug/L	\$15.00
NG		X			Y		NG 20 6/16F	Health Rm. RR	Apex Laboratories	A6F0629-35	6/20/16	6/27/16	6/28/16	6060794	10.3	ug/L	\$15.00
NG	X				Y		NG 21	Computer Lab	Apex Laboratories	A6F0118-54	6/1/16	6/6/16	6/8/16	6060155	8.67	ug/L	\$15.00
NG	X				Y		NG 22	Fountain SE	Apex Laboratories	A6F0118-55	6/1/16	6/6/16	6/8/16	6060155	12.0	ug/L	\$15.00
NG		X			Y		NG 22 6/16F	Fountain SE	Apex Laboratories	A6F0629-33	6/20/16	6/27/16	6/28/16	6060794	9.47	ug/L	\$15.00
NG		X			Y		NG 22 6/16FF	Fountain SE	Apex Laboratories	A6F0629-34	6/20/16	6/27/16	6/28/16	6060794	13.3	ug/L	\$15.00
NG	X				Y		NG 23	Rm. 10	Apex Laboratories	A6F0118-56	6/1/16	6/6/16	6/8/16	6060155	2.81	ug/L	\$15.00
NG	X				Y		NG 24	Rm. 1	Apex Laboratories	A6F0118-57	6/1/16	6/6/16	6/8/16	6060155	1.52	ug/L	\$15.00
NG	X				Y		NG 25	Rm. 2	Apex Laboratories	A6F0118-58	6/1/16	6/6/16	6/8/16	6060155	1.99	ug/L	\$15.00
NG	X				Y		NG 26	Rm. 9	Apex Laboratories	A6F0118-59	6/1/16	6/6/16	6/8/16	6060155	2.67	ug/L	\$15.00
NG	X				Y		NG 27	Rm. 8	Apex Laboratories	A6F0118-60	6/1/16	6/6/16	6/8/16	6060155	4.28	ug/L	\$15.00
NG	X				Y		NG 28	Rm. 3	Apex Laboratories	A6F0118-61	6/1/16	6/6/16	6/8/16	6060156	0.967	ug/L	\$15.00
NG	X				Y		NG 29	Rm. 4	Apex Laboratories	A6F0118-62	6/1/16	6/6/16	6/8/16	6060156	2.17	ug/L	\$15.00
NG	X				Y		NG 30	Rm. 7	Apex Laboratories	A6F0118-63	6/1/16	6/6/16	6/8/16	6060156	2.00	ug/L	\$15.00
NG	X				Y		NG 31	Rm. 6	Apex Laboratories	A6F0118-64	6/1/16	6/6/16	6/8/16	6060156	5.39	ug/L	\$15.00
NG	X				Y		NG 32	Rm. 5	Apex Laboratories	A6F0118-65	6/1/16	6/6/16	6/8/16	6060156	2.42	ug/L	\$15.00
NG	X				Y		NG 33	Custodial Office	Apex Laboratories	A6F0118-66	6/1/16	6/6/16	6/8/16	6060156	7.86	ug/L	\$15.00
NG	X				Y		NG 50	Ext Hose Bib - NE corner outside HUB Rm.	Apex Laboratories	A6J0075-28	9/2/16	10/5/16	10/6/16	6100256	18.2	ug/L	\$25.00
NG		X			Y		NG 50F	Ext Hose Bib - NE corner outside HUB Rm.	Apex Laboratories	A6J0075-37	9/2/16	10/5/16	10/6/16	6100256	0.278	ug/L	\$25.00
NG	X				Y		NG 51	Ext Hose Bib - East outside HUB Rm.	Apex Laboratories	A6J0075-29	9/2/16	10/5/16	10/6/16	6100256	19.5	ug/L	\$25.00
NG		X			Y		NG 51F	Ext Hose Bib - East outside HUB Rm.	Apex Laboratories	A6J0075-38	9/2/16	10/5/16	10/6/16	6100256	0.467	ug/L	\$25.00
NG	X				N	Labeled not for Drinking	NG 52	Ext Hose Bib - Outside Tech Rm.	Apex Laboratories	A6J0075-30	9/2/16	10/5/16	10/6/16	6100256	59.7	ug/L	\$25.00
NG		X			Y		NG 52F	Ext Hose Bib - Outside Tech Rm.	Apex Laboratories	A6J0075-39F	9/2/16	10/5/16	10/6/16	6100256	0.256	ug/L	\$25.00
NG	X				N	Labeled not for Drinking	NG 53	Ext Hose Bib - Outside Resource Rm.	Apex Laboratories	A6J0075-31	9/2/16	10/5/16	10/6/16	6100256	25.3	ug/L	\$25.00



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45

46
47
48
49
50
51
52
53
54
55
56
57
58
59
60