

Powell Valley Elementary School 4825 E Powell Valley Road, Gresham, OR 97080

Gresham Barlow School District

SCHOOL	TEST# 1 First Flow	TEST# 2 30 Sec Flush	TEST# 3 After action	Action required Y/N	Passed Below 20/ppm Y/N	Remediation	SAMPLE NAME	BUILDING LOCATION	Lab Name	LAB SAMP ID	SAMP DATE	PREP DATE	ANA DATE	BATCH	Result	UNITS
PVES	X			N	Y		PV 401	Fountain Main Office Hall	Apex Labora	A6F0114-60	06/01/20	06/06/2016	06/07/2016	6060136	6.35	ug/L
PVES	X			Y	N		PV 402	Rm. 21 Title	Apex Labora	A6F0114-61	06/01/20	06/06/2016	06/07/2016	6060138	48.2	ug/L
PVES		X		Y	N	Replaced Faucet	PV 402 6/16F	Rm. 21 Title	Apex Labora	A6F0629-43	06/20/20	06/27/2016	06/28/2016	6060795	49.7	ug/L
PVES			X	N	Y		PV-402	Rm. 21 Title	N Lab	A6H0465-08	8/8/16	8/16/16	8/16/16		1.22	ug/L
PVES	X			N	Y		PV 403	Fountain Library Hall	Apex Labora	A6F0114-62	06/01/20	06/06/2016	06/07/2016	6060138	3.22	ug/L
PVES	X			N	Y		PV 404	Rm. 3	Apex Labora	A6F0114-63	06/01/20	06/06/2016	06/07/2016	6060138	5.76	ug/L
PVES	X			N	Y		PV 405	Rm. 1	Apex Labora	A6F0114-64	06/01/20	06/06/2016	06/07/2016	6060138	8.64	ug/L
PVES	X			N	Y		PV 406	Rm. 2	Apex Labora	A6F0114-65	06/01/20	06/06/2016	06/07/2016	6060138	3.39	ug/L
PVES	X			N	Y		PV 407	Rm. 4	Apex Labora	A6F0114-66	06/01/20	06/06/2016	06/07/2016	6060138	12.4	ug/L
PVES	X			N	Y	Replaced Faucet	PV 407 6/16F	Rm. 4	Apex Labora	A6F0629-44	06/20/20	06/27/2016	06/28/2016	6060795	13	ug/L
PVES	X			N	Y		PV 408	Rm. 5	Apex Labora	A6F0114-67	06/01/20	06/06/2016	06/07/2016	6060138	4.26	ug/L
PVES	X			N	Y		PV 409	Rm. 7	Apex Labora	A6F0114-68	06/01/20	06/06/2016	06/07/2016	6060138	4.20	ug/L
PVES	X			N	Y		PV 410	Rm. 9	Apex Labora	A6F0114-69	06/01/20	06/06/2016	06/07/2016	6060138	3.41	ug/L
PVES	X			N	Y		PV 411	Rm. 11	Apex Labora	A6F0114-70	06/01/20	06/06/2016	06/07/2016	6060138	6.32	ug/L
PVES	X			N	Y		PV 412	Fountain Mid Hall	Apex Labora	A6F0114-71	06/01/20	06/06/2016	06/07/2016	6060138	3.45	ug/L
PVES	X			N	Y		PV 413	Rm. 13	Apex Labora	A6F0114-72	06/01/20	06/06/2016	06/07/2016	6060138	12.1	ug/L
PVES		X		N	Y	Replaced Faucet	PV 413 6/16F	Rm. 13	Apex Labora	A6F0629-45	06/20/20	06/27/2016	06/28/2016	6060795	7.34	ug/L
PVES			X	N	Y		PV-413		N Lab	A6H0465-09	8/8/16	8/16/16	8/16/16		0.261	ug/L
PVES	X			N	Y		PV 414	Rm. 15	Apex Labora	A6F0114-73	06/01/20	06/06/2016	06/07/2016	6060138	14.2	ug/L
PVES		X		N	Y		PV 414 6/16F	Rm. 15	Apex Labora	A6F0629-48	06/20/20	06/27/2016	06/28/2016	6060795	16.8	ug/L
PVES			X	N	Y	Replaced Faucet	PV-414		N Lab	A6H0465-10	8/8/16	8/16/16	8/16/16		0.338	ug/L
PVES	X			N	Y		PV 415	Rm. 17	Apex Labora	A6F0114-74	06/01/20	06/06/2016	06/07/2016	6060138	2.38	ug/L
PVES	X			N	Y		PV 416	Rm. 19	Apex Labora	A6F0114-75	06/01/20	06/06/2016	06/07/2016	6060138	2.55	ug/L
PVES	X			N	Y		PV 417	Fountain Gym Hall	Apex Labora	A6F0114-76	06/01/20	06/06/2016	06/07/2016	6060138	13.5	ug/L
PVES			X	N	Y		PV-417 Hallway	Fountain Gym Hall	N Lab	A6H0465-16	8/8/16	8/16/16	8/16/16		2.24	ug/L
PVES		X		N	Y		PV 417 6/16F A	Fountain Gym Interior	Apex Labora	A6F0629-47	06/20/20	06/27/2016	06/28/2016	6060795	15.2	ug/L
PVES		X		Y	N	Replaced supply lines	PV 417 6/16F B	Fountain Music Room	Apex Labora	A6F0629-49	06/20/20	06/27/2016	06/28/2016	6060795	20	ug/L
PVES			X	Y	N	Replaced drinking fountain	PV-417 Band Room	Fountain Music Room	N Lab	A6H0465-17	8/8/16	8/16/16	8/16/16		32	ug/L
PVES			X	N	Y	Water disconnected	PV-417 B	Fountain Music Room	N Lab	A6H0465-18	8/8/16	8/16/16	8/16/16		7.11	ug/L
PVES	X				Y		PV 418	Kitchen Sink	Apex Labora	A6F0114-77	06/01/20	06/06/2016	06/07/2016	6060138	3.01	ug/L
PVES		X			Y		PV 419	Kitchen	Apex Labora	A6F0114-78	06/01/20	06/06/2016	06/07/2016	6060138	15.8	ug/L
PVES	X				Y	Replaced Faucet	PV 419 6/16F	Kitchen	Apex Labora	A6F0629-41	06/20/20	06/27/2016	06/28/2016	6060795	1.46	ug/L
PVES		X	X		Y		PV-419 Left Mix	Kitchen	N Lab	A6H0465-03	8/8/16	8/16/16	8/16/16		0.255	ug/L
PVES	X		X		Y		PV-419 Right Mix	Kitchen	N Lab	A6H0465-04	8/8/16	8/16/16	8/16/16		0.463	ug/L
PVES		X	X		Y		PV-419 Left	Kitchen	N Lab	A6H0465-05	8/8/16	8/16/16	8/16/16		0.709	ug/L
PVES	X		X		Y		PV-419 Right	Kitchen	N Lab	A6H0465-06	8/8/16	8/16/16	8/16/16		0.473	ug/L
PVES	X			Y			PV 420	Kitchen Dishwasher	Apex Labora	A6F0114-79	06/01/20	06/06/2016	06/07/2016	6060138	40.1	ug/L
PVES		X		N		Replaced Faucet	PV 420 6/16F	Kitchen Dishwasher	Apex Labora	A6F0629-42	06/20/20	06/27/2016	06/28/2016	6060795	2.69	ug/L
PVES			X	N			PV-420	Kitchen Dishwasher	N Lab	A6H0465-02	8/8/16	8/16/16	8/16/16		1.35	ug/L
PVES	X			N			PV 421	Fountain Kitchen Hall	Apex Labora	A6F0114-80	06/01/20	06/06/2016	06/07/2016	6060138	8.04	ug/L
PVES	X			N			PV 422	Rm. 20	Apex Labora	A6F0114-81	06/01/20	06/06/2016	06/07/2016	6060139	2.77	ug/L
PVES	X			N			PV 423	Rm. 18	Apex Labora	A6F0114-82	06/01/20	06/06/2016	06/07/2016	6060139	1.53	ug/L
PVES	X			N		Replaced Faucet	PV 424	Rm. 16	Apex Labora	A6F0114-83	06/01/20	06/06/2016	06/07/2016	6060139	14.0	ug/L
PVES		X		N			PV 424 6/16F	Rm. 16	Apex Labora	A6F0629-46	06/20/20	06/27/2016	06/28/2016	6060795	11.1	ug/L
PVES			X	N			PV-424	Rm. 16	N Lab	A6H0465-19	8/8/16	8/16/16	8/16/16		0.344	ug/L

PVES	X		N		PV 425	Rm. 14	Apex Labora	A6F0114-84	06/01/20	06/06/2016	06/07/2016	6060139	2.13 ug/L
PVES	X		N		PV 426	Rm. 12	Apex Labora	A6F0114-85	06/01/20	06/06/2016	06/07/2016	6060139	1.99 ug/L
PVES	X		N		PV 427	Rm. 10	Apex Labora	A6F0114-86	06/01/20	06/06/2016	06/07/2016	6060139	5.34 ug/L
PVES	X		N		PV 428	Rm. 8	Apex Labora	A6F0114-87	06/01/20	06/06/2016	06/07/2016	6060139	5.28 ug/L
PVES	X		N		PV 429	Rm. 6	Apex Labora	A6F0114-88	06/01/20	06/06/2016	06/07/2016	6060139	3.83 ug/L
PVES	X		Y	Labeled not for Drinking	PV 450	Ext Hose Bib - Outside Boiler Rm.	Apex Labora	A6I0953-35	09/01/20	10/05/2016	10/05/2016	6100240	39.5 ug/L
PVES		X	N		PV 450F	Ext Hose Bib - Outside Boiler Rm.	Apex Labora	A6I0953-39	09/01/20	10/05/2016	10/05/2016	6100240	5.31 ug/L
PVES	X		Y	Labeled not for Drinking	PV 451	Ext Hose Bib - Outside Staff Rm.	Apex Labora	A6I0953-36	09/01/20	10/05/2016	10/05/2016	6100240	22.5 ug/L
PVES		X	N		PV 451F	Ext Hose Bib - Outside Staff Rm.	Apex Labora	A6I0953-40	09/01/20	10/05/2016	10/05/2016	6100240	0.561 ug/L
PVES	X		Y	Labeled not for Drinking	PV 452	Ext Hose Bib - Outside Rm. 18	Apex Labora	A6I0953-37	09/01/20	10/05/2016	10/05/2016	6100240	35.2 ug/L
PVES		X	N		PV 452F	Ext Hose Bib - Outside Rm. 18	Apex Labora	A6I0953-41	09/01/20	10/05/2016	10/05/2016	6100240	2.45 ug/L
PVES	X		Y	Labeled not for Drinking	PV 453	Ext Hose Bib - Outside Rm. 10	Apex Labora	A6I0953-38	09/01/20	10/05/2016	10/05/2016	6100240	28.3 ug/L
PVES		X	N		PV 453F	Ext Hose Bib - Outside Rm. 10	Apex Labora	A6I0953-42	09/01/20	10/05/2016	10/05/2016	6100240	2.42 ug/L
PVES	X		Y	Labeled not for Drinking	PV 454	Ext Hose Bib - Outside Rm. 1	Apex Labora	A6I0953-43	09/01/20	10/05/2016	10/05/2016	6100240	20.0 ug/L
PVES		X	N		PV 454F	Ext Hose Bib - Outside Rm. 1	Apex Labora	A6I0953-48	09/01/20	10/05/2016	10/05/2016	6100240	0.663 ug/L
PVES	X		Y	Labeled not for Drinking	PV 455	Ext Hose Bib - Outside Rm. 9	Apex Labora	A6I0953-44	09/01/20	10/05/2016	10/05/2016	6100240	30.4 ug/L
PVES		X	N		PV 455F	Ext Hose Bib - Outside Rm. 9	Apex Labora	A6I0953-49	09/01/20	10/05/2016	10/05/2016	6100240	3.19 ug/L
PVES	X		Y	Labeled not for Drinking	PV 456	Ext Hose Bib - Outside Rm. 13	Apex Labora	A6I0953-45	09/01/20	10/05/2016	10/05/2016	6100240	42.6 ug/L
PVES		X	N		PV 456F	Ext Hose Bib - Outside Rm. 13	Apex Labora	A6I0953-50	09/01/20	10/05/2016	10/05/2016	6100240	1.62 ug/L
PVES	X		Y	Labeled not for Drinking	PV 457	Ext Hose Bib - NW Outside Gym	Apex Labora	A6I0953-46	09/01/20	10/10/2016	10/11/2016	6100386	1480 ug/L
PVES		X	N		PV 457F	Ext Hose Bib - NW Outside Gym	Apex Labora	A6I0953-51	09/01/20	10/05/2016	10/05/2016	6100240	6.81 ug/L
PVES	X		Y	Labeled not for Drinking	PV 458	Ext Hose Bib - NE Outside Gym	Apex Labora	A6I0953-47	09/01/20	10/10/2016	10/11/2016	6100386	24.5 ug/L
PVES		X	N		PV 458F	Ext Hose Bib - NE Outside Gym	Apex Labora	A6I0953-52	09/01/20	10/05/2016	10/05/2016	6100240	0.979 ug/L

Numbers of
samples

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25
- 26
- 27
- 28**
- 29**
- 30
- 31
- 32
- 33
- 34
- 35
- 36
- 37
- 38
- 39
- 40
- 41
- 42
- 43
- 44
- 45

46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68