

	TEST# 1 First Flow	TEST# 2 30 Sec Flush	TEST# 3 After action	Action required Y/N	Passed Below 20/ppm Y/N	Remediation	SAMPLE NAME	BUILDING LOCATION	Lab Name	LAB SAMP ID	SAMPLE DATE	PREP DATE	ANA DATE	BATCH	Result target <20ppb		
															ND= non detect	UNITS	COST PER SAMPLE
SBHS	X				Y		SB 801	Boys Locker Rm.	Apex Laborat	A6F0137-99	6/2/16	6/7/16	6/8/16	6060206	3.7	ug/L	\$15.00
SBHS	X				Y		SB 802	Girls Locker Rm.	Apex Laborat	A6F0137-AA	6/2/16	6/7/16	6/8/16	6060206	1.18	ug/L	\$15.00
SBHS	X				Y		SB 803	Main Gym West	Apex Laborat	A6F0138-01	6/2/16	6/10/16	6/10/16	6060319	0.652	ug/L	\$15.00
SBHS	X				Y		SB 804	Main Gym East	Apex Laborat	A6F0138-02	6/2/16	6/10/16	6/10/16	6060319	0.427	ug/L	\$15.00
SBHS	X				Y		SB 805	Gym Hallway	Apex Laborat	A6F0138-03	6/2/16	6/10/16	6/10/16	6060319	5.83	ug/L	\$15.00
SBHS	X				Y		SB 806	Café North Wall	Apex Laborat	A6F0138-04	6/2/16	6/10/16	6/10/16	6060319	ND	ug/L	\$15.00
SBHS	X				Y		SB 807	Café South Wall	Apex Laborat	A6F0138-05	6/2/16	6/10/16	6/10/16	6060319	8.90	ug/L	\$15.00
SBHS	X				Y		SB 808	Kitchen	Apex Laborat	A6F0138-06	6/2/16	6/10/16	6/10/16	6060319	1.50	ug/L	\$15.00
SBHS	X				Y		SB 809	Kitchen	Apex Laborat	A6F0138-07	6/2/16	6/10/16	6/10/16	6060319	1.67	ug/L	\$15.00
SBHS	X				Y		SB 810	Kitchen	Apex Laborat	A6F0138-08	6/2/16	6/10/16	6/10/16	6060319	2.12	ug/L	\$15.00
SBHS	X				Y		SB 811	Kitchen	Apex Laborat	A6F0138-09	6/2/16	6/10/16	6/10/16	6060319	1.14	ug/L	\$15.00
SBHS	X				Y		SB 812	Kitchen	Apex Laborat	A6F0138-10	6/2/16	6/10/16	6/10/16	6060319	3.04	ug/L	\$15.00
SBHS	X				Y		SB 813	100 Hall	Apex Laborat	A6F0138-11	6/2/16	6/10/16	6/10/16	6060319	1.33	ug/L	\$15.00
SBHS	X				Y		SB 814	200 Hall	Apex Laborat	A6F0138-12	6/2/16	6/10/16	6/10/16	6060319	0.258	ug/L	\$15.00
SBHS	X				Y		SB 815	Main Hall Library	Apex Laborat	A6F0138-13	6/2/16	6/10/16	6/10/16	6060319	ND	ug/L	\$15.00
SBHS	X				N	Replaced Faucet	SB 816	Main Office	Apex Laborat	A6F0138-14	6/2/16	6/10/16	6/10/16	6060319	23.0	ug/L	\$15.00
SBHS		X			Y		SB 816 6/16F	Main Office	Apex Laborat	A6F0629-52	6/2/16	6/27/16	6/28/16	6060795	4.82	ug/L	\$15.00
SBHS	X				Y		SB 817	500 Hall	Apex Laborat	A6F0138-15	6/2/16	6/10/16	6/10/16	6060321	1.33	ug/L	\$15.00
SBHS	X				Y		SB 818	Auditorium Hall	Apex Laborat	A6F0138-16	6/2/16	6/10/16	6/10/16	6060321	0.481	ug/L	\$15.00
SBHS	X				Y		SB 819	Music Hall	Apex Laborat	A6F0138-17	6/2/16	6/10/16	6/10/16	6060321	0.411	ug/L	\$15.00
SBHS	X				Y		SB 820	Metal Shop	Apex Laborat	A6F0138-18	6/2/16	6/10/16	6/10/16	6060321	1.55	ug/L	\$15.00
SBHS	X				Y		SB 821	Pool Deck East	Apex Laborat	A6F0138-19	6/2/16	6/10/16	6/10/16	6060321	0.991	ug/L	\$15.00
SBHS	X				Y		SB 822	Pool Deck West	Apex Laborat	A6F0138-20	6/2/16	6/10/16	6/10/16	6060321	14.7	ug/L	\$15.00
SBHS		X			Y		SB 822 6/16F	Pool Deck West	Apex Laborat	A6F0629-51	6/2/16	6/27/16	6/28/16	6060795	1.3	ug/L	\$15.00
SBHS	X				Y		SB 823A	Fountain Holevas Gym Left	Apex Laborat	A6F0138-21	6/2/16	6/10/16	6/10/16	6060321	1.01	ug/L	\$15.00
SBHS	X				Y		SB 823B	Fountain Holevas Gym Right	Apex Laborat	A6F0138-22	6/2/16	6/10/16	6/10/16	6060321	0.932	ug/L	\$15.00
SBHS	X				Y		SB 824	Wrestling Rm.	Apex Laborat	A6F0138-23	6/2/16	6/10/16	6/10/16	6060321	1.42	ug/L	\$15.00
SBHS	X				N	Labeled not for Drink	SB 825	Ext Hose Bib - Baseball	Apex Laborat	A6F0138-24	6/2/16	6/10/16	6/10/16	6060321	49.1	ug/L	\$15.00
SBHS		X			Y		SB 825 6/16F	Ext Hose Bib - Baseball	Apex Laborat	A6F0629-53	6/20/16	6/27/16	6/28/16	6060795	2.38	ug/L	\$15.00
SBHS	X				Y		SB 826	Ext Hose Bib - Childcare	Apex Laborat	A6F0138-25	6/2/16	6/10/16	6/10/16	6060321	17.6	ug/L	\$15.00
SBHS		X			Y		SB 826 6/16F	Ext Hose Bib - Childcare	Apex Laborat	A6F0629-50	6/20/16	6/27/16	6/28/16	6060795	7.53	ug/L	\$15.00
SBHS	X				Y		SB 827	Ext Hose Bib - Grounds Shop	Apex Laborat	A6I0419-91	8/31/16	9/30/16	10/4/16	6091182	6.88	ug/L	\$25.00
SBHS		X			Y		SB 827F	Ext Hose Bib - Grounds Shop	Apex Laborat	A6I0419-92	8/31/16	9/30/16	10/4/16	6091182	0.292	ug/L	\$25.00
SBHS	X				Y		SB 828	Ext Hose Bib - Tennis Court by Boys RR	Apex Laborat	A6I0419-93	8/31/16	9/30/16	10/4/16	6091182	1.94	ug/L	\$25.00
SBHS		X			Y		SB 828F	Ext Hose Bib - Tennis Court by Boys RR	Apex Laborat	A6I0419-94	8/31/16	9/30/16	10/4/16	6091182	0.321	ug/L	\$25.00
SBHS	X				Y		SB 829	Ext Hose Bib - Green House	Apex Laborat	A6I0419-95	8/31/16	10/3/16	10/5/16	6100157	3.19	ug/L	\$25.00
SBHS		X			Y		SB 829F	Ext Hose Bib - Green House	Apex Laborat	A6I0419-96	8/31/16	10/3/16	10/5/16	6100157	0.200	ug/L	\$25.00
SBHS	X				N	Replaced Faucet	SB 830	Faucet - Boys Locker Room Coaches Office	Apex Laborat	A6I0419-97	8/31/16	10/3/16	10/5/16	6100157	181	ug/L	\$25.00
SBHS		X			Y		SB 830F	Faucet - Boys Locker Room Coaches Office	Apex Laborat	A6I0419-98	8/31/16	10/3/16	10/5/16	6100157	18.5	ug/L	\$25.00
SBHS	X				Y		SB 831	Mop Sink - Gym Hall Custodial Closet	Apex Laborat	A6I0419-99	8/31/16	10/5/16	10/5/16	6100231	14.2	ug/L	\$25.00
SBHS		X			Y		SB 831F	Mop Sink - Gym Hall Custodial Closet	Apex Laborat	A6I0419-AAF	8/31/16	10/3/16	10/5/16	6100157	0.789	ug/L	\$25.00
SBHS	X				Y		SB 832	Ice Machine - Girls Locker Room	Apex Laborat	A6I0953-01	8/31/16	10/5/16	10/5/16	6100217	1.46	ug/L	\$25.00
SBHS		X			Y		SB 833	Ice Machine - Kitchen in Cafeteria	Apex Laborat	A6I0953-02	8/31/16	10/5/16	10/5/16	6100217	2.30	ug/L	\$25.00





Number of  
samples

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25
- 26
- 27
- 28
- 29
- 30
- 31
- 32
- 33
- 34
- 35
- 36
- 37
- 38
- 39
- 40
- 41
- 42
- 43

44

45

46

47

48

49

50

51

52

53

54

55

56

57

58

59

60

61

62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73