December 2023

CLEAN

SAFE

HEALTHY

SCHOOLS

Amity Regional School District No. 5

Facilities Department Monthly Report

Completed Projects:

- The lecture hall at ARHS is complete, all the punch list items have been addressed.
- The gym floor repair at AMSO is complete. A complete refinish is planned for next summer.
- New shot clocks were installed in the ARHS gym by our in house electrician and building maintainer.
- Power was run from the press box to the IT cabinets under the home and visitor side bleachers at ARHS. New junction boxes and conduits were also added for additional runs of fiber for the IT department.
- Both variable frequency drives on the chillers at ARHS were refurbished by TRANE.
- Electrical contactors for the chiller at AMSB were replaced by TRANE.
- A leaking discharge pipe for the fire pump at AMSO was repaired by our fire protection contractor.
- Restriping and renumbering of parking spaces as well as repainting of speed bumps, fire lanes, and curbing at ARHS was completed.

Projects in Process:

Amity Regional School District No. 5

25 Newton Road

Woodbridge, CT 06525 Phone: 203-397-4817

Fax: 203-397-4864

- Re-lamping the Bethany indoor fixtures is still in progress with approximately 10% left to complete. Unlike AMSO, the majority of the fixtures at AMSB need to be rewired prior to re-lamping.
- All of the failed parking lot light fixtures at ARHS have been replaced. We are working on scheduling lift rentals around the weather to finish replacing the remaining fixtures.
- A sewage ejector pump at AMSO is in need of being rebuilt. Hungerfords pumps are working on ordering the materials and once they are in, a day will be scheduled to pull the pump and rebuild it.
- Classic Turf has repaired some warranty items on the track at ARHS.
- All snow removal equipment is being gone through and prepped for the winter season.
- Filter changes on all air handlers District Wide is underway.
- The test header piping for the fire pump at AMSB is scheduled to be redone this month.

