



ALG ORELAP ID #OR100012  
361 West 5th Ave  
Eugene, OR 97401  
TEL: (541) 485-8404 FAX: (541) 484-5995  
Website:

September 24, 2018

Brett Yancey  
Springfield School District #19  
1890 North 42nd Street  
Springfield, OR 97477  
TEL:  
FAX

RE: THS CDC

Order No.: 1809614

Dear Brett Yancey:

Analytical Laboratory Group received 10 sample(s) on 9/13/2018 for the analyses presented in the following report.

Kimberly Reeve Morghan  
Quality Manager  
361 West 5th Ave  
Eugene, OR 97401



ALG ORELAP ID #OR100012  
361 West 5th Ave  
Eugene, OR 97401  
TEL: (541) 485-8404 FAX: (541) 484-5995  
Website:

## Case Narrative

WO#: 1809614  
Date: 9/24/2018

---

**CLIENT:** Springfield School District #19  
**Project:** THS CDC

---

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met except as noted below.

Analytical comments are noted with qualifiers (see "Qual" column) or data flags on the reports and/or below.



**WO#:** 1809614  
**CLIENT:** Springfield School District #19  
**Location:**  
**Project:** THS CDC  
**Sample Source:**

**Received Date:** 9/13/2018 8:50:00 AM  
**Sampler Name:** Thomas Schmit  
**Matrix:** Drinking Water  
**Treatment:**

**Lab ID:** 1809614-001      **Client Sample ID** #1      **Collection Date:** 9/13/2018 7:05:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	9/21/2018 6:21:00 PM	AS

**Lab ID:** 1809614-002      **Client Sample ID** #2      **Collection Date:** 9/13/2018 7:06:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	9/21/2018 6:21:00 PM	AS

**Lab ID:** 1809614-003      **Client Sample ID** #3      **Collection Date:** 9/13/2018 7:08:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	9/21/2018 6:21:00 PM	AS

**Lab ID:** 1809614-004      **Client Sample ID** #4      **Collection Date:** 9/13/2018 7:10:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	8.01	15.0	2.00		ppb	9/21/2018 6:21:00 PM	AS

**Lab ID:** 1809614-005      **Client Sample ID** #5      **Collection Date:** 9/13/2018 7:14:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	9/21/2018 6:21:00 PM	AS

**Lab ID:** 1809614-006      **Client Sample ID** #6      **Collection Date:** 9/13/2018 7:15:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	9/21/2018 6:21:00 PM	AS

**Lab ID:** 1809614-007      **Client Sample ID** #7      **Collection Date:** 9/13/2018 7:20:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.43	15.0	2.00		ppb	9/21/2018 6:21:00 PM	AS

**Lab ID:** 1809614-008      **Client Sample ID** #8      **Collection Date:** 9/13/2018 7:21:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	3.74	15.0	2.00		ppb	9/21/2018 6:21:00 PM	AS

**Qualifiers:**

- \* Value exceeds Maximum Contaminant Level (MCL)
- C Value is below Minimum Compound Limit.
- H Holding times for preparation or analysis exceeded
- MCL Maximum Contaminant Level
- ND Not Detected at the Reporting Limit
- A Accredited by ORELAP
- E Value above quantitation range
- LOD Limit of Detection
- NAR See note in Case Narrative
- PL Permit Limit



ALG ORELAP ID #OR100012  
 361 West 5th Ave  
 Eugene, OR 97401  
 TEL: (541) 485-8404 FAX: (541) 484-5995  
 Website:

# Analytical Report

Date Reported: 9/24/2018

**WO#:** 1809614  
**CLIENT:** Springfield School District #19  
**Location:**  
**Project:** THS CDC  
**Sample Source:**

**Received Date:** 9/13/2018 8:50:00 AM  
**Sampler Name:** Thomas Schmit  
**Matrix:** Drinking Water  
**Treatment:**

Lab ID:	Client Sample ID			Collection Date:				
1809614-009	#9			9/13/2018 7:22:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	5.75	15.0	2.00		ppb	9/21/2018 6:21:00 PM	AS

Lab ID:	Client Sample ID			Collection Date:				
1809614-010	#10			9/13/2018 7:32:00 AM				
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	9/21/2018 6:21:00 PM	AS

<b>Qualifiers:</b>	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit



Delivering more than  
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

## Definition Base

WO#: 1809614

Date: 9/24/2018

---

### Definitions:

### Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.



Delivering more than just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

# Accreditation Program Analytes Report

WO#: 1809614

24-Sep-18

**Client:** Springfield School District #19

**Project:** THS CDC

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	1809614-001A	#1	Drinking Water	AA Metals by SM 3113 Daycare 250mL	Lead	A
	1809614-002A	#2			Lead	A
	1809614-003A	#3			Lead	A
	1809614-004A	#4			Lead	A
	1809614-005A	#5			Lead	A
	1809614-006A	#6			Lead	A
	1809614-007A	#7			Lead	A
	1809614-008A	#8			Lead	A
	1809614-009A	#9			Lead	A
	1809614-010A	#10			Lead	A

ORELAP A Accredited

ACCRED

Original #1809614# v1

Page 6 of 6

Limbs SC  
checked CO

# Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE  
EUGENE, OREGON 97401  
800-262-5973/541-485-8404 Fax 541-484-5995  
Email: [alglabs@alglabsinc.com](mailto:alglabs@alglabsinc.com)



Delivering more than  
just test results

## CHAIN OF CUSTODY

Attention: <b>Brett Yancey</b>	Client: <b>Springfield School District</b>
Phone: <b>(541) 744-6375</b>	Address: <b>1890 North 42nd Street</b>
Email: <b>brett.yancey@springfield.k12.or.us</b>	City, State, Zip: <b>Springfield, OR 97477</b>
Client Project: <del>Page Elementary</del> <b>THIS CDC</b>	Sampler: Print <b>Thomas Schmit</b> Sampler: Signature <i>Thomas Schmit</i>

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
#1	DW/Grab	9/13/18	7:05	Lead	P	1			001A
#2	DW/Grab	9/13/18	7:06	Lead	P	1			002A
#3	DW/Grab	9/13/18	7:08	Lead	P	1			003A
#4	DW/Grab	9/13/18	7:10	Lead	P	1			004A
#5	DW/Grab	9/13/18	7:14	Lead	P	1			005A
#6	DW/Grab	9/13/18	7:15	Lead	P	1			006A
#7	DW/Grab	9/13/18	7:20	Lead	P	1			007A
#8	DW/Grab	9/13/18	7:24	Lead	P	1			008A
#9	DW/Grab	9/13/18	7:22	Lead	P	1			009A
#10	DW/Grab	9/13/18	7:32	Lead	P	1			010A

Notes: <i>Childcare</i>	<b>Preservation Check</b> <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>Lab ID</th> <th>Date/Time</th> <th>Pre-Preserved</th> <th>pH</th> <th>Tech</th> </tr> </thead> <tbody> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> <tr><td> </td><td> </td><td> </td><td> </td><td> </td></tr> </tbody> </table>	Lab ID	Date/Time	Pre-Preserved	pH	Tech																																													
Lab ID	Date/Time	Pre-Preserved	pH	Tech																																															

Turn Around Time Requested (Rush incurs a Surcharge): <i>Before end of Sept.</i> <input type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: <i>Thomas Schmit</i>	Refrigerated <i>no</i>
Relinquished by: <i>Thomas Schmit</i>	Date: <i>9/13/18</i> Time: <i>8:50</i>	Received by: Date:      Time:
Relinquished by:	Date:      Time: <i>9/13/18</i>	Received by:
Relinquished by:	Date:      Time:	Received by Laboratory: <i>[Signature]</i>
		Date: <i>9/13/18</i> Time: <i>08:50</i>