

Kim Moore

From: Facilities
Sent: Friday, June 23, 2023 2:31 PM
Subject: Addendum 1 - Request for Quote for Concrete Remove and Replacement #24005

The following additions, deletions, modifications, or clarifications shall be made to the appropriate sections of the specifications and shall become a part of the Contract Documents. Bidders shall acknowledge receipt of this Addendum on the Bid form.

Notice of Bid Changes:

- **Sawcut, as necessary, to protect remaining concrete and poles.**
- **Concrete finish shall be a sand blast or sand washed finish to match existing. Add lamp black to slightly darken finish.**
- **Use 1/2" rebar to dowel into existing and 3/8" rebar for grid.**
- **Polymeric sand for paver re-install shall be charcoal grey in color.**

Thanks,

Tracey

