



Customer Name: Derry Township
Address: 30C East Granada Ave
City, State, Zip: Hershey PA 17033
Attn:
email:
Date: August 10, 2023
RE: Early Childhood Center Water Sampling Results

Sample Date: 07/24/23

Lab ID AB59376:

Lab Sample Number	Client Sample ID/ Sample Location	Copper	EPA Action Level Copper	Lead	EPA Action Level Lead
1	Left Ftn @ 40	270 ppb	1,300 ppb	<1.00 ppb	15 ppb
2	Left Ftn @ 6	220 ppb	1,300 ppb	<1.00 ppb	15 ppb
3	Right Ftn @ 20	470 ppb	1,300 ppb	<1.00 ppb	15 ppb
4	Right Ftn @ 32	510 ppb	1,300 ppb	<1.00 ppb	15 ppb
5	Ftn inside Rm 34	350 ppb	1,300 ppb	<1.00 ppb	15 ppb

* ND- None Detected

** ppb- Parts per Billion

Comments / Recommendations:

ACIA has found all locations sampled on July 24, 2023 to be within EPA limits. There are no further recommendations at this time.

Regards,

AIRBORNE CONTAMINATION IDENTIFICATION ASSOCIATES, LTD.

Randall R. Leaman

Our Certifications:

WBENC: Certified Women Owned Business (WBE)

Pennsylvania Home Improvement Contractor Registration Number: PA 059333

NADCA Certified Ventilation Systems Mold Remediators (CVSMR)

NADCA Certified Air Systems Cleaning Specialists (ASCS)

AEE – Certified Indoor Air Quality Professional (CIAQP)

ACAC: Certified Mold Remediation Supervisor (Required by Maryland Law) (CMRS)

Anabec: Certified Microbial Remediator Supervisor and Product Distributor (CMRS)

Co-Stars Number: 008-002



Customer Name: Derry Township
Address: 30C East Granada Ave
City, State, Zip: Hershey PA 17033
Attn:
email:
Date: August 10, 2023
RE: Hershey Elem. Water Sampling Results

Sample Date: 07/24/23

Lab ID AB59392:

Lab Sample Number	Client Sample ID/ Sample Location	Copper	EPA Action Level Copper	Lead	EPA Action Level Lead
1	Left Ftn @ 7	410 ppb	1,300 ppb	<1.00 ppb	15 ppb
2	Ftn @ 28	770 ppb	1,300 ppb	<1.00 ppb	15 ppb
3	Right Ftn @ 35	410 ppb	1,300 ppb	<1.00 ppb	15 ppb
4	Left Ftn @ Rec.	150 ppb	1,300 ppb	<1.00 ppb	15 ppb
5	Gym Ftn	270 ppb	1,300 ppb	<1.00 ppb	15 ppb
6	Left Ftn @ Caf� 1	190 ppb	1,300 ppb	<1.00 ppb	15 ppb

* ND- None Detected
** ppb- Parts per Billion

Comments / Recommendations:

ACIA has found all locations sampled on July 24, 2023 to be within EPA limits. There are no further recommendations at this time.

Regards,

AIRBORNE CONTAMINATION IDENTIFICATION ASSOCIATES, LTD.

Randall R. Leaman

Our Certifications:

WBENC: Certified Women Owned Business (WBE)
Pennsylvania Home Improvement Contractor Registration Number: PA 059333
NADCA Certified Ventilation Systems Mold Remediators (CVSMR)
NADCA Certified Air Systems Cleaning Specialists (ASCS)
AEE – Certified Indoor Air Quality Professional (CIAQP)
ACAC: Certified Mold Remediation Supervisor (Required by Maryland Law) (CMRS)
Anabec: Certified Microbial Remediator Supervisor and Product Distributor (CMRS)
Co-Stars Number: 008-002



Customer Name: Derry Township
Address: 30C East Granada Ave
City, State, Zip: Hershey PA 17033
Attn:
email:
Date: August 10, 2023
RE: Hershey Middle School Water Sampling Results

Sample Date: 07/24/23

Lab ID AB59391:

Lab Sample Number	Client Sample ID/ Sample Location	Copper	EPA Action Level Copper	Lead	EPA Action Level Lead
1	Boys Locker Rm Ftn	420 ppb	1,300 ppb	<1.00 ppb	15 ppb
2	Ftn @ G16	1,100 ppb	1,300 ppb	<1.00 ppb	15 ppb
3	Ftn @ G05	220 ppb	1,300 ppb	<1.00 ppb	15 ppb
4	Ftn @ Gym	93 ppb	1,300 ppb	<1.00 ppb	15 ppb
5	Ftn @ B116	93 ppb	1,300 ppb	<1.00 ppb	15 ppb
6	Ftn @ A133	1,300 ppb	1,300 ppb	<1.00 ppb	15 ppb

* ND- None Detected

** ppb- Parts per Billion

Comments / Recommendations:

Sample location six is at the acceptable limit. A re-test could be performed to ensure a lower level. If you wish to re-test the fountain, it should be flushed then let stand 8-24hrs before re-sampling.

Regards,

AIRBORNE CONTAMINATION IDENTIFICATION ASSOCIATES, LTD.

Randall R. Leaman

Our Certifications:

WBENC: Certified Women Owned Business (WBE)

Pennsylvania Home Improvement Contractor Registration Number: PA 059333

NADCA Certified Ventilation Systems Mold Remediators (CVSMR)

NADCA Certified Air Systems Cleaning Specialists (ASCS)

AEE – Certified Indoor Air Quality Professional (CIAQP)

ACAC: Certified Mold Remediation Supervisor (Required by Maryland Law) (CMRS)

Anabec: Certified Microbial Remediator Supervisor and Product Distributor (CMRS)

Co-Stars Number: 008-002



Customer Name: Derry Township
Address: 30C East Granada Ave
City, State, Zip: Hershey PA 17033
Attn:
email:
Date: August 10, 2023
RE: Hershey High School Water Sampling Results

Sample Date: 07/24/23

Lab ID AB59389:

Lab Sample Number	Client Sample ID/ Sample Location	Copper	EPA Action Level Copper	Lead	EPA Action Level Lead
1	Left Ftn @ D209	430 ppb	1,300 ppb	<1.00 ppb	15 ppb
2	Right Ftn @ F225	210 ppb	1,300 ppb	<1.00 ppb	15 ppb
3	Right Ftn @ G237	970 ppb	1,300 ppb	<1.00 ppb	15 ppb
4	Left Ftn @ Nurse	110 ppb	1,300 ppb	<1.00 ppb	15 ppb
5	Right Ftn @ Chorus	220 ppb	1,300 ppb	<1.00 ppb	15 ppb
6	Left Ftn @ Gym	140 ppb	1,300 ppb	<1.00 ppb	15 ppb

* ND- None Detected
** ppb- Parts per Billion

Comments / Recommendations:

ACIA has found all locations sampled on July 24, 2023 to be within EPA limits. There are no further recommendations at this time.

Regards,

AIRBORNE CONTAMINATION IDENTIFICATION ASSOCIATES, LTD.

Randall R. Leaman

Our Certifications:

WBENC: Certified Women Owned Business (WBE)
Pennsylvania Home Improvement Contractor Registration Number: PA 059333
NADCA Certified Ventilation Systems Mold Remediators (CVSMR)
NADCA Certified Air Systems Cleaning Specialists (ASCS)
AEE – Certified Indoor Air Quality Professional (CIAQP)
ACAC: Certified Mold Remediation Supervisor (Required by Maryland Law) (CMRS)
Anabec: Certified Microbial Remediator Supervisor and Product Distributor (CMRS)
Co-Stars Number: 008-002