

Lead Sampling KEY

In general, the number is the room number or a location very close to the room number (typically used for water coolers or bubblers).

F-Faucet

B-Bubbler

WC-Water Cooler

WCBF-Water Cooler Bottle Filler

L,M,R – Left, Middle, Right

N,W,S,E – North, West, South, East

a,b,c,d,e,f.... Are samples within a room – typically starting on the left as you enter the room is a. If all the faucets are on the right side of room the first sample a would be the first faucet you come to.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012012316
 CustomerID: PLTH42
 CustomerPO:
 ProjectID:

Attn: **John Polito**
Polito Home Inspections, Inc.
181 Monroe Street
Honeoye Falls, NY 14472

Phone: (585) 330-5644
 Fax:
 Received: 11/2/2020 11:45 AM

Project: **Cal Mum Elementary School**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
11FE		10/27/2020 11:00:00 PM		012012316-0001	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.28	1.00 µg/L	11/10/2020 KB	11/11/2020 KB 22:57
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
11FG		10/27/2020 11:00:00 PM		012012316-0002	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	3.71	1.00 µg/L	11/10/2020 KB	11/11/2020 KB 23:00
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
9EF		10/27/2020 11:00:00 PM		012012316-0003	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	3.99	1.00 µg/L	11/10/2020 KB	11/11/2020 KB 23:02
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
2AWCBF		10/27/2020 11:00:00 PM		012012316-0004	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.48	1.00 µg/L	11/10/2020 KB	11/11/2020 KB 23:03
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
1AF		10/27/2020 11:00:00 PM		012012316-0005	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	2.31	1.00 µg/L	11/10/2020 KB	11/11/2020 KB 23:04

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012012316
 CustomerID: PLTH42
 CustomerPO:
 ProjectID:

Attn: **John Polito**
Polito Home Inspections, Inc.
181 Monroe Street
Honeoye Falls, NY 14472

Phone: (585) 330-5644
 Fax:
 Received: 11/2/2020 11:45 AM

Project: **Cal Mum Elementary School**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
3AF		10/27/2020 11:00:00 PM		012012316-0006	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	2.67	1.00 µg/L	11/10/2020 KB	11/11/2020 KB 23:05
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
7AF		10/27/2020 11:00:00 PM		012012316-0007	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/10/2020 KB	11/11/2020 KB 23:07
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
13AF		10/27/2020 11:00:00 PM		012012316-0008	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	21.9	1.00 µg/L	11/10/2020 KB	11/11/2020 KB 23:10
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
16AF		10/27/2020 11:00:00 PM		012012316-0009	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.26	1.00 µg/L	11/10/2020 KB	11/11/2020 KB 23:12
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
CAFEWCBF		10/27/2020 11:00:00 PM		012012316-0010	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/10/2020 KB	11/11/2020 KB 23:13

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012012316
 CustomerID: PLTH42
 CustomerPO:
 ProjectID:

Attn: **John Polito**
Polito Home Inspections, Inc.
181 Monroe Street
Honeoye Falls, NY 14472

Phone: (585) 330-5644
 Fax:
 Received: 11/2/2020 11:45 AM

Project: **Cal Mum Elementary School**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
CAFEFL		10/27/2020 11:00:00 PM		012012316-0011	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.20	1.00 µg/L	11/10/2020 KB	11/11/2020 KB 23:14

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
CAFEFR		10/27/2020 11:00:00 PM		012012316-0012	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.26	1.00 µg/L	11/10/2020 KB	11/11/2020 KB 23:18

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
CAFESINGLE		10/27/2020 11:00:00 PM		012012316-0013	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.16	1.00 µg/L	11/10/2020 KB	11/11/2020 KB 23:19

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
2BF		10/27/2020 11:00:00 PM		012012316-0014	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	7.66	1.00 µg/L	11/10/2020 KB	11/11/2020 KB 23:21

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
4BF		10/27/2020 11:00:00 PM		012012316-0015	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	11.2	1.00 µg/L	11/10/2020 KB	11/11/2020 KB 23:22

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012012316
 CustomerID: PLTH42
 CustomerPO:
 ProjectID:

Attn: **John Polito**
Polito Home Inspections, Inc.
181 Monroe Street
Honeoye Falls, NY 14472

Phone: (585) 330-5644
 Fax:
 Received: 11/2/2020 11:45 AM

Project: **Cal Mum Elementary School**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
3BWCBF		10/27/2020 11:00:00 PM		012012316-0016	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.57	1.00 µg/L	11/10/2020 KB	11/11/2020 KB 23:26
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
6BF		10/27/2020 11:00:00 PM		012012316-0017	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	3.91	1.00 µg/L	11/10/2020 KB	11/11/2020 KB 23:27
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
8BF		10/27/2020 11:00:00 PM		012012316-0018	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	6.15	1.00 µg/L	11/10/2020 KB	11/11/2020 KB 23:28
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
10BF		10/27/2020 11:00:00 PM		012012316-0019	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	5.05	1.00 µg/L	11/10/2020 KB	11/11/2020 KB 23:29
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
12BF		10/27/2020 11:00:00 PM		012012316-0020	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	2.88	1.00 µg/L	11/10/2020 KB	11/11/2020 KB 23:31

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012012316
 CustomerID: PLTH42
 CustomerPO:
 ProjectID:

Attn: **John Polito**
Polito Home Inspections, Inc.
181 Monroe Street
Honeoye Falls, NY 14472

Phone: (585) 330-5644
 Fax:
 Received: 11/2/2020 11:45 AM

Project: **Cal Mum Elementary School**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
13BF		10/27/2020 11:00:00 PM		012012316-0021	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	6.10	1.00 µg/L	11/10/2020 KB	11/11/2020 KB 23:36
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
22AFL		10/27/2020 11:00:00 PM		012012316-0022	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	50.8	1.00 µg/L	11/10/2020 KB	11/11/2020 KB 23:42
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
22AFR		10/27/2020 11:00:00 PM		012012316-0023	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	68.3	1.00 µg/L	11/10/2020 KB	11/11/2020 KB 23:43
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
22AWCBF		10/27/2020 11:00:00 PM		012012316-0024	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/10/2020 KB	11/11/2020 KB 23:45
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
27AF		10/27/2020 11:00:00 PM		012012316-0025	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	11.2	1.00 µg/L	11/10/2020 KB	11/11/2020 KB 23:46

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012012316
 CustomerID: PLTH42
 CustomerPO:
 ProjectID:

Attn: **John Polito**
Polito Home Inspections, Inc.
181 Monroe Street
Honeoye Falls, NY 14472

Phone: (585) 330-5644
 Fax:
 Received: 11/2/2020 11:45 AM

Project: **Cal Mum Elementary School**

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
40AWCBF		10/27/2020 11:00:00 PM		012012316-0026	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.92	1.00 µg/L	11/10/2020 KB	11/11/2020 KB 23:47
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
42AR		10/27/2020 11:00:00 PM		012012316-0027	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	7.91	1.00 µg/L	11/10/2020 KB	11/11/2020 KB 23:48
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
42AM		10/27/2020 11:00:00 PM		012012316-0028	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	8.66	1.00 µg/L	11/10/2020 KB	11/11/2020 KB 23:50
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
42AL		10/27/2020 11:00:00 PM		012012316-0029	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	11.5	1.00 µg/L	11/10/2020 KB	11/11/2020 KB 23:51
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
28EF		10/27/2020 11:00:00 PM		012012316-0030	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	2.13	1.00 µg/L	11/10/2020 KB	11/11/2020 KB 23:52

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012012316
 CustomerID: PLTH42
 CustomerPO:
 ProjectID:

Attn: **John Polito**
Polito Home Inspections, Inc.
181 Monroe Street
Honeoye Falls, NY 14472

Phone: (585) 330-5644
 Fax:
 Received: 11/2/2020 11:45 AM

Project: Cal Mum Elementary School

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
30EF		10/27/2020 11:00:00 PM		012012316-0031	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/10/2020 KB	11/11/2020 KB 23:58
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
32EF		10/27/2020 11:00:00 PM		012012316-0032	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	ND	1.00 µg/L	11/10/2020 KB	11/12/2020 KB 00:02
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
21BF		10/27/2020 11:00:00 PM		012012316-0033	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	1.86	1.00 µg/L	11/10/2020 KB	11/12/2020 KB 00:03
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
22BF		10/27/2020 11:00:00 PM		012012316-0034	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	5.49	1.00 µg/L	11/10/2020 KB	11/12/2020 KB 00:05
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
24BF		10/27/2020 11:00:00 PM		012012316-0035	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	5.77	1.00 µg/L	11/10/2020 KB	11/12/2020 KB 00:06

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012012316
 CustomerID: PLTH42
 CustomerPO:
 ProjectID:

Attn: **John Polito**
Polito Home Inspections, Inc.
181 Monroe Street
Honeoye Falls, NY 14472

Phone: (585) 330-5644
 Fax:
 Received: 11/2/2020 11:45 AM

Project: Cal Mum Elementary School

Analytical Results

Client Sample Description		23BF	Collected:	10/27/2020 11:00:00 PM	Lab ID:	012012316-0036	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst		
METALS							
200.8	Lead	39.3	1.00 µg/L	11/10/2020 KB	11/12/2020	KB	00:07
Client Sample Description		26BF	Collected:	10/27/2020 11:00:00 PM	Lab ID:	012012316-0037	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst		
METALS							
200.8	Lead	4.53	1.00 µg/L	11/10/2020 KB	11/12/2020	KB	00:11
Client Sample Description		25BF	Collected:	10/27/2020 11:00:00 PM	Lab ID:	012012316-0038	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst		
METALS							
200.8	Lead	28.2	1.00 µg/L	11/10/2020 KB	11/12/2020	KB	00:12
Client Sample Description		32BF	Collected:	10/27/2020 11:00:00 PM	Lab ID:	012012316-0039	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst		
METALS							
200.8	Lead	5.36	1.00 µg/L	11/10/2020 KB	11/12/2020	KB	00:14
Client Sample Description		32BWCBF	Collected:	10/27/2020 11:00:00 PM	Lab ID:	012012316-0040	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst		
METALS							
200.8	Lead	ND	1.00 µg/L	11/10/2020 KB	11/12/2020	KB	00:15

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012012316
 CustomerID: PLTH42
 CustomerPO:
 ProjectID:

Attn: **John Polito**
Pollito Home Inspections, Inc.
181 Monroe Street
Honeoye Falls, NY 14472

Phone: (585) 330-5644
 Fax:
 Received: 11/2/2020 11:45 AM

Project: **Cal Mum Elementary School**

Analytical Results

Client Sample Description 34BF **Collected:** 10/27/2020 **Lab ID:** 012012316-0041
 11:00:00 PM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.55	1.00 µg/L	11/9/2020 KB	11/9/2020 KB 21:04

Client Sample Description 29BF **Collected:** 10/27/2020 **Lab ID:** 012012316-0042
 11:00:00 PM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.72	1.00 µg/L	11/9/2020 KB	11/9/2020 KB 21:06

Client Sample Description 40BF **Collected:** 10/27/2020 **Lab ID:** 012012316-0043
 11:00:00 PM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.01	1.00 µg/L	11/9/2020 KB	11/9/2020 KB 21:07

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012012443
 CustomerID: PLTH42
 CustomerPO:
 ProjectID:

Attn: **John Polito**
Polito Home Inspections, Inc.
181 Monroe Street
Honeoye Falls, NY 14472

Phone: (585) 330-5644
 Fax:
 Received: 11/2/2020 11:45 AM

Project: **Cal Mum Middle School/High School**

Analytical Results

Client Sample Description CONCF **Collected:** 10/27/2020 11:00:00 PM **Lab ID:** 012012443-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.11	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 12:22

Client Sample Description CONCIM **Collected:** 10/27/2020 11:00:00 PM **Lab ID:** 012012443-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 13:02

Client Sample Description CONCSPIG **Collected:** 10/27/2020 11:00:00 PM **Lab ID:** 012012443-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	16.7	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 13:03

Client Sample Description MS123FL **Collected:** 10/27/2020 11:00:00 PM **Lab ID:** 012012443-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.01	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 01:23

Client Sample Description MS123FR **Collected:** 10/27/2020 11:00:00 PM **Lab ID:** 012012443-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	6.53	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 01:24

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012012443

CustomerID: PLTH42

CustomerPO:

ProjectID:

Attn: **John Polito**
Polito Home Inspections, Inc.
181 Monroe Street
Honeoye Falls, NY 14472

Phone: (585) 330-5644
 Fax:
 Received: 11/2/2020 11:45 AM

Project: Cal Mum Middle School/High School

Analytical Results

Client Sample Description		MS121FL	Collected:	10/27/2020 11:00:00 PM	Lab ID:	012012443-0006	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst		
METALS							
200.8	Lead	4.17	1.00 µg/L	11/12/2020 KB	11/13/2020	KB	01:26
Client Sample Description		MS121FR	Collected:	10/27/2020 11:00:00 PM	Lab ID:	012012443-0007	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst		
METALS							
200.8	Lead	9.43	1.00 µg/L	11/12/2020 KB	11/13/2020	KB	01:27
Client Sample Description		MS119WCBF	Collected:	10/27/2020 11:00:00 PM	Lab ID:	012012443-0008	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst		
METALS							
200.8	Lead	ND	1.00 µg/L	11/12/2020 KB	11/13/2020	KB	01:28
Client Sample Description		MSCAFEKK	Collected:	10/27/2020 11:00:00 PM	Lab ID:	012012443-0009	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst		
METALS							
200.8	Lead	4.68	1.00 µg/L	11/12/2020 KB	11/13/2020	KB	01:29
Client Sample Description		MSCAFEF	Collected:	10/27/2020 11:00:00 PM	Lab ID:	012012443-0010	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst		
METALS							
200.8	Lead	5.22	1.00 µg/L	11/12/2020 KB	11/13/2020	KB	01:31

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012012443
 CustomerID: PLTH42
 CustomerPO:
 ProjectID:

Attn: **John Polito**
Polito Home Inspections, Inc.
181 Monroe Street
Honeoye Falls, NY 14472

Phone: (585) 330-5644
 Fax:
 Received: 11/2/2020 11:45 AM

Project: Cal Mum Middle School/High School

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
MSCAFEDSF		10/27/2020 11:00:00 PM		012012443-0011	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	14.9	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 01:32
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
MS103FC		10/27/2020 11:00:00 PM		012012443-0012	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	13.3	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 01:38
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
MS103FPHONE		10/27/2020 11:00:00 PM		012012443-0013	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	27.9	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 01:40
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
MSAUDWCBF		10/27/2020 11:00:00 PM		012012443-0014	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	2.40	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 01:41
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
MS102F		10/27/2020 11:00:00 PM		012012443-0015	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	8.63	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 01:42

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012012443

CustomerID: PLTH42

CustomerPO:

ProjectID:

Attn: **John Polito**
Polito Home Inspections, Inc.
181 Monroe Street
Honeoye Falls, NY 14472

Phone: (585) 330-5644
 Fax:
 Received: 11/2/2020 11:45 AM

Project: Cal Mum Middle School/High School

Analytical Results

Client Sample Description		MS102BF	Collected:	10/27/2020 11:00:00 PM	Lab ID:	012012443-0016	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst		
METALS							
200.8	Lead	5.80	1.00 µg/L	11/12/2020 KB	11/13/2020	KB	01:43
Client Sample Description		MS104F	Collected:	10/27/2020 11:00:00 PM	Lab ID:	012012443-0017	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst		
METALS							
200.8	Lead	5.70	1.00 µg/L	11/12/2020 KB	11/13/2020	KB	01:45
Client Sample Description		MS106WCBF	Collected:	10/27/2020 11:00:00 PM	Lab ID:	012012443-0018	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst		
METALS							
200.8	Lead	ND	1.00 µg/L	11/12/2020 KB	11/13/2020	KB	01:46
Client Sample Description		MS113F	Collected:	10/27/2020 11:00:00 PM	Lab ID:	012012443-0019	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst		
METALS							
200.8	Lead	9.62	1.00 µg/L	11/12/2020 KB	11/13/2020	KB	01:47
Client Sample Description		MS133FL	Collected:	10/27/2020 11:00:00 PM	Lab ID:	012012443-0020	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst		
METALS							
200.8	Lead	2.05	1.00 µg/L	11/12/2020 KB	11/13/2020	KB	01:48

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012012443
 CustomerID: PLTH42
 CustomerPO:
 ProjectID:

Attn: **John Polito**
Pollto Home Inspections, Inc.
181 Monroe Street
Honeoye Falls, NY 14472

Phone: (585) 330-5644
 Fax:
 Received: 11/2/2020 11:45 AM

Project: Cal Mum Middle School/High School

Analytical Results

Client Sample Description MS133FR **Collected:** 10/27/2020 11:00:00 PM **Lab ID:** 012012443-0021

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.17	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 01:56

Client Sample Description MS129F **Collected:** 10/27/2020 11:00:00 PM **Lab ID:** 012012443-0022

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 02:00

Client Sample Description MS141WCBF **Collected:** 10/27/2020 11:00:00 PM **Lab ID:** 012012443-0023

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 02:01

Client Sample Description MSIM **Collected:** 10/27/2020 11:00:00 PM **Lab ID:** 012012443-0024

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.20	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 02:02

Client Sample Description H147FRTF **Collected:** 10/27/2020 11:00:00 PM **Lab ID:** 012012443-0025

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	12.8	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 02:03

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012012443

CustomerID: PLTH42

CustomerPO:

ProjectID:

Attn: **John Polito**
Polito Home Inspections, Inc.
181 Monroe Street
Honeoye Falls, NY 14472

Phone: (585) 330-5644
 Fax:
 Received: 11/2/2020 11:45 AM

Project: Cal Mum Middle School/High School

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
H147F1		10/27/2020 11:00:00 PM	012012443-0026		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	2.58	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 02:05
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
H147F2		10/27/2020 11:00:00 PM	012012443-0027		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	24.0	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 02:09
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
H147F3		10/27/2020 11:00:00 PM	012012443-0028		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	2.57	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 02:10
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
H147F4		10/27/2020 11:00:00 PM	012012443-0029		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	5.25	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 02:11
<i>Client Sample Description</i>		<i>Collected:</i>	<i>Lab ID:</i>		
H147FREAR		10/27/2020 11:00:00 PM	012012443-0030		
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	2.80	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 02:12

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012012443
 CustomerID: PLTH42
 CustomerPO:
 ProjectID:

Attn: **John Polito**
Polito Home Inspections, Inc.
181 Monroe Street
Honeoye Falls, NY 14472

Phone: (585) 330-5644
 Fax:
 Received: 11/2/2020 11:45 AM

Project: Cal Mum Middle School/High School

Analytical Results

Client Sample Description H149FNR **Collected:** 10/27/2020 11:00:00 PM **Lab ID:** 012012443-0031

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	4.32	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 02:14

Client Sample Description H149FNL **Collected:** 10/27/2020 11:00:00 PM **Lab ID:** 012012443-0032

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	15.7	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 02:17

Client Sample Description H149FE **Collected:** 10/27/2020 11:00:00 PM **Lab ID:** 012012443-0033

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	9.19	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 02:19

Client Sample Description H126FL **Collected:** 10/27/2020 11:00:00 PM **Lab ID:** 012012443-0034

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	56.9	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 02:20

Client Sample Description H124FNL **Collected:** 10/27/2020 11:00:00 PM **Lab ID:** 012012443-0035

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.99	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 02:26

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> Env.Chemistry2@emsl.com

EMSL Order: 012012443
 CustomerID: PLTH42
 CustomerPO:
 ProjectID:

Attn: **John Polito**
Pollito Home Inspections, Inc.
181 Monroe Street
Honeoye Falls, NY 14472

Phone: (585) 330-5644
 Fax:
 Received: 11/2/2020 11:45 AM

Project: Cal Mum Middle School/High School

Analytical Results

Client Sample Description H124FNR		Collected: 10/27/2020 11:00:00 PM		Lab ID: 012012443-0036	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.11	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 02:28

Client Sample Description H124FE		Collected: 10/27/2020 11:00:00 PM		Lab ID: 012012443-0037	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.98	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 02:29

Client Sample Description HMAINOF		Collected: 10/27/2020 11:00:00 PM		Lab ID: 012012443-0038	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 02:30

Client Sample Description H120F		Collected: 10/27/2020 11:00:00 PM		Lab ID: 012012443-0039	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.47	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 02:31

Client Sample Description H120WCBF		Collected: 10/27/2020 11:00:00 PM		Lab ID: 012012443-0040	
Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 02:33

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012012443
 CustomerID: PLTH42
 CustomerPO:
 ProjectID:

Attn: **John Polito**
Polito Home Inspections, Inc.
181 Monroe Street
Honeoye Falls, NY 14472

Phone: (585) 330-5644
 Fax:
 Received: 11/2/2020 11:45 AM

Project: Cal Mum Middle School/High School

Analytical Results

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
H110FL		10/27/2020 11:00:00 PM		012012443-0041	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	2.89	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 04:03
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
H110FR		10/27/2020 11:00:00 PM		012012443-0042	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	2.82	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 04:10
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
H201FN		10/27/2020 11:00:00 PM		012012443-0043	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	15.5	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 04:11
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
H201FEL		10/27/2020 11:00:00 PM		012012443-0044	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	14.3	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 04:12
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>	
H201FER		10/27/2020 11:00:00 PM		012012443-0045	
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL Units</i>	<i>Prep Date & Analyst</i>	<i>Analysis Date & Analyst</i>
METALS					
200.8	Lead	7.27	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 04:14

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012012443
 CustomerID: PLTH42
 CustomerPO:
 ProjectID:

Attn: **John Polito**
Pollito Home Inspections, Inc.
181 Monroe Street
Honeoye Falls, NY 14472

Phone: (585) 330-5644
 Fax:
 Received: 11/2/2020 11:45 AM

Project: Cal Mum Middle School/High School

Analytical Results

Client Sample Description H201FS **Collected:** 10/27/2020 11:00:00 PM **Lab ID:** 012012443-0046

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	3.30	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 04:15

Client Sample Description H208WCBF **Collected:** 10/27/2020 11:00:00 PM **Lab ID:** 012012443-0047

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 04:16

Client Sample Description H225FTEACHERS **Collected:** 10/27/2020 11:00:00 PM **Lab ID:** 012012443-0048

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	7.81	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 04:17

Client Sample Description MS227F **Collected:** 10/27/2020 11:00:00 PM **Lab ID:** 012012443-0049

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	5.83	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 04:19

Client Sample Description H216WCBF **Collected:** 10/27/2020 11:00:00 PM **Lab ID:** 012012443-0050

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	11/16/2020 KB	11/16/2020 KB 16:43

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012012443
 CustomerID: PLTH42
 CustomerPO:
 ProjectID:

Attn: **John Polito**
Polito Home Inspections, Inc.
181 Monroe Street
Honeoye Falls, NY 14472

Phone: (585) 330-5644
 Fax:
 Received: 11/2/2020 11:45 AM

Project: Cal Mum Middle School/High School

Analytical Results

Client Sample Description MS133FM **Collected:** 10/27/2020 **Lab ID:** 012012443-0051
 11:00:00 PM

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	1.89	1.00 µg/L	11/12/2020 KB	11/13/2020 KB 04:20

Definitions:

- MDL - method detection limit
- J - Result was below the reporting limit, but at or above the MDL
- ND - indicates that the analyte was not detected at the reporting limit
- RL - Reporting Limit (Analytical)
- D - Dilution Sample required a dilution which was used to calculate final results