

**Public Notification to Parents, Teachers, and Staff
Participation in School Drinking Water Quality Reimbursement Program**

School/District Name: Abbott Elementary School, Ann Arbor Public Schools

Date: 8/25/17

This School/District is committed to protecting the health of students, teachers, and staff. We are participating in the School Drinking Water Quality Reimbursement Program, which is a program jointly administered by the Michigan Department of Education and Department of Environmental Quality. This program is designed to provide school funding for costs associated with the mitigation of potential lead exposure from drinking water. Up to \$950 per school building is available on a reimbursement basis for the cost of testing for lead in drinking water, fixture replacement, filter purchases, plumbing assessments, or technical assistance incurred between July 1, 2016, and September 30, 2017.

The School Drinking Water Quality Reimbursement Program requires that schools submit proof of public notification of the number of fixtures providing water for drinking or food preparation, testing results, number of fixtures replaced, and other corrective action plans prior to reimbursement. This information is as follows:

Number of fixtures providing water for drinking or food preparation: 12

Number of fixtures replaced: (zero if not applicable) 0

Number of filters purchased: (zero if not applicable) 0

Other Actions Taken: (if applicable) _____

Testing Results:

Number of Lead Tests Completed: (zero if not applicable) 12

Number of Lead Tests with Over 5 parts per billion of Lead: (zero if not applicable) 1

Based upon actions taken to date:

The District/School has determined that additional corrective action is not necessary.

The District/School will be taking the following additional corrective action: _____

About Lead:

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life.

How Can I Learn More?

You can see a copy of all water testing results at the school district's central office, and on our website at (<https://www.a2schools.org>). For more information about water quality in our schools, please contact (Physical Properties) at (734-994-8118). For information about water quality and sampling for lead at home, contact your local water supplier or the Michigan DEQ (www.michigan.gov/drinkingwater).

This Public Notification is being distributed through the following means: Posting in Common Areas of School Buildings; E-mail or Letter to Parents, Teachers and Staff; Posting on Website; Newsletter.

Signed and Certified



Name and Title

Marios Demetriou
Assistant Superintendent,
Finance & Operations



Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE170567

Abbot Elementary School							
Date of Sampling: July 25, 2017							
Sampler: Amanda Peterson							
Sample #	Location	Type ¹	Time Collected	Lead EPA Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	Notes
Abbot ES-01	Across from Teachers Lounge, Water Cooler	8:15 AM	WC	15	2	N	First Draw
Abbot ES-02	Teachers Lounge, Kitchen Sink	8:17 AM	KS	15	2	Y	First Draw
Abbot ES-03	Floor Prep Room, Left Faucet	8:20 AM	KS	15	3	Y	First Draw
Abbot ES-04	Food Prep Room, 3-Compartment Sink, Left Sprayer	8:25 AM	KS	15	3	N	First Draw
Abbot ES-05	Food Prep Room, 3-Compartment Sink, Right Faucet	8:28 AM	KS	15	8	Y	First Draw
Abbot ES-06	Childcare Room, Left Faucet	8:30 AM	CF	15	2	Y	First Draw
Abbot ES-07	Childcare Room, Right Bubbler	8:35 AM	B	15	2	N	First Draw
Abbot ES-08	Room D-2, Bubbler	8:40 AM	B	15	3	N	First Draw
Abbot ES-09	Room D-3, Bubbler	8:42 AM	B	15	4	N	First Draw
Abbot ES-10	Room D-4, Bubbler	8:45 AM	B	15	3	N	First Draw
Abbot ES-11	Room D-5, Bubbler	8:50 AM	B	15	3	N	First Draw
Abbot ES-12	Next to Room C-8, Right Bubbler	8:55 AM	B	15	2	N	First Draw

¹ Type: B = Bubbler, BT = Bottle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, FS = Floor Sink
² <https://www.mdeq.com/your-drinking-water/public-regulation/drinking-water-standards>
³ ND = None Detected at Reported Detection Limit of 1 ug/L
⁴ NT = Not Tested

**Public Notification to Parents, Teachers, and Staff
Participation in School Drinking Water Quality Reimbursement Program**

School/District Name: Administration Building, Ann Arbor Public Schools

Date: 8/25/17

This School/District is committed to protecting the health of students, teachers, and staff. We are participating in the School Drinking Water Quality Reimbursement Program, which is a program jointly administered by the Michigan Department of Education and Department of Environmental Quality. This program is designed to provide school funding for costs associated with the mitigation of potential lead exposure from drinking water. Up to \$950 per school building is available on a reimbursement basis for the cost of testing for lead in drinking water, fixture replacement, filter purchases, plumbing assessments, or technical assistance incurred between July 1, 2016, and September 30, 2017.

The School Drinking Water Quality Reimbursement Program requires that schools submit proof of public notification of the number of fixtures providing water for drinking or food preparation, testing results, number of fixtures replaced, and other corrective action plans prior to reimbursement. This information is as follows:

Number of fixtures providing water for drinking or food preparation: 4

Number of fixtures replaced: (zero if not applicable) 0

Number of filters purchased: (zero if not applicable) 0

Other Actions Taken: (if applicable) _____

Testing Results:

Number of Lead Tests Completed: (zero if not applicable) 4

Number of Lead Tests with Over 5 parts per billion of Lead: (zero if not applicable) 0

Based upon actions taken to date:

The District/School has determined that additional corrective action is not necessary.

The District/School will be taking the following additional corrective action: _____

About Lead:

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life.

How Can I Learn More?

You can see a copy of all water testing results at the school district's central office, and on our website at (<https://www.a2schools.org>). For more information about water quality in our schools, please contact (Physical Properties) at (734-994-8118). For information about water quality and sampling for lead at home, contact your local water supplier or the Michigan DEQ (www.michigan.gov/drinkingwater).

This Public Notification is being distributed through the following means: Posting in Common Areas of School Buildings; E-mail or Letter to Parents, Teachers and Staff; Posting on Website; Newsletter.

Signed and Certified



Name and Title

Marios Demetriou
Assistant Superintendent,
Finance & Operations



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE170567

Balas Administration Building							
Date of Sampling: 8/3/17							
Sampler: Andrew Kelly							
Sample #	Location	Type ¹	Time Collected	Lead EPA Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	Notes
Admin-01	Staff Lounge Sink	KS	1:00 PM	15	ND ³	Y	First Draw
Admin-02	Hallway Left of Men's Restroom Near Payroll/Accounting, Water Cooler	WC	1:05 PM	15	1	N	First Draw
Admin-03	Lower Level Hallway Outside Men's Restroom, Bubbler	B	1:07 PM	15	ND	N	First Draw
Admin-04	Loading Dock at End of Bay Divider Wall, Water Cooler	WC	1:10 PM	15	ND	N	First Draw

1) Type: B = Bubbler, BT = Bottle Filling, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, FS = First Draw Sink
 2) <https://www.epa.gov/your-drinking-water/in-the-regions-of-drinking-water-epha-removal>
 3) ND = Non Detected at Report Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE170567**

Allen Elementary School
Date of Sampling: 8/29/17
Sampler: Ben Mark

Sample #	Location	Type ¹	Time Collected	Lead EPA Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	Notes
Allen ES-01	Staff Lounge Sink	CF	10:33 AM	15	2	Y	First Draw
Allen ES-02	Room K-3, Bubbler	B	10:42 AM	15	3	N	First Draw
Allen ES-03	Room CC8, Bubbler	B	10:50 AM	15	5	Y	First Draw
Allen ES-04	Room C-10, Sink	CF	10:55 AM	15	3	Y	First Draw
Allen ES-05	Hallway Water Cooler Outside of Computer Lab and Room Flex-A	WC	11:07 AM	15	ND ³	Y	First Draw
Allen ES-06	Room A-14, Sink	CF	11:13 AM	15	3	Y	First Draw
Allen ES-07	Room A-17, Bubbler	B	11:17 AM	15	3	Y	First Draw
Allen ES-08	Room A-18, Bubbler	B	11:22 AM	15	8	Y	First Draw
Allen ES-09	Room A-20, Sink	CF	11:27 AM	15	3	Y	First Draw
Allen ES-10	Hallway Water Cooler Outside Womens Bathroom Near Art Room	WC	11:45 AM	15	ND	N	First Draw
Allen ES-11	Room B-22, Bubbler	B	11:52 AM	15	ND	Y	First Draw
Allen ES-12	Kitchen/Food Service, Right Hand Faucet, 3-Compartment Sink	KS	11:57 AM	15	4	Y	First Draw

1) Type: B = Bubbler, BT = Bottle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

**Public Notification to Parents, Teachers, and Staff
Participation in School Drinking Water Quality Reimbursement Program**

School/District Name: Angell Elementary School, Ann Arbor Public Schools

Date: 8/25/17

This School/District is committed to protecting the health of students, teachers, and staff. We are participating in the School Drinking Water Quality Reimbursement Program, which is a program jointly administered by the Michigan Department of Education and Department of Environmental Quality. This program is designed to provide school funding for costs associated with the mitigation of potential lead exposure from drinking water. Up to \$950 per school building is available on a reimbursement basis for the cost of testing for lead in drinking water, fixture replacement, filter purchases, plumbing assessments, or technical assistance incurred between July 1, 2016, and September 30, 2017.

The School Drinking Water Quality Reimbursement Program requires that schools submit proof of public notification of the number of fixtures providing water for drinking or food preparation, testing results, number of fixtures replaced, and other corrective action plans prior to reimbursement. This information is as follows:

Number of fixtures providing water for drinking or food preparation: 12

Number of fixtures replaced: (zero if not applicable) 1

Number of filters purchased: (zero if not applicable) 0

Other Actions Taken: (if applicable) Follow up testing performed

Testing Results:

Number of Lead Tests Completed: (zero if not applicable) 16

Number of Lead Tests with Over 5 parts per billion of Lead: (zero if not applicable) 3

Based upon actions taken to date:

The District/School has determined that additional corrective action is not necessary.

The District/School will be taking the following additional corrective action: Replaced 1 room faucet.
Retest location after replacement.

About Lead:


Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life.

How Can I Learn More?

You can see a copy of all water testing results at the school district's central office, and on our website at (<https://www.a2schools.org>). For more information about water quality in our schools, please contact (Physical Properties) at (734-994-8118). For information about water quality and sampling for lead at home, contact your local water supplier or the Michigan DEQ (www.michigan.gov/drinkingwater).

This Public Notification is being distributed through the following means: () Posting in Common Areas of School Buildings; () E-mail or Letter to Parents, Teachers and Staff; (X) Posting on Website; () Newsletter.

Signed and Certified



Name and Title

Marios Demetriou
Assistant Superintendent,
Finance & Operations



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE170567

Angell Elementary School							
Date of Sampling: July 27, 2017							
Sampler: Andrew Kelly							
Sample #	Location	Type ¹	Time Collected	Lead EPA Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	Notes
Angell-01	Room 108, Faucet	CF	9:05 AM	15	37	Y	First Draw
Angell-02	Room 147, Bubblers	B	9:08 AM	15	1	N	First Draw
Angell-03	Clinic Faucet, Main Office	NS	9:11 AM	15	10	Y	First Draw, Corrosion on Aerator
Angell-04	In Hallway, Outside Main Office	WC	9:14 AM	15	ND ³	N	First Draw
Angell-05	Principals Office	BF	9:16 AM	15	3	Y	First Draw, Corrosion on Aerator
Angell-06	Room 123, Bubblers	B	9:18 AM	15	11	N	First Draw
Angell-07	Room 119, Bubblers	B	9:27 AM	15	ND	N	First Draw
Angell-08	Room 221, Bubblers	B	9:36 AM	15	ND	N	First Draw, Corrosion on Aerator
Angell-09	Room 217, Bubblers	B	9:39 AM	15	ND	N	First Draw, Corrosion on Aerator
Angell-10	Room 207, Bubblers	B	9:45 AM	15	18	N	First Draw
Angell-11	Room 212, Bubblers	B	9:51 AM	15	2	N	First Draw
Angell-12	Room 101, Bubblers	B	9:54 AM	15	3	N	First Draw

Angell Elementary School							
Date of Sampling: August 15, 2017							
Sampler: Andrew Kelly							
Sample #	Location	Type ¹	Time Collected	Lead EPA Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	Notes
Angell-01A	Room 108, Faucet	CF	1:32 PM	15	3	Y	Follow-up Flush
Angell-10A	Room 207, Bubblers	B	1:35 PM	15	ND	N	Follow-up Flush

1) Type: B = Bubblers, BT = Bottle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE170567

Angell Elementary School							
Date of Sampling: August 16, 2017							
Sampler: Amanda Peterson							
Sample #	Location	Type ¹	Time Collected	Lead EPA Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	Notes
Angell-01B	Room 108, Faucet	CF	8:26 AM	15	42	Y	Repeat First Draw
Angell-10B	Room 207, Bubbler	B	8:28 AM	15	2	N	Repeat First Draw

1) Type: B = Bubbler, BT = Bottle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

**Public Notification to Parents, Teachers, and Staff
Participation in School Drinking Water Quality Reimbursement Program**

School/District Name: Ann Arbor Open at Mack School, Ann Arbor Public Schools

Date: 8/30/17

This School/District is committed to protecting the health of students, teachers, and staff. We are participating in the School Drinking Water Quality Reimbursement Program, which is a program jointly administered by the Michigan Department of Education and Department of Environmental Quality. This program is designed to provide school funding for costs associated with the mitigation of potential lead exposure from drinking water. Up to \$950 per school building is available on a reimbursement basis for the cost of testing for lead in drinking water, fixture replacement, filter purchases, plumbing assessments, or technical assistance incurred between July 1, 2016, and September 30, 2017.

The School Drinking Water Quality Reimbursement Program requires that schools submit proof of public notification of the number of fixtures providing water for drinking or food preparation, testing results, number of fixtures replaced, and other corrective action plans prior to reimbursement. This information is as follows:

Number of fixtures providing water for drinking or food preparation: 12

Number of fixtures replaced: (zero if not applicable) 0

Number of filters purchased: (zero if not applicable) 0

Other Actions Taken: (if applicable) _____

Testing Results:

Number of Lead Tests Completed: (zero if not applicable) 12

Number of Lead Tests with Over 5 parts per billion of Lead: (zero if not applicable) 2

Based upon actions taken to date:

The District/School has determined that additional corrective action is not necessary.

The District/School will be taking the following additional corrective action: _____

About Lead:

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life.

How Can I Learn More?

You can see a copy of all water testing results at the school district's central office, and on our website at (<https://www.a2schools.org>). For more information about water quality in our schools, please contact (Physical Properties) at (734-994-8118). For information about water quality and sampling for lead at home, contact your local water supplier or the Michigan DEQ (www.michigan.gov/drinkingwater).

This Public Notification is being distributed through the following means: Posting in Common Areas of School Buildings; E-mail or Letter to Parents, Teachers and Staff; Posting on Website; Newsletter.

Signed and Certified



Name and Title

Marios Demetriou
Assistant Superintendent,
Finance & Operations



Allen Park Public Schools
 Drinking Water Analysis
 Project Number: AE170567

Ann Arbor Open at Mack School							
Date of Sampling: July 26, 2017							
Sampler: Amanda Peterson							
Sample #	Location	Type ¹	Time Collected	Lead EPA Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	Notes
A2SOM - 01	Bubbler, in Hallway to the Right of Room 209	B	7:45 AM	15	ND ³	N	First Draw
A2SOM - 02	Water Cooler in Room 205	WC	7:49 AM	15	ND	N	First Draw
A2SOM - 03	Water Cooler in Hallway to the Left of Dining Room 202	WC	7:53 AM	15	ND	N	First Draw
A2SOM - 04	Bubbler in Hallway to the Right of Boiler Room	B	7:56 AM	15	4	N	First Draw
A2SOM - 05	Bubbler Inside Gym Entrance Door by Men's Locker Room	B	8:03 AM	15	9	N	First Draw
A2SOM - 06	Kitchen 3-Compartment Sink, Left Faucet	KS	8:06 AM	15	2	Y	First Draw
A2SOM - 07	Kitchen 3-Compartment Sink, Right Faucet	KS	8:07 AM	15	3	Y	First Draw
A2SOM - 08	Room 261, Left Classroom Faucet	CF	8:12 AM	15	7	Y	First Draw
A2SOM - 09	Room 261, Right Bubbler	B	8:13 AM	15	2	N	First Draw
A2SOM - 10	2nd Floor Bubbler in Hallway Right of Room 311	B	8:18 AM	15	1	N	First Draw
A2SOM - 11	2nd Floor Bubbler in Hallway Left of Room 311	B	8:20 AM	15	2	N	First Draw
A2SOM - 12	2nd Floor Room 315 2-Compartment Sink	KS	8:25 AM	15	5	Y	First Draw

1) Type: B = Bubbler, BT = Bottle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/is-be-regulated-drinking-water-contaminant>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

**Public Notification to Parents, Teachers, and Staff
Participation in School Drinking Water Quality Reimbursement Program**

School/District Name: Bach Elementary School, Ann Arbor Public Schools

Date: 8/25/17

This School/District is committed to protecting the health of students, teachers, and staff. We are participating in the School Drinking Water Quality Reimbursement Program, which is a program jointly administered by the Michigan Department of Education and Department of Environmental Quality. This program is designed to provide school funding for costs associated with the mitigation of potential lead exposure from drinking water. Up to \$950 per school building is available on a reimbursement basis for the cost of testing for lead in drinking water, fixture replacement, filter purchases, plumbing assessments, or technical assistance incurred between July 1, 2016, and September 30, 2017.

The School Drinking Water Quality Reimbursement Program requires that schools submit proof of public notification of the number of fixtures providing water for drinking or food preparation, testing results, number of fixtures replaced, and other corrective action plans prior to reimbursement. This information is as follows:

Number of fixtures providing water for drinking or food preparation: 12

Number of fixtures replaced: (zero if not applicable) 0

Number of filters purchased: (zero if not applicable) 0

Other Actions Taken: (if applicable) _____

Testing Results:

Number of Lead Tests Completed: (zero if not applicable) 12

Number of Lead Tests with Over 5 parts per billion of Lead: (zero if not applicable) 0

Based upon actions taken to date:

The District/School has determined that additional corrective action is not necessary.

The District/School will be taking the following additional corrective action: _____

About Lead:


Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life.

How Can I Learn More?

You can see a copy of all water testing results at the school district's central office, and on our website at (<https://www.a2schools.org>). For more information about water quality in our schools, please contact (Physical Properties) at (734-994-8118). For information about water quality and sampling for lead at home, contact your local water supplier or the Michigan DEQ (www.michigan.gov/drinkingwater).

This Public Notification is being distributed through the following means: Posting in Common Areas of School Buildings; E-mail or Letter to Parents, Teachers and Staff; Posting on Website; Newsletter.

Signed and Certified



Name and Title

Marios Demetriou
Assistant Superintendent,
Finance & Operations



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE170567

Bach Elementary School							
Date of Sampling: July 27, 2017							
Sampler: Andrew Kelly							
Sample #	Location	Type ¹	Time Collected	Lead EPA Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	Notes
Bach ES-01	Room 202, Bubblers	10:22 AM	B	15	ND ³	N	First Draw
Bach ES-02	Staff Lounge	10:26 AM	KS	15	15	Y	First Draw
Bach ES-03	Room A-24, Bubblers	10:30 AM	B	15	ND	N	First Draw
Bach ES-04	Room A-25, Bubblers	10:32 AM	B	15	ND	N	First Draw
Bach ES-05	Room A-26, Bubblers	10:33 AM	B	15	ND	N	First Draw
Bach ES-06	Room A-29, Bubblers	10:33 AM	B	15	ND	N	First Draw
Bach ES-07	Room 19, Bubblers	10:40 AM	B	15	3	N	First Draw
Bach ES-08	Room 20, Bubblers	10:42 AM	B	15	2	N	First Draw
Bach ES-09	Room 18, Bubblers	10:44 AM	B	15	ND	N	First Draw
Bach ES-10	Room 16, Bubblers	10:46 AM	B	15	ND	N	First Draw
Bach ES-11	In Hallway Outside Room 104	10:48 AM	B	15	ND	N	First Draw
Bach ES-12	In Hallway Outside Room 306	10:55 AM	WC	15	ND	N	First Draw

1) Type: B = Bubblers, BF = Bottle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

**Public Notification to Parents, Teachers, and Staff
Participation in School Drinking Water Quality Reimbursement Program**

School/District Name: Bryant Elementary, Ann Arbor Public Schools

Date: 8/30/17

This School/District is committed to protecting the health of students, teachers, and staff. We are participating in the School Drinking Water Quality Reimbursement Program, which is a program jointly administered by the Michigan Department of Education and Department of Environmental Quality. This program is designed to provide school funding for costs associated with the mitigation of potential lead exposure from drinking water. Up to \$950 per school building is available on a reimbursement basis for the cost of testing for lead in drinking water, fixture replacement, filter purchases, plumbing assessments, or technical assistance incurred between July 1, 2016, and September 30, 2017.

The School Drinking Water Quality Reimbursement Program requires that schools submit proof of public notification of the number of fixtures providing water for drinking or food preparation, testing results, number of fixtures replaced, and other corrective action plans prior to reimbursement. This information is as follows:

Number of fixtures providing water for drinking or food preparation: 12

Number of fixtures replaced: (zero if not applicable) 0

Number of filters purchased: (zero if not applicable) 0

Other Actions Taken: (if applicable) _____

Testing Results:

Number of Lead Tests Completed: (zero if not applicable) 12

Number of Lead Tests with Over 5 parts per billion of Lead: (zero if not applicable) 0

Based upon actions taken to date:

The District/School has determined that additional corrective action is not necessary.

The District/School will be taking the following additional corrective action: _____

About Lead:


Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life.

How Can I Learn More?

You can see a copy of all water testing results at the school district's central office, and on our website at (<https://www.a2schools.org>). For more information about water quality in our schools, please contact (Physical Properties) at (734-994-8118). For information about water quality and sampling for lead at home, contact your local water supplier or the Michigan DEQ (www.michigan.gov/drinkingwater).

This Public Notification is being distributed through the following means: Posting in Common Areas of School Buildings; E-mail or Letter to Parents, Teachers and Staff; Posting on Website; Newsletter.

Signed and Certified



Name and Title

Marios Demetriou
Assistant Superintendent,
Finance & Operations



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE170567

Bryant Elementary School							
Date of Sampling: 8/1/2017							
Sampler: Andrew Kelly							
Sample #	Location	Type ¹	Time Collected	Lead EPA Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	Notes
Bryant-01	Hallway Outside Main Office, Left Water Cooler	WC	8:24 AM	15	ND ³	N	First Draw
Bryant-02	Teachers Lounge Sink	KS	8:25 AM	15	2	Y	First Draw
Bryant-03	Clinic Bathroom Sink	BF	8:29 AM	15	4	Y	First Draw
Bryant-04	Kitchen 3-Compartment Left Faucet	KS	8:33 AM	15	2	Y	First Draw
Bryant-05	Room 200 Bubbler	B	8:36 AM	15	4	N	First Draw
Bryant-06	Hallway Outside Room 203, Right Water Cooler	WC	8:39 AM	15	ND	N	First Draw
Bryant-07	Between Room 203 & 204, Bubbler	B	8:44 AM	15	3	N	First Draw
Bryant-08	Room 206 Bubbler	B	8:46 AM	15	1	N	First Draw
Bryant-09	Between Room 210 & 211, Bubbler	B	8:49 AM	15	ND	N	First Draw
Bryant-10	Room 212 Bubbler	B	8:53 AM	15	3	N	First Draw
Bryant-11	Room 215 Bubbler	B	8:55 AM	15	2	N	First Draw
Bryant-12	Hallway Outside Exit Door 5 by Girls Bathroom, Right Water Cooler	WC	9:03 AM	15	ND	N	First Draw

1) Type: B = Bubbler, BF = Bathroom Sink, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, ND = Not to Test
 2) Notes: <http://www.aasps.gov/psur-drinking-water/whats-new/guidelines-for-drinking-water-test-numbers>
 3) ND = Not Detected at Report or Detection Limit of 1 ug/L
 4) NT = Not Tested

**Public Notification to Parents, Teachers, and Staff
Participation in School Drinking Water Quality Reimbursement Program**

School/District Name: Burns Park School, Ann Arbor Public Schools

Date: 8/30/17

This School/District is committed to protecting the health of students, teachers, and staff. We are participating in the School Drinking Water Quality Reimbursement Program, which is a program jointly administered by the Michigan Department of Education and Department of Environmental Quality. This program is designed to provide school funding for costs associated with the mitigation of potential lead exposure from drinking water. Up to \$950 per school building is available on a reimbursement basis for the cost of testing for lead in drinking water, fixture replacement, filter purchases, plumbing assessments, or technical assistance incurred between July 1, 2016, and September 30, 2017.

The School Drinking Water Quality Reimbursement Program requires that schools submit proof of public notification of the number of fixtures providing water for drinking or food preparation, testing results, number of fixtures replaced, and other corrective action plans prior to reimbursement. This information is as follows:

Number of fixtures providing water for drinking or food preparation: 12

Number of fixtures replaced: (zero if not applicable) 0

Number of filters purchased: (zero if not applicable) 0

Other Actions Taken: (if applicable) Follow up sampling performed

Testing Results:

Number of Lead Tests Completed: (zero if not applicable) 14

Number of Lead Tests with Over 5 parts per billion of Lead: (zero if not applicable) 2

Based upon actions taken to date:

The District/School has determined that additional corrective action is not necessary.

The District/School will be taking the following additional corrective action: _____

About Lead:


Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life.

How Can I Learn More?

You can see a copy of all water testing results at the school district's central office, and on our website at (<https://www.a2schools.org>). For more information about water quality in our schools, please contact (Physical Properties) at (734-994-8118). For information about water quality and sampling for lead at home, contact your local water supplier or the Michigan DEQ (www.michigan.gov/drinkingwater).

This Public Notification is being distributed through the following means: Posting in Common Areas of School Buildings; E-mail or Letter to Parents, Teachers and Staff; Posting on Website; Newsletter.

Signed and Certified



Name and Title

Marios Demetriou
Assistant Superintendent,
Finance & Operations



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE170567

Burns Park Elementary School

Date of Sampling: July 27th, 2017

Sampler: Andrew Kelly

Sample #	Location	Type ¹	Time Collected	EPA Action Level (ug/L) ²	Results (ug/L)	Aerator Present Y/N	Notes
Burns-01	Room 110, Bubblers	B	12:40 PM	15	2	N	First Draw
Burns-02	In Hallway, Outside Room 102, Water Cooler	WC	12:43 PM	15	ND ³	N	First Draw
Burns-03	In Hallway, Outside Room 109, Bottle Fill	BT	12:46 PM	15	ND	Y	First Draw
Burns-04	Room 213, Bubblers	B	12:51 PM	15	6	N	First Draw
Burns-05	In Hallway, Outside Media Center, Water Cooler	WC	12:53 PM	15	ND	N	First Draw
Burns-06	In Hallway, Outside Room 312, Water Cooler	WC	12:57 PM	15	ND	N	First Draw
Burns-07	Room 304, Faucet	CF	1:01 PM	15	320	N	First Draw, Low Flow, Brown Color
Burns-08	Room 302, Faucet	CF	1:03 PM	15	4	Y	First Draw
Burns-09	Room 103, Bubblers	B	1:10 PM	15	15	N	First Draw
Burns-10	In Hallway, Outside Room 109, Water Cooler	WC	1:11 PM	15	ND	N	First Draw
Burns-11	Room A-6, Bubblers	B	1:15 PM	15	2	N	First Draw
Burns-12	Room A-7, Bubblers	B	1:16 PM	15	ND	N	First Draw

Burns Park Elementary School

Date of Sampling: August 15th, 2017

Sampler: Andrew Kelly

Sample #	Location	Type ¹	Time Collected	EPA Action Level (ug/L) ²	Results (ug/L)	Aerator Present Y/N	Notes
Burns-07A	Room 304, Faucet	CF	2:13 PM	15	10	N	Follow-up Flush

Burns Park Elementary School

Date of Sampling: August 16th, 2017

Sampler: Amanda Peterson

Sample #	Location	Type ¹	Time Collected	EPA Action Level (ug/L) ²	Results (ug/L)	Aerator Present Y/N	Notes
Burns-07 B	Room 304, Faucet	CF	8:01 AM	15	5	N	Repeat First Draw

1) Type: B = Bubblers, BT = Bottle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

**Public Notification to Parents, Teachers, and Staff
Participation in School Drinking Water Quality Reimbursement Program**

School/District Name: Carpenter Elementary, Ann Arbor Public Schools

Date: 8/30/17

This School/District is committed to protecting the health of students, teachers, and staff. We are participating in the School Drinking Water Quality Reimbursement Program, which is a program jointly administered by the Michigan Department of Education and Department of Environmental Quality. This program is designed to provide school funding for costs associated with the mitigation of potential lead exposure from drinking water. Up to \$950 per school building is available on a reimbursement basis for the cost of testing for lead in drinking water, fixture replacement, filter purchases, plumbing assessments, or technical assistance incurred between July 1, 2016, and September 30, 2017.

The School Drinking Water Quality Reimbursement Program requires that schools submit proof of public notification of the number of fixtures providing water for drinking or food preparation, testing results, number of fixtures replaced, and other corrective action plans prior to reimbursement. This information is as follows:

Number of fixtures providing water for drinking or food preparation: 12

Number of fixtures replaced: (zero if not applicable) 0

Number of filters purchased: (zero if not applicable) 0

Other Actions Taken: (if applicable) _____

Testing Results:

Number of Lead Tests Completed: (zero if not applicable) 12

Number of Lead Tests with Over 5 parts per billion of Lead: (zero if not applicable) 0

Based upon actions taken to date:

The District/School has determined that additional corrective action is not necessary.

The District/School will be taking the following additional corrective action: _____

About Lead:


Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life.

How Can I Learn More?

You can see a copy of all water testing results at the school district's central office, and on our website at (<https://www.a2schools.org>). For more information about water quality in our schools, please contact (Physical Properties) at (734-994-8118). For information about water quality and sampling for lead at home, contact your local water supplier or the Michigan DEQ (www.michigan.gov/drinkingwater).

This Public Notification is being distributed through the following means: Posting in Common Areas of School Buildings; E-mail or Letter to Parents, Teachers and Staff; Posting on Website; Newsletter.

Signed and Certified



Name and Title

Marios Demetriou
Assistant Superintendent,
Finance & Operations



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE170567

Carpenter Elementary School							
Date of Sampling: 8/1/2017							
Sampler: Andrew Kelly							
Sample #	Location	Type ¹	Time Collected	Lead EPA Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	Notes
Carpenter-01	Outside Main Entrance Bubblers	B	1:10 PM	15	ND ³	N	First Draw
Carpenter-02	Room 136 Bubblers	B	1:13 PM	15	ND	N	First Draw
Carpenter-03	Room 137 Bubblers	B	1:15 PM	15	ND	N	First Draw
Carpenter-04	Room 140 Bubblers	B	1:17 PM	15	ND	N	First Draw
Carpenter-05	Room 141 Bubblers	B	1:19 PM	15	ND	N	First Draw
Carpenter-06	Main Office Clinic Sink	NS	1:23 PM	15	ND	N	First Draw
Carpenter-07	Main Office Staff Lounge Sink	KS	1:25 PM	15	ND	Y	First Draw
Carpenter-08	Room 112 Bubblers	B	1:27 PM	15	ND	N	First Draw
Carpenter-09	Hallway Outside Room 119 Water Cooler	WC	1:29 PM	15	ND	N	First Draw
Carpenter-10	Room 120 Bubblers	B	1:33 PM	15	4	N	First Draw
Carpenter-11	Room 122 Bubblers	B	1:37 PM	15	2	N	First Draw
Carpenter-12	Room 123 Bubblers	B	1:41 PM	15	2	N	First Draw

1) Type: B = Bubblers, BT = Bottle Filled, WC = Water Cooler, CF = Classroom Fountain, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/understanding-of-drinking-water-quality-standards>
 3) ND = None Detected at Report of Detection level of 1 ug/L
 4) NT = Not Tested

**Public Notification to Parents, Teachers, and Staff
Participation in School Drinking Water Quality Reimbursement Program**

School/District Name: Clague Middle School, Ann Arbor Public Schools

Date: 8/30/17

This School/District is committed to protecting the health of students, teachers, and staff. We are participating in the School Drinking Water Quality Reimbursement Program, which is a program jointly administered by the Michigan Department of Education and Department of Environmental Quality. This program is designed to provide school funding for costs associated with the mitigation of potential lead exposure from drinking water. Up to \$950 per school building is available on a reimbursement basis for the cost of testing for lead in drinking water, fixture replacement, filter purchases, plumbing assessments, or technical assistance incurred between July 1, 2016, and September 30, 2017.

The School Drinking Water Quality Reimbursement Program requires that schools submit proof of public notification of the number of fixtures providing water for drinking or food preparation, testing results, number of fixtures replaced, and other corrective action plans prior to reimbursement. This information is as follows:

Number of fixtures providing water for drinking or food preparation: 12

Number of fixtures replaced: (zero if not applicable) 1

Number of filters purchased: (zero if not applicable) 0

Other Actions Taken: (if applicable) Follow up sampling performed

Testing Results:

Number of Lead Tests Completed: (zero if not applicable) 16

Number of Lead Tests with Over 5 parts per billion of Lead: (zero if not applicable) 2

Based upon actions taken to date:

 The District/School has determined that additional corrective action is not necessary.

 x The District/School will be taking the following additional corrective action: One fixture replaced, and follow-up sampling conducted.

About Lead:

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life.

How Can I Learn More?

You can see a copy of all water testing results at the school district's central office, and on our website at (<https://www.a2schools.org>). For more information about water quality in our schools, please contact (Physical Properties) at (734-994-8118). For information about water quality and sampling for lead at home, contact your local water supplier or the Michigan DEQ (www.michigan.gov/drinkingwater).

This Public Notification is being distributed through the following means: Posting in Common Areas of School Buildings; E-mail or Letter to Parents, Teachers and Staff; Posting on Website; Newsletter.

Signed and Certified



Name and Title

Marios Demetriou
Assistant Superintendent,
Finance & Operations



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE170567

Clague Middle School							
Date of Sampling: July 28, 2017							
Sampler: Amanda Peterson							
Sample #	Location	Type ¹	Time Collected	Lead EPA Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	Notes
Clague MS - 01	Water cooler to the left of main entrance in hallway	WC	7:54 AM	15	4	N	First Draw
Clague MS - 02	Water cooler to the right of serving area, left of elevator in hallway	WC	7:56 AM	15	ND ³	N	First Draw
Clague MS - 03	Cafeteria water cooler	WC	8:02 AM	15	ND	N	First Draw
Clague MS - 04	Kitchen 3-comp sink, middle faucet	KS	8:05 AM	15	3	N	First Draw
Clague MS - 05	Kitchen 3-comp sink, left faucet	KS	8:06 AM	15	2	N	First Draw
Clague MS - 06	Water cooler in hallway to the right of Natatorium 160	WC	8:08 AM	15	1	N	First Draw
Clague MS - 07	Water cooler in hallway to the left of laundry room by gym	WC	8:10 AM	15	ND	N	First Draw
Clague MS - 08	Water cooler in-between Mechanical Room 230 and elevator, 2nd floor	WC	8:15 AM	15	ND	N	First Draw
Clague MS - 09	Room 228 Right Classroom Faucet	CF	8:18 AM	15	50	N	First Draw, Slight Yellow Tint
Clague MS - 10	Room 226 Classroom Faucet	CF	8:20 AM	15	16	N	First Draw
Clague MS - 11	Water cooler to the left of Room 223 in hallway	WC	8:25 AM	15	3	N	First Draw
Clague MS - 12	Room 220 classroom faucet, right of 3 faucets	CF	8:28 AM	15	9	Y	First Draw

Clague Middle School							
Date of Sampling: August 15, 2017							
Sampler: Andrew Kelly							
Sample #	Location	Type ¹	Time Collected	Lead EPA Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	Notes
Clague MS - 09A	Room 228 Right Classroom Faucet	CF	12:53 PM	15	ND	N	Follow-up Flush
Clague MS - 10A	Room 226 Classroom Faucet	CF	12:54 PM	15	ND	N	Follow-up Flush

1) Type: B = Bubbler, BT = Bottle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE170567

Clague Middle School							
Date of Sampling: August 16, 2017							
Sampler: Amanda Peterson							
Sample #	Location	Type ¹	Time Collected	Lead EPA Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	Notes
Clague MS - 09B	Room 228 Right Classroom Faucet	CF	9:19 AM	15	4	N	Repeat First Draw
Clague MS - 10B	Room 226 Classroom Faucet	CF	9:23 AM	15	24	N	Repeat First Draw

1) Type: B = Bubblers, BT = Bottle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/ta-ble-regulated-drinking-water-contaminants>
 3) ND= Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

**Public Notification to Parents, Teachers, and Staff
Participation in School Drinking Water Quality Reimbursement Program**

School/District Name: Community High School, Ann Arbor Public Schools

Date: 8/30/17

This School/District is committed to protecting the health of students, teachers, and staff. We are participating in the School Drinking Water Quality Reimbursement Program, which is a program jointly administered by the Michigan Department of Education and Department of Environmental Quality. This program is designed to provide school funding for costs associated with the mitigation of potential lead exposure from drinking water. Up to \$950 per school building is available on a reimbursement basis for the cost of testing for lead in drinking water, fixture replacement, filter purchases, plumbing assessments, or technical assistance incurred between July 1, 2016, and September 30, 2017.

The School Drinking Water Quality Reimbursement Program requires that schools submit proof of public notification of the number of fixtures providing water for drinking or food preparation, testing results, number of fixtures replaced, and other corrective action plans prior to reimbursement. This information is as follows:

Number of fixtures providing water for drinking or food preparation: 12

Number of fixtures replaced: (zero if not applicable) 1

Number of filters purchased: (zero if not applicable) 0

Other Actions Taken: (if applicable) Follow up sampling performed

Testing Results:

Number of Lead Tests Completed: (zero if not applicable) 14

Number of Lead Tests with Over 5 parts per billion of Lead: (zero if not applicable) 1

Based upon actions taken to date:

 The District/School has determined that additional corrective action is not necessary.

 X The District/School will be taking the following additional corrective action: Replaced one fixture, and follow-up sampling completed.

About Lead:

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life.

How Can I Learn More?

You can see a copy of all water testing results at the school district's central office, and on our website at (<https://www.a2schools.org>). For more information about water quality in our schools, please contact (Physical Properties) at (734-994-8118). For information about water quality and sampling for lead at home, contact your local water supplier or the Michigan DEQ (www.michigan.gov/drinkingwater).

This Public Notification is being distributed through the following means: () Posting in Common Areas of School Buildings; () E-mail or Letter to Parents, Teachers and Staff; (X) Posting on Website; () Newsletter.

Signed and Certified



Name and Title

Manos Demetriou
Assistant Superintendent,
Finance & Operations



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE170567

Community High School

Date of Sampling: July 27th, 2017

Sampler: Andrew Kelly

Sample #	Location	Type ¹	Time Collected	EPA Action Level (ug/L) ²	Results (ug/L)	Aerator Present Y/N	Notes
Community - 01	Main Office Staff Sink	KS	11:30 AM	15	18	Y	First Draw
Community - 02	Hallway outside Room 212	WC	11:40 AM	15	ND ³	N	First Draw
Community - 03	Hallway outside Room 310	WC	11:45 AM	15	ND	N	First Draw
Community - 04	Room 312 Lounge	KS	11:47 AM	15	2	Y	First Draw
Community - 05	Hallway outside Room 306	WC	11:50 AM	15	2	N	First Draw
Community - 06	Hallway outside Room 303	WC	11:52 AM	15	ND	N	First Draw
Community - 07	Hallway outside Room 315	WC	11:54 AM	15	4	N	First Draw
Community - 08	Hallway outside Room 213	WC	12:00 PM	15	ND	N	First Draw
Community - 09	Clinic	NS	12:00 PM	15	ND	Y	First Draw
Community - 10	Kitchen 1-compartment sink	KS	12:05 PM	15	3	Y	First Draw
Community - 11	Hallway outside Room 118	B	12:15 PM	15	ND	N	First Draw
Community - 12	Hallway outside Room 113	B	12:25 PM	15	ND	N	First Draw

Community High School

Date of Sampling: August 15th, 2017

Sampler: Andrew Kelly

Sample #	Location	Type ¹	Time Collected	EPA Action Level (ug/L) ²	Results (ug/L)	Aerator Present Y/N	Notes
Community - 01	Main Office Staff Sink	KS	1:13 PM	15	ND	Y	Follow-up Flush

Community High School

Date of Sampling: August 16th, 2017

Sampler: Andrew Kelly

Sample #	Location	Type ¹	Time Collected	EPA Action Level (ug/L) ²	Results (ug/L)	Aerator Present Y/N	Notes
Community - 01	Main Office Staff Sink	KS	8:57AM	15	26	Y	Repeat First Draw

1) Type: B = Bubbler, BT = Bottle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

**Public Notification to Parents, Teachers, and Staff
Participation in School Drinking Water Quality Reimbursement Program**

School/District Name: Dicken Elementary, Ann Arbor Public Schools

Date: 8/30/17

This School/District is committed to protecting the health of students, teachers, and staff. We are participating in the School Drinking Water Quality Reimbursement Program, which is a program jointly administered by the Michigan Department of Education and Department of Environmental Quality. This program is designed to provide school funding for costs associated with the mitigation of potential lead exposure from drinking water. Up to \$950 per school building is available on a reimbursement basis for the cost of testing for lead in drinking water, fixture replacement, filter purchases, plumbing assessments, or technical assistance incurred between July 1, 2016, and September 30, 2017.

The School Drinking Water Quality Reimbursement Program requires that schools submit proof of public notification of the number of fixtures providing water for drinking or food preparation, testing results, number of fixtures replaced, and other corrective action plans prior to reimbursement. This information is as follows:

Number of fixtures providing water for drinking or food preparation: 12

Number of fixtures replaced: (zero if not applicable) 0

Number of filters purchased: (zero if not applicable) 0

Other Actions Taken: (if applicable) Follow up sampling performed

Testing Results:

Number of Lead Tests Completed: (zero if not applicable) 16

Number of Lead Tests with Over 5 parts per billion of Lead: (zero if not applicable) 3

Based upon actions taken to date:

The District/School has determined that additional corrective action is not necessary.

The District/School will be taking the following additional corrective action: _____

About Lead:

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life.

How Can I Learn More?

You can see a copy of all water testing results at the school district's central office, and on our website at (<https://www.a2schools.org>). For more information about water quality in our schools, please contact (Physical Properties) at (734-994-8118). For information about water quality and sampling for lead at home, contact your local water supplier or the Michigan DEQ (www.michigan.gov/drinkingwater).

This Public Notification is being distributed through the following means: Posting in Common Areas of School Buildings; E-mail or Letter to Parents, Teachers and Staff; Posting on Website; Newsletter.

Signed and Certified



Name and Title

Marios Demetriou
Assistant Superintendent,
Finance & Operations



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE170567

Dicken Elementary School							
Date of Sampling: 7/25/17							
Sampler: Amanda Peterson							
Sample #	Location	Type ¹	Time Collected	Lead EPA Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	Notes
Dicken ES-01	To the right of Room 123 in Hallway	CF	9:30 AM	15	5	Y	First Draw
Dicken ES-02	Kitchen Sink	KS	9:33 AM	15	2	Y	First Draw
Dicken ES-03	Room 104 Classroom Faucet - Left	CF	9:35 AM	15	3	Y	First Draw
Dicken ES-04	Room 112 Classroom Faucet - Left	CF	9:37 AM	15	5	Y	First Draw
Dicken ES-05	Room 114 Classroom Faucet - Left - 1 of 2	CF	9:40 AM	15	6	Y	First Draw
Dicken ES-06	Room 114 Right Bubbler, Left Combo Sink	B	9:42 AM	15	4	N	First Draw
Dicken ES-07	Room 114 Bubbler, Right Combo Sink	B	9:45 AM	15	4	N	First Draw
Dicken ES-08	Room 113, Left Faucet, Left Combo Sink	CF	9:48 AM	15	4	Y	First Draw
Dicken ES-09	Room 113, Right Bubbler, Left Combo Sink	B	9:50 AM	15	25	N	First Draw
Dicken ES-10	Room 113, Left Faucet, Right Combo Sink	CF	9:53 AM	15	20	Y	First Draw
Dicken ES-11	Room 109 Left Faucet	CF	9:58 AM	15	11	Y	First Draw
Dicken ES-12	Room 107 Left Faucet	CF	10:02 AM	15	14	Y	First Draw

Dicken Elementary School - Follow Up Flush							
Date of Sampling: 8/2/17							
Sampler: Andrew Kelly							
Dicken ES-09A	Room 113, Right Bubbler, Left Combo Sink	B	1:49 PM	15	ND	N	Follow Up Flush
Dicken ES-10A	Room 113, Left Faucet, Right Combo Sink	CF	1:53 PM	15	ND	Y	Follow Up Flush

Dicken Elementary School - Repeat First Draw							
Date of Sampling: 8/3/17							
Sampler: Andrew Kelly							
Dicken ES-09B	Room 113, Right Bubbler, Left Combo Sink	B	10:15 AM	15	4	N	Repeat First Draw
Dicken ES-10B	Room 113, Left Faucet, Right Combo Sink	CF	10:16 AM	15	ND	Y	Repeat First Draw

1) Type: B = Bubbler, BT = Bottle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

**Public Notification to Parents, Teachers, and Staff
Participation in School Drinking Water Quality Reimbursement Program**

School/District Name: Eberwhite Elementary, Ann Arbor Public Schools

Date: 8/30/17

This School/District is committed to protecting the health of students, teachers, and staff. We are participating in the School Drinking Water Quality Reimbursement Program, which is a program jointly administered by the Michigan Department of Education and Department of Environmental Quality. This program is designed to provide school funding for costs associated with the mitigation of potential lead exposure from drinking water. Up to \$950 per school building is available on a reimbursement basis for the cost of testing for lead in drinking water, fixture replacement, filter purchases, plumbing assessments, or technical assistance incurred between July 1, 2016, and September 30, 2017.

The School Drinking Water Quality Reimbursement Program requires that schools submit proof of public notification of the number of fixtures providing water for drinking or food preparation, testing results, number of fixtures replaced, and other corrective action plans prior to reimbursement. This information is as follows:

Number of fixtures providing water for drinking or food preparation: 12

Number of fixtures replaced: (zero if not applicable) 0

Number of filters purchased: (zero if not applicable) 0

Other Actions Taken: (if applicable) Follow up sampling performed

Testing Results:

Number of Lead Tests Completed: (zero if not applicable) 14

Number of Lead Tests with Over 5 parts per billion of Lead: (zero if not applicable) 3

Based upon actions taken to date:

The District/School has determined that additional corrective action is not necessary.

The District/School will be taking the following additional corrective action: _____

About Lead:


Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life.

How Can I Learn More?

You can see a copy of all water testing results at the school district's central office, and on our website at (<https://www.a2schools.org>). For more information about water quality in our schools, please contact (Physical Properties) at (734-994-8118). For information about water quality and sampling for lead at home, contact your local water supplier or the Michigan DEQ (www.michigan.gov/drinkingwater).

This Public Notification is being distributed through the following means: Posting in Common Areas of School Buildings; E-mail or Letter to Parents, Teachers and Staff; Posting on Website; Newsletter.

Signed and Certified



Name and Title

Marios Demetriou
Assistant Superintendent,
Finance & Operations



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE170567

Eberwhite Elementary School							
Date of Sampling: July 25, 2017							
Sampler: Amanda Peterson							
Sample #	Location	Type ¹	Time Collected	Lead EPA Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	Notes
Eberwhite ES-01	Room 113, Left Faucet	CF	10:30 AM	15	3	Y	First Draw
Eberwhite ES-02	To the Left of Room 115 in Hallway	WC	10:35 AM	15	6	N	First Draw
Eberwhite ES-03	Room 127, Left Faucet	CF	10:40 AM	15	5	Y	First Draw
Eberwhite ES-04	Room 127, Right Bubbler	B	10:42 AM	15	2	N	First Draw
Eberwhite ES-05	Room 125, Left Faucet	CF	10:45 AM	15	13	Y	First Draw
Eberwhite ES-06	Room 125, Right Bubbler	B	10:48 AM	15	2	N	First Draw
Eberwhite ES-07	Room 126, Left Faucet	CF	10:50 AM	15	2	Y	First Draw
Eberwhite ES-08	In Hallway to the Left of Main Office, Left Water Cooler	WC	10:55 AM	15	39	N	First Draw
Eberwhite ES-09	In Hallway to the Left of Room 122, Left Bubbler	B	10:57 AM	15	4	N	First Draw
Eberwhite ES-10	In Hallway to the Left of Room 122, Right Bubbler	B	11:00 AM	15	3	N	First Draw
Eberwhite ES-11	Room 122, Left Faucet	CF	11:05 AM	15	3	Y	First Draw
Eberwhite ES-12	In Hallway to the Left of Main Office, Right Water Cooler	WC	11:10 AM	15	7	N	First Draw

Eberwhite Elementary School							
Date of Sampling: August 2, 2017							
Sampler: Andrew Kelly							
Eberwhite ES-08A	In Hallway to the Left of Main Office, Left Water Cooler	WC	2:32 PM	15	ND ³	N	Follow Up Flush

Eberwhite Elementary School							
Date of Sampling: August 3, 2017							
Sampler: Andrew Kelly							
Eberwhite ES-08B	In Hallway to the Left of Main Office, Left Water Cooler	WC	9:57 AM	15	ND	N	Repeat First Draw

1) Type: B = Bubbler, BT = Best the Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND= Non Detected at Report ed Detection Limit of 1 ug/L
 4) NT = Not Tested

**Public Notification to Parents, Teachers, and Staff
Participation in School Drinking Water Quality Reimbursement Program**

School/District Name: Forsythe Middle School, Ann Arbor Public Schools

Date: 8/30/17

This School/District is committed to protecting the health of students, teachers, and staff. We are participating in the School Drinking Water Quality Reimbursement Program, which is a program jointly administered by the Michigan Department of Education and Department of Environmental Quality. This program is designed to provide school funding for costs associated with the mitigation of potential lead exposure from drinking water. Up to \$950 per school building is available on a reimbursement basis for the cost of testing for lead in drinking water, fixture replacement, filter purchases, plumbing assessments, or technical assistance incurred between July 1, 2016, and September 30, 2017.

The School Drinking Water Quality Reimbursement Program requires that schools submit proof of public notification of the number of fixtures providing water for drinking or food preparation, testing results, number of fixtures replaced, and other corrective action plans prior to reimbursement. This information is as follows:

Number of fixtures providing water for drinking or food preparation: 12

Number of fixtures replaced: (zero if not applicable) 0

Number of filters purchased: (zero if not applicable) 0

Other Actions Taken: (if applicable) Follow up sampling performed

Testing Results:

Number of Lead Tests Completed: (zero if not applicable) 24

Number of Lead Tests with Over 5 parts per billion of Lead: (zero if not applicable) 2

Based upon actions taken to date:

The District/School has determined that additional corrective action is not necessary.

The District/School will be taking the following additional corrective action: _____

About Lead:


Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life.

How Can I Learn More?

You can see a copy of all water testing results at the school district's central office, and on our website at (<https://www.a2schools.org>). For more information about water quality in our schools, please contact (Physical Properties) at (734-994-8118). For information about water quality and sampling for lead at home, contact your local water supplier or the Michigan DEQ (www.michigan.gov/drinkingwater).

This Public Notification is being distributed through the following means: Posting in Common Areas of School Buildings; E-mail or Letter to Parents, Teachers and Staff; Posting on Website; Newsletter.

Signed and Certified



Name and Title

Marios Demetriou
Assistant Superintendent,
Finance & Operations



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE170567

Forsythe Middle School
Date of Sampling: July 26, 2017
Sampler: Amanda Peterson

Sample #	Location	Type ¹	Time Collected	Lead EPA Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	Notes
Forsythe MS-01	Watercooler in Hallway to the Right of Counseling Center Across from Room 308	WC	8:55 AM	15	ND	N	First Draw
Forsythe MS-02	Bubbler in Hallway Across from Room 501	B	8:58 AM	15	2	N	First Draw
Forsythe MS-03	Room 602 Right Classroom Faucet	CF	9:00 AM	15	2	Y	First Draw
Forsythe MS-04	Bubbler in Hallway Across from Room 614	B	9:03 AM	15	49	N	First Draw
Forsythe MS-05	Room 611 2-Compartment Sink	KS	9:06 AM	15	74	Y	First Draw
Forsythe MS-06	Bubbler in Room 113	B	9:35 AM	15	21	Y	First Draw
Forsythe MS-07	Bubbler in Hallway Across from Room 401	B	9:12 AM	15	9	N	First Draw
Forsythe MS-08	Bubbler Across from Room 412	B	9:15 AM	15	120	N	First Draw, Cloudy Appearance to Water
Forsythe MS-09	Room 312 Back of Classroom, Front Sink	CF	9:20 AM	15	18	Y	First Draw
Forsythe MS-10	Bubbler in Girls Locker Room	B	9:23 AM	15	ND	N	First Draw
Forsythe MS-11	Bubbler in Boys Locker Room	B	9:25 AM	15	ND	N	First Draw
Forsythe MS-12	Bubbler in Room 111	B	9:30 AM	15	79	N	First Draw

Forsythe Middle School
Date of Sampling: August 2, 2017
Sampler: Andrew Kelly

Sample #	Location	Type ¹	Time Collected	Lead EPA Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	Notes
Forsythe MS-04A	Bubbler in Hallway Across from Room 614	B	5:23 PM	15	ND ³	N	Follow-up Flush
Forsythe MS-05A	Room 611 2-Compartment Sink	KS	5:24 PM	15	ND	Y	Follow-up Flush
Forsythe MS-06A	Bubbler in Room 113	B	5:39 PM	15	ND	N	Follow-up Flush
Forsythe MS-08A	Bubbler Across from Room 412	B	5:53 PM	15	ND	N	Follow-up Flush
Forsythe MS-09A	Room 312 Back of Classroom, Front Sink	CF	5:27 PM	15	6	Y	Follow-up Flush
Forsythe MS-12A	Bubbler in Room 111	B	5:34 PM	15	2	N	Follow-up Flush

1) Type: B = Bubbler, BF = Battle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/is-bie-regulated-drinking-water-contaminant>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE170567

Forsythe Middle School							
Date of Sampling: August 3, 2017							
Sampler: Andrew Kelly							
Sample #	Location	Type ¹	Time Collected	Lead EPA Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	Notes
Forsythe MS-04B	Bubbler in Hallway Across from Room 614	B	8:26 AM	15	ND	N	Repeat First Draw
Forsythe MS-05B	Room 611 2-Compartment Sink	KS	8:27 AM	15	5	Y	Repeat First Draw
Forsythe MS-06B	Bubbler in Room 113	B	8:23 AM	15	1	N	Repeat First Draw
Forsythe MS-08B	Bubbler Across from Room 412	B	8:30 AM	15	3	N	Repeat First Draw
Forsythe MS-09B	Room 312 Back of Classroom, Front Sink	CF	8:24 AM	15	13	Y	Repeat First Draw
Forsythe MS-12B	Bubbler in Room 111	B	8:22 AM	15	ND	N	Repeat First Draw

1) Type: B = Bubbler, BT = Bottle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

**Public Notification to Parents, Teachers, and Staff
Participation in School Drinking Water Quality Reimbursement Program**

School/District Name: Haisley Elementary, Ann Arbor Public Schools

Date: 8/30/17

This School/District is committed to protecting the health of students, teachers, and staff. We are participating in the School Drinking Water Quality Reimbursement Program, which is a program jointly administered by the Michigan Department of Education and Department of Environmental Quality. This program is designed to provide school funding for costs associated with the mitigation of potential lead exposure from drinking water. Up to \$950 per school building is available on a reimbursement basis for the cost of testing for lead in drinking water, fixture replacement, filter purchases, plumbing assessments, or technical assistance incurred between July 1, 2016, and September 30, 2017.

The School Drinking Water Quality Reimbursement Program requires that schools submit proof of public notification of the number of fixtures providing water for drinking or food preparation, testing results, number of fixtures replaced, and other corrective action plans prior to reimbursement. This information is as follows:

Number of fixtures providing water for drinking or food preparation: 12

Number of fixtures replaced: (zero if not applicable) 2

Number of filters purchased: (zero if not applicable) 0

Other Actions Taken: (if applicable) Follow up sampling performed

Testing Results:

Number of Lead Tests Completed: (zero if not applicable) 16

Number of Lead Tests with Over 5 parts per billion of Lead: (zero if not applicable) 2

Based upon actions taken to date:

 The District/School has determined that additional corrective action is not necessary.

 X The District/School will be taking the following additional corrective action: _____

Replaced one fixture and conducted follow-up sampling from the replacement fixture.

About Lead:


Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life.

How Can I Learn More?

You can see a copy of all water testing results at the school district's central office, and on our website at (<https://www.a2schools.org>). For more information about water quality in our schools, please contact (Physical Properties) at (734-994-8118). For information about water quality and sampling for lead at home, contact your local water supplier or the Michigan DEQ (www.michigan.gov/drinkingwater).

This Public Notification is being distributed through the following means: Posting in Common Areas of School Buildings; E-mail or Letter to Parents, Teachers and Staff; Posting on Website; Newsletter.

Signed and Certified



Name and Title

Marios Demetriou
Assistant Superintendent,
Finance & Operations



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE170567

Haisley Elementary School							
Date of Sampling: 7/25/17							
Sampler: Amanda Peterson							
Sample #	Location	Type ¹	Time Collected	Lead EPA Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	Notes
Haisley ES-01	In hallway across from Room 114	WC	11:30 AM	15	2	N	First Draw - Slight Yellow Tint
Haisley ES-02	In hallway across from Room 200	WC	11:33 AM	15	2	N	First Draw - Slight Yellow Tint
Haisley ES-03	Room 200, Left Bubbler	B	11:35 AM	15	4	N	First Draw - Slight Yellow Tint
Haisley ES-04	Room 200, Right Faucet	CF	11:37 AM	15	4	Y	First Draw - Slight Yellow Tint
Haisley ES-05	Room 112, Left Classroom Faucet	CF	11:40 AM	15	3	Y	First Draw - Slight Yellow Tint
Haisley ES-06	Room 112, Right Bubbler	B	11:42 AM	15	1	N	First Draw - Slight Yellow Tint
Haisley ES-07	Room 109, Middle Faucet	CF	11:45 AM	15	38	Y	First Draw
Haisley ES-08	Room 106, Left Faucet	CF	11:48 AM	15	8	Y	First Draw - Slight Yellow Tint
Haisley ES-09	Room 106, Right Bubbler	B	11:50 AM	15	2	N	First Draw - Slight Yellow Tint
Haisley ES-10	Room 102, Left Faucet	CF	11:55 AM	15	5	Y	First Draw - Slight Yellow Tint
Haisley ES-11	Room 102, Right Bubbler	B	12:00 PM	15	2	N	First Draw - Slight Yellow Tint
Haisley ES-12	Library Work Room 2 Compartment Sink	CF	12:10 PM	15	17	Y	First Draw - Slight Yellow Tint

Haisley Elementary School							
Date of Sampling: 8/2/17							
Sampler: Andrew Kelly							
Haisley ES-07A	Room 109, Middle Faucet	CF	3:38 PM	15	6	Y	Follow Up Flush
Haisley ES-12A	Library Work Room 2 Compartment Sink	CF	3:39 PM	15	ND	Y	Follow Up Flush

Haisley Elementary School							
Date of Sampling: 8/3/17							
Sampler: Andrew Kelly							
Haisley ES-07B	Room 109, Middle Faucet	CF	9:27 AM	15	3	Y	Repeat First Draw
Haisley ES-12B	Library Work Room 2 Compartment Sink	CF	9:28 AM	15	20	Y	Repeat First Draw

1) Type: B = Bubbler, BT = Bottle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

**Public Notification to Parents, Teachers, and Staff
Participation in School Drinking Water Quality Reimbursement Program**

School/District Name: Huron High School, Ann Arbor Public Schools

Date: 8/30/17

This School/District is committed to protecting the health of students, teachers, and staff. We are participating in the School Drinking Water Quality Reimbursement Program, which is a program jointly administered by the Michigan Department of Education and Department of Environmental Quality. This program is designed to provide school funding for costs associated with the mitigation of potential lead exposure from drinking water. Up to \$950 per school building is available on a reimbursement basis for the cost of testing for lead in drinking water, fixture replacement, filter purchases, plumbing assessments, or technical assistance incurred between July 1, 2016, and September 30, 2017.

The School Drinking Water Quality Reimbursement Program requires that schools submit proof of public notification of the number of fixtures providing water for drinking or food preparation, testing results, number of fixtures replaced, and other corrective action plans prior to reimbursement. This information is as follows:

Number of fixtures providing water for drinking or food preparation: 12

Number of fixtures replaced: (zero if not applicable) 0

Number of filters purchased: (zero if not applicable) 0

Other Actions Taken: (if applicable) _____

Testing Results:

Number of Lead Tests Completed: (zero if not applicable) 12

Number of Lead Tests with Over 5 parts per billion of Lead: (zero if not applicable) 0

Based upon actions taken to date:

The District/School has determined that additional corrective action is not necessary.

The District/School will be taking the following additional corrective action: _____

About Lead:

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life.

How Can I Learn More?

You can see a copy of all water testing results at the school district's central office, and on our website at (<https://www.a2schools.org>). For more information about water quality in our schools, please contact (Physical Properties) at (734-994-8118). For information about water quality and sampling for lead at home, contact your local water supplier or the Michigan DEQ (www.michigan.gov/drinkingwater).

This Public Notification is being distributed through the following means: Posting in Common Areas of School Buildings; E-mail or Letter to Parents, Teachers and Staff; Posting on Website; Newsletter.

Signed and Certified



Name and Title

Marios Demetriou
Assistant Superintendent,
Finance & Operations



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE170567

Huron High School							
Date of Sampling: July 28th, 2017							
Sampler: Amanda Peterson							
Sample #	Location	Type ¹	Time Collected	EPA Action Level (ug/L) ²	Results (ug/L)	Aerator Present Y/N	Notes
Huron HS-01	In Hallway, Left of Room 6152	B	9:45 AM	15	ND ³	N	First Draw
Huron HS-02	In Hallway, Right of Career Center 6120, Left Water Cooler	WC	9:50 AM	15	ND	N	First Draw
Huron HS-03	In Hallway, Right of Career Center 6120, Right Water Cooler	WC	9:52 AM	15	ND	N	First Draw
Huron HS-04	Principals Office Lounge Faucet	CF	9:56 AM	15	ND	Y	First Draw
Huron HS-05	Clinic Faucet, Room 2	CF	9:58 AM	15	ND	Y	First Draw
Huron HS-06	In Hallway, Left of Media Center 5101, Left Bubbler	B	10:02 AM	15	ND	N	First Draw
Huron HS-07	In Hallway, Left of Media Center 5101, Right Bubbler	B	10:03 AM	15	ND	N	First Draw
Huron HS-08	In Hallway, Left of Cafeteria, Left Bubbler	B	10:06 AM	15	ND	N	First Draw
Huron HS-09	In Hallway, Left of Cafeteria, Right Bubbler	B	10:08 AM	15	ND	N	First Draw
Huron HS-10	In Hallway, Across From Room 2104	B	10:10 AM	15	ND	N	First Draw
Huron HS-11	In Hallway, Across From Room 1110, Left Bubbler	B	10:12 AM	15	ND	N	First Draw
Huron HS-12	In Hallway, Across From Room 1110, Right Bubbler	B	10:14 AM	15	ND	N	First Draw

1) Type: B = Bubbler, BT = Bottle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/table-regulate-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

**Public Notification to Parents, Teachers, and Staff
Participation in School Drinking Water Quality Reimbursement Program**

School/District Name: King Elementary, Ann Arbor Public Schools

Date: 8/30/17

This School/District is committed to protecting the health of students, teachers, and staff. We are participating in the School Drinking Water Quality Reimbursement Program, which is a program jointly administered by the Michigan Department of Education and Department of Environmental Quality. This program is designed to provide school funding for costs associated with the mitigation of potential lead exposure from drinking water. Up to \$950 per school building is available on a reimbursement basis for the cost of testing for lead in drinking water, fixture replacement, filter purchases, plumbing assessments, or technical assistance incurred between July 1, 2016, and September 30, 2017.

The School Drinking Water Quality Reimbursement Program requires that schools submit proof of public notification of the number of fixtures providing water for drinking or food preparation, testing results, number of fixtures replaced, and other corrective action plans prior to reimbursement. This information is as follows:

Number of fixtures providing water for drinking or food preparation: 12

Number of fixtures replaced: (zero if not applicable) 0

Number of filters purchased: (zero if not applicable) 0

Other Actions Taken: (if applicable) _____

Testing Results:

Number of Lead Tests Completed: (zero if not applicable) 12

Number of Lead Tests with Over 5 parts per billion of Lead: (zero if not applicable) 1

Based upon actions taken to date:

The District/School has determined that additional corrective action is not necessary.

The District/School will be taking the following additional corrective action: _____

About Lead:


Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life.

How Can I Learn More?

You can see a copy of all water testing results at the school district's central office, and on our website at (<https://www.a2schools.org>). For more information about water quality in our schools, please contact (Physical Properties) at (734-994-8118). For information about water quality and sampling for lead at home, contact your local water supplier or the Michigan DEQ (www.michigan.gov/drinkingwater).

This Public Notification is being distributed through the following means: Posting in Common Areas of School Buildings; E-mail or Letter to Parents, Teachers and Staff; Posting on Website; Newsletter.

Signed and Certified



Name and Title

Marios Demetriou
Assistant Superintendent,
Finance & Operations



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE170567

King Elementary School							
Date of Sampling: July 28th, 2017							
Sampler: Amanda Peterson							
Sample #	Location	Type ¹	Time Collected	EPA Action Level (ug/L) ²	Results (ug/L)	Aerator Present Y/N	Notes
King ES-01	In Hallway, Outside Main Office	WC	11:05 AM	15	ND ³	N	First Draw
King ES-02	Teachers Lounge Faucet	CF	11:07 AM	15	8	Y	First Draw
King ES-03	Kitchen, Single Compartment Sink	KS	11:09 AM	15	ND	Y	First Draw
King ES-04	In Hallway, Between Multipurpose Room and Cafeteria, Left of Men's Restroom	B	11:11 AM	15	ND	N	First Draw
King ES-05	Room 106, Right Bubbler	B	11:13 AM	15	ND	N	First Draw
King ES-06	Room 107, Left Bubbler	B	11:15 AM	15	1	N	First Draw
King ES-07	Room 108, Left Faucet	CF	11:17 AM	15	2	Y	First Draw
King ES-08	Room 110, Right Bubbler	B	11:20 AM	15	ND	N	First Draw
King ES-09	Room 118, Left Faucet	CF	11:25 AM	15	ND	Y	First Draw
King ES-10	Clinic in Main Office	CF	11:30 AM	15	3	Y	First Draw
King ES-11	Room 109, Left Bubbler	B	11:35 AM	15	ND	N	First Draw
King ES-12	Room 104, Left Faucet	CF	11:38 AM	15	ND	Y	First Draw

1) Type: B = Bubbler, BT = Bottle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

**Public Notification to Parents, Teachers, and Staff
Participation in School Drinking Water Quality Reimbursement Program**

School/District Name: Lakewood Elementary, Ann Arbor Public Schools

Date: 8/30/17

This School/District is committed to protecting the health of students, teachers, and staff. We are participating in the School Drinking Water Quality Reimbursement Program, which is a program jointly administered by the Michigan Department of Education and Department of Environmental Quality. This program is designed to provide school funding for costs associated with the mitigation of potential lead exposure from drinking water. Up to \$950 per school building is available on a reimbursement basis for the cost of testing for lead in drinking water, fixture replacement, filter purchases, plumbing assessments, or technical assistance incurred between July 1, 2016, and September 30, 2017.

The School Drinking Water Quality Reimbursement Program requires that schools submit proof of public notification of the number of fixtures providing water for drinking or food preparation, testing results, number of fixtures replaced, and other corrective action plans prior to reimbursement. This information is as follows:

Number of fixtures providing water for drinking or food preparation: 12

Number of fixtures replaced: (zero if not applicable) 0

Number of filters purchased: (zero if not applicable) 0

Other Actions Taken: (if applicable) _____

Testing Results:

Number of Lead Tests Completed: (zero if not applicable) 12

Number of Lead Tests with Over 5 parts per billion of Lead: (zero if not applicable) 2

Based upon actions taken to date:

The District/School has determined that additional corrective action is not necessary.

The District/School will be taking the following additional corrective action: _____

About Lead:


Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life.

How Can I Learn More?

You can see a copy of all water testing results at the school district's central office, and on our website at (<https://www.a2schools.org>). For more information about water quality in our schools, please contact (Physical Properties) at (734-994-8118). For information about water quality and sampling for lead at home, contact your local water supplier or the Michigan DEQ (www.michigan.gov/drinkingwater).

This Public Notification is being distributed through the following means: Posting in Common Areas of School Buildings; E-mail or Letter to Parents, Teachers and Staff; Posting on Website; Newsletter.

Signed and Certified



Name and Title

Marios Demetriou
Assistant Superintendent,
Finance & Operations



Allen Park Public Schools
 Drinking Water Analysis
 Project Number: AE170567

Lakewood Elementary School							
Date of Sampling: July 25, 2017							
Sampler: Amanda Peterson							
Sample #	Location	Type ¹	Time Collected	Lead EPA Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	Notes
Lakewood ES - 01	Lounge Across from 2-Compartment Sink	KS	12:15 PM	15	3	Y	First Draw
Lakewood ES - 02	Water Cooler across from Media Center	WC	12:17 PM	15	2	N	First Draw
Lakewood ES - 03	Room 103, Classroom Faucet	CF	12:19 PM	15	2	Y	First Draw
Lakewood ES - 04	Room 109, Right Faucet	CF	12:25 PM	15	9	Y	First Draw
Lakewood ES - 05	Room 109, Left Bubbler	B	12:30 PM	15	2	N	First Draw
Lakewood ES - 06	Bubbler Right of the Gym	B	12:32 PM	15	1	N	First Draw
Lakewood ES - 07	Room 108, Left Faucet	CF	12:35 PM	15	3	Y	First Draw
Lakewood ES - 08	Room 108, Right Bubbler	B	12:40 PM	15	2	N	First Draw
Lakewood ES - 09	Room 139, Left Faucet	CF	12:42 PM	15	7	Y	First Draw
Lakewood ES - 10	Water Cooler in Hallway to the Left of Room 139	WC	12:45 PM	15	1	N	First Draw
Lakewood ES - 11	Kitchen 3-Compartment Sink, Middle Faucet	KS	12:50 PM	15	2	Y	First Draw
Lakewood ES - 12	Room A-5, Right Bubbler	B	1:00 PM	15	2	N	First Draw

1) Type: B = Bubbler, BT = Bottle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

**Public Notification to Parents, Teachers, and Staff
Participation in School Drinking Water Quality Reimbursement Program**

School/District Name: Lawton Elementary, Ann Arbor Public Schools

Date: 8/30/17

This School/District is committed to protecting the health of students, teachers, and staff. We are participating in the School Drinking Water Quality Reimbursement Program, which is a program jointly administered by the Michigan Department of Education and Department of Environmental Quality. This program is designed to provide school funding for costs associated with the mitigation of potential lead exposure from drinking water. Up to \$950 per school building is available on a reimbursement basis for the cost of testing for lead in drinking water, fixture replacement, filter purchases, plumbing assessments, or technical assistance incurred between July 1, 2016, and September 30, 2017.

The School Drinking Water Quality Reimbursement Program requires that schools submit proof of public notification of the number of fixtures providing water for drinking or food preparation, testing results, number of fixtures replaced, and other corrective action plans prior to reimbursement. This information is as follows:

Number of fixtures providing water for drinking or food preparation: 12

Number of fixtures replaced: (zero if not applicable) 1

Number of filters purchased: (zero if not applicable) 0

Other Actions Taken: (if applicable) Follow up sampling performed.

Testing Results:

Number of Lead Tests Completed: (zero if not applicable) 14

Number of Lead Tests with Over 5 parts per billion of Lead: (zero if not applicable) 2

Based upon actions taken to date:

 The District/School has determined that additional corrective action is not necessary.

X The District/School will be taking the following additional corrective action: One Fixture Replaced, and follow-up sampling conducted.

About Lead:


Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life.

How Can I Learn More?

You can see a copy of all water testing results at the school district's central office, and on our website at (<https://www.a2schools.org>). For more information about water quality in our schools, please contact (Physical Properties) at (734-994-8118). For information about water quality and sampling for lead at home, contact your local water supplier or the Michigan DEQ (www.michigan.gov/drinkingwater).

This Public Notification is being distributed through the following means: () Posting in Common Areas of School Buildings; () E-mail or Letter to Parents, Teachers and Staff; (X) Posting on Website; () Newsletter.

Signed and Certified



Name and Title

Marios Demetriou
Assistant Superintendent,
Finance & Operations



**Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE170567**

Lawton Elementary School

Date of Sampling: 08/03/17

Sampler: Andrew Kelly

Sample #	Location	Type ¹	Time Collected	Lead EPA Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	Notes
Lawton-01	Room 310, Bubbler	B	10:33 AM	15	ND	N	First Draw
Lawton-02	Room 312, Classroom Faucet	CF	10:34 AM	15	51	Y	First Draw
Lawton-03	Room 316, Bubbler	B	10:36 AM	15	1	N	First Draw
Lawton-04	Room 314, Classroom Faucet	CF	10:37 AM	15	3	Y	First Draw
Lawton-05	Room 210, Bubbler	B	10:41 AM	15	1	N	First Draw
Lawton-06	Cafeteria/Auditorium, Right Water Cooler	WC	10:43 AM	15	ND	N	First Draw
Lawton-07	Kitchen 3-Compartment Sink, Left Faucet	KS	10:45 AM	15	7	Y	First Draw
Lawton-08	Gym Bubbler	B	10:48 AM	15	1	N	First Draw
Lawton-09	Staff Lounge Kitchen Sink, Left Faucet	KS	10:50 AM	15	1	Y	First Draw
Lawton-10	Room 203, Bubbler	B	10:52 AM	15	ND	N	First Draw
Lawton-11	Room 201 Classroom Faucet, Back Corner of Classroom	CF	10:55 AM	15	1	Y	First Draw
Lawton-12	Hallway Outside Room 219, Bubbler	B	10:57 AM	15	2	N	First Draw

Lawton Elementary School

Date of Sampling: 08/15/17

Sampler: Andrew Kelly

Sample #	Location	Type ¹	Time Collected	Lead EPA Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	Notes
Lawton-02A	Room 312, Classroom Faucet	CF	2:36 PM	15	3	Y	Follow-Up Flush

Lawton Elementary School

Date of Sampling: 08/16/17

Sampler: Amanda Peterson

Sample #	Location	Type ¹	Time Collected	Lead EPA Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	Notes
Lawton-02B	Room 312, Classroom Faucet	CF	10:15 AM	15	23	Y	Repeat First Draw

1) Type: B = Bubbler, CF = Classroom Faucet, WC = Water Cooler, KS = Kitchen Sink, NS = Nurse Sink
2) <https://www.epa.gov/your-drinking-water/lead-regulation-drinking-water-unsafe-children>
3) ND = Non-Detected at Report of Detection Limit of 1 ug/L
4) NT = Not Tested

**Public Notification to Parents, Teachers, and Staff
Participation in School Drinking Water Quality Reimbursement Program**

School/District Name: Logan Elementary, Ann Arbor Public Schools

Date: 8/30/17

This School/District is committed to protecting the health of students, teachers, and staff. We are participating in the School Drinking Water Quality Reimbursement Program, which is a program jointly administered by the Michigan Department of Education and Department of Environmental Quality. This program is designed to provide school funding for costs associated with the mitigation of potential lead exposure from drinking water. Up to \$950 per school building is available on a reimbursement basis for the cost of testing for lead in drinking water, fixture replacement, filter purchases, plumbing assessments, or technical assistance incurred between July 1, 2016, and September 30, 2017.

The School Drinking Water Quality Reimbursement Program requires that schools submit proof of public notification of the number of fixtures providing water for drinking or food preparation, testing results, number of fixtures replaced, and other corrective action plans prior to reimbursement. This information is as follows:

Number of fixtures providing water for drinking or food preparation: 12

Number of fixtures replaced: (zero if not applicable) 0

Number of filters purchased: (zero if not applicable) 0

Other Actions Taken: (if applicable) _____

Testing Results:

Number of Lead Tests Completed: (zero if not applicable) 12

Number of Lead Tests with Over 5 parts per billion of Lead: (zero if not applicable) 1

Based upon actions taken to date:

The District/School has determined that additional corrective action is not necessary.

The District/School will be taking the following additional corrective action: _____

About Lead:


Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life.

How Can I Learn More?

You can see a copy of all water testing results at the school district's central office, and on our website at (<https://www.a2schools.org>). For more information about water quality in our schools, please contact (Physical Properties) at (734-994-8118). For information about water quality and sampling for lead at home, contact your local water supplier or the Michigan DEQ (www.michigan.gov/drinkingwater).

This Public Notification is being distributed through the following means: Posting in Common Areas of School Buildings; E-mail or Letter to Parents, Teachers and Staff; Posting on Website; Newsletter.

Signed and Certified



Name and Title

Marios Demetriou
Assistant Superintendent,
Finance & Operations



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE170567

Logan Elementary School							
Date of Sampling: July 28th, 2017							
Sampler: Amanda Peterson							
Sample #	Location	Type ¹	Time Collected	EPA Action Level (ug/L) ²	Results (ug/L)	Aerator Present Y/N	Notes
Logan ES - 01	Water cooler in hallway in from of Teacher's Lounge 262	WC	12:00 PM	15	1	N	First Draw
Logan ES - 02	Teacher's Lounge, Classroom Faucet	CF	12:02 PM	15	5	Y	First Draw
Logan ES - 03	Kitchen 2-Compartment Sink	KS	12:03 PM	15	6	Y	First Draw
Logan ES - 04	Bubbler in Hallway to the Left of Room 316	B	12:05 PM	15	5	N	First Draw
Logan ES - 05	Left Water Cooler in Hallway to the Right of Teacher's Work Room	WC	12:10 PM	15	ND ³	N	First Draw
Logan ES - 06	Right Water Cooler in Hallway to the Right of Teacher's Work Room	WC	12:11 PM	15	ND	N	First Draw
Logan ES - 07	Room 324, Left Bubbler	B	12:15 PM	15	3	N	First Draw
Logan ES - 08	Left Water Cooler in Media Center, Right of Teacher's Work Room	WC	12:17 PM	15	ND	N	First Draw
Logan ES - 09	Right Water Cooler in Media Center Right of Teacher's Work Room	WC	12:19 PM	15	ND	N	First Draw
Logan ES - 10	Room 240, Left Bubbler	B	12:20 PM	15	4	N	First Draw
Logan ES - 11	Room 234, Left Faucet	CF	12:22 PM	15	5	Y	First Draw
Logan ES - 12	Room 220 Kindergarten, Right Bubbler	B	12:25 PM	15	2	N	First Draw

1) Type: B = Bubbler, BF = Bottle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

**Public Notification to Parents, Teachers, and Staff
Participation in School Drinking Water Quality Reimbursement Program**

School/District Name: Mitchell Elementary, Ann Arbor Public Schools

Date: 8/30/17

This School/District is committed to protecting the health of students, teachers, and staff. We are participating in the School Drinking Water Quality Reimbursement Program, which is a program jointly administered by the Michigan Department of Education and Department of Environmental Quality. This program is designed to provide school funding for costs associated with the mitigation of potential lead exposure from drinking water. Up to \$950 per school building is available on a reimbursement basis for the cost of testing for lead in drinking water, fixture replacement, filter purchases, plumbing assessments, or technical assistance incurred between July 1, 2016, and September 30, 2017.

The School Drinking Water Quality Reimbursement Program requires that schools submit proof of public notification of the number of fixtures providing water for drinking or food preparation, testing results, number of fixtures replaced, and other corrective action plans prior to reimbursement. This information is as follows:

Number of fixtures providing water for drinking or food preparation: 12

Number of fixtures replaced: (zero if not applicable) 0

Number of filters purchased: (zero if not applicable) 0

Other Actions Taken: (if applicable) _____

Testing Results:

Number of Lead Tests Completed: (zero if not applicable) 12

Number of Lead Tests with Over 5 parts per billion of Lead: (zero if not applicable) 0

Based upon actions taken to date:

The District/School has determined that additional corrective action is not necessary.

The District/School will be taking the following additional corrective action: _____

About Lead:


Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life.

How Can I Learn More?

You can see a copy of all water testing results at the school district's central office, and on our website at (<https://www.a2schools.org>). For more information about water quality in our schools, please contact (Physical Properties) at (734-994-8118). For information about water quality and sampling for lead at home, contact your local water supplier or the Michigan DEQ (www.michigan.gov/drinkingwater).

This Public Notification is being distributed through the following means: Posting in Common Areas of School Buildings; E-mail or Letter to Parents, Teachers and Staff; Posting on Website; Newsletter.

Signed and Certified



Name and Title

Marios Demetriou
Assistant Superintendent,
Finance & Operations



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE170567

Mitchell Elementary School							
Date of Sampling: 08/01/17							
Sampler: Andrew Kelly							
Sample #	Location	Type ¹	Time Collected	Lead EPA Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	Notes
Mitchell -01	Hallway Outside MPR Left of Girls Bathroom, Water Cooler	WC	11:14 AM	15	ND ³	N	First Draw
Mitchell -02	Room 1 Bubbler	B	11:16 AM	15	ND	N	First Draw
Mitchell-03	Room 6 Bubbler	B	11:18 AM	15	ND	N	First Draw
Mitchell-04	Room 4 Bubbler	B	11:20 AM	15	ND	N	First Draw
Mitchell-05	Computer Center Faucet	CF	11:22 AM	15	1	Y	First Draw
Mitchell-06	Room 8 Bubbler	B	11:25 AM	15	4	N	First Draw
Mitchell-07	Room 9 Right Faucet	B	11:27 AM	15	ND	Y	First Draw
Mitchell-08	Teachers Lounge Sink	KS	11:31 AM	15	ND	Y	First Draw
Mitchell-09	Hallway Outside Gym Next to Girls Bathroom	WC	11:32 AM	15	ND	N	First Draw
Mitchell-10	Room 15 Water Cooler	WC	11:33 AM	15	2	N	First Draw
Mitchell-11	Room 19 Water Cooler	WC	11:37 AM	15	ND	N	First Draw
Mitchell-12	Main Office Clinic Sink	NS	11:41 AM	15	2	Y	First Draw

1) Type: B = Bubbler, BT = Bottle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

Public Notification to Parents, Teachers, and Staff
Participation in School Drinking Water Quality Reimbursement Program
Pathways to Success Academic Campus, Ann Arbor Public Schools
School/District Name: _____

Date: 8/30/17

This School/District is committed to protecting the health of students, teachers, and staff. We are participating in the School Drinking Water Quality Reimbursement Program, which is a program jointly administered by the Michigan Department of Education and Department of Environmental Quality. This program is designed to provide school funding for costs associated with the mitigation of potential lead exposure from drinking water. Up to \$950 per school building is available on a reimbursement basis for the cost of testing for lead in drinking water, fixture replacement, filter purchases, plumbing assessments, or technical assistance incurred between July 1, 2016, and September 30, 2017.

The School Drinking Water Quality Reimbursement Program requires that schools submit proof of public notification of the number of fixtures providing water for drinking or food preparation, testing results, number of fixtures replaced, and other corrective action plans prior to reimbursement. This information is as follows:

Number of fixtures providing water for drinking or food preparation: 12

Number of fixtures replaced: (zero if not applicable) 0

Number of filters purchased: (zero if not applicable) 0

Other Actions Taken: (if applicable) _____

Testing Results:

Number of Lead Tests Completed: (zero if not applicable) 12

Number of Lead Tests with Over 5 parts per billion of Lead: (zero if not applicable) 2

Based upon actions taken to date:

The District/School has determined that additional corrective action is not necessary.

The District/School will be taking the following additional corrective action: _____

About Lead:

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life.

How Can I Learn More?

You can see a copy of all water testing results at the school district's central office, and on our website at (<https://www.a2schools.org>). For more information about water quality in our schools, please contact (Physical Properties) at (734-994-8118). For information about water quality and sampling for lead at home, contact your local water supplier or the Michigan DEQ (www.michigan.gov/drinkingwater).

This Public Notification is being distributed through the following means: Posting in Common Areas of School Buildings; E-mail or Letter to Parents, Teachers and Staff; Posting on Website; Newsletter.

Signed and Certified



Name and Title

Marios Demetriou
Assistant Superintendent,
Finance & Operations



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE170567

Pathways to Success Academic Campus							
Date of Sampling: August 2, 2017							
Sampler: Andrew Kelly							
Sample #	Location	Type ¹	Time Collected	EPA Action Level (ug/L) ²	Results (ug/L)	Aerator Present Y/N	Notes
Pathways - 01	Room 113, Classroom Faucet	CF	10:35 AM	15	3	Y	First Draw
Pathways - 02	Room 114, Kitchen Sink	KS	10:36 AM	15	7	Y	First Draw
Pathways - 03	Hallway Outside Gym, Left of Room 114, Left Water Cooler	WC	10:38 AM	15	ND ³	N	First Draw
Pathways - 04	Hallway Outside Room 402	B	10:43 AM	15	6	N	First Draw
Pathways - 05	Hallway Outside Room 208	WC	10:45 AM	15	ND	N	First Draw
Pathways - 06	Hallway Outside Room 200	B	10:48 AM	15	ND	N	First Draw
Pathways - 07	Hallway Between Men's and Women's Bathrooms, "Art Avenue"	B	10:52 AM	15	2	N	First Draw
Pathways - 08	Hallway Outside Room 310	B	10:55 AM	15	2	N	First Draw
Pathways - 09	Staff Lounge	KS	10:59 AM	15	ND	Y	First Draw
Pathways - 10	Gym/Lunch Room	WC	11:03 AM	15	ND	N	First Draw
Pathways - 11	Kitchen 3-Compartment Sink, Right Faucet	KS	11:06 AM	15	ND	Y	First Draw
Pathways - 12	Room 402, Kitchen Sink	KS	11:15 AM	15	4	Y	First Draw

1) Type: B = Bubblers, BT = Bottle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/tsble-regular-ed-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



**Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE170567**

Pattengill Elementary School							
Date of Sampling: 08/02/17							
Sampler: Andrew Kelly							
Sample #	Location	Type ¹	Time Collected	Lead EPA Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pattengill-01	Teachers Lounge sink	KS	8:40 AM	15	ND ³	Y	First Draw
Pattengill-02	Hallway Outside Music Room, Faucet	CF	8:42 AM	15	3	Y	First Draw
Pattengill-03	Hallway Outside Room C-8 Between Boy's and Girl's Restrooms, Water Cooler	WC	8:44 AM	15	2	N	First Draw
Pattengill-04	Hallway Outside Room A-1, Water Cooler	WC	8:47 AM	15	ND	N	First Draw
Pattengill-05	Room A-4 Bubbler	B	8:53 AM	15	7	N	First Draw
Pattengill-06	Room A-6 Faucet	CF	8:56 AM	15	7	Y	First Draw
Pattengill-07	Room A-8 Faucet	CF	9:00 AM	15	16	Y	First Draw
Pattengill-08	Room A-8 Bubbler	B	9:01 AM	15	ND	N	First Draw
Pattengill-09	Room A-7 Bubbler	B	9:03 AM	15	1	N	First Draw
Pattengill-10	Room B-16 Faucet	CF	2:57 PM	15	9	Y	First Draw
Pattengill-11	Room B-7 Faucet	CF	2:59 PM	15	4	Y	First Draw
Pattengill-12	Hallway Outside Room B-3, Water Cooler	WC	3:01 PM	15	ND	N	First Draw

Pattengill Elementary School							
Date of Sampling: 08/29/17							
Sampler: Benjamin Mark							
Sample #	Location	Type ¹	Time Collected	Lead EPA Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pattengill-07A	Room A-8 Faucet	CF	1:44 PM	15	1	Y	Follow-Up Flush

Pattengill Elementary School							
Date of Sampling: 08/30/17							
Sampler: Benjamin Mark							
Sample #	Location	Type ¹	Time Collected	Lead EPA Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pattengill-07B	Room A-8 Faucet	CF	7:19 AM	15	1	Y	Repeat First Draw

1) Type: B = Bubbler, BT = Bottle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

**Public Notification to Parents, Teachers, and Staff
Participation in School Drinking Water Quality Reimbursement Program**

School/District Name: Pioneer High School, Ann Arbor Public Schools

Date: 8/30/17

This School/District is committed to protecting the health of students, teachers, and staff. We are participating in the School Drinking Water Quality Reimbursement Program, which is a program jointly administered by the Michigan Department of Education and Department of Environmental Quality. This program is designed to provide school funding for costs associated with the mitigation of potential lead exposure from drinking water. Up to \$950 per school building is available on a reimbursement basis for the cost of testing for lead in drinking water, fixture replacement, filter purchases, plumbing assessments, or technical assistance incurred between July 1, 2016, and September 30, 2017.

The School Drinking Water Quality Reimbursement Program requires that schools submit proof of public notification of the number of fixtures providing water for drinking or food preparation, testing results, number of fixtures replaced, and other corrective action plans prior to reimbursement. This information is as follows:

Number of fixtures providing water for drinking or food preparation: 12

Number of fixtures replaced: (zero if not applicable) 0

Number of filters purchased: (zero if not applicable) 0

Other Actions Taken: (if applicable) _____

Testing Results:

Number of Lead Tests Completed: (zero if not applicable) 12

Number of Lead Tests with Over 5 parts per billion of Lead: (zero if not applicable) 3

Based upon actions taken to date:

The District/School has determined that additional corrective action is not necessary.

The District/School will be taking the following additional corrective action: _____

About Lead:


Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life.

How Can I Learn More?

You can see a copy of all water testing results at the school district's central office, and on our website at (<https://www.a2schools.org>). For more information about water quality in our schools, please contact (Physical Properties) at (734-994-8118). For information about water quality and sampling for lead at home, contact your local water supplier or the Michigan DEQ (www.michigan.gov/drinkingwater).

This Public Notification is being distributed through the following means: Posting in Common Areas of School Buildings; E-mail or Letter to Parents, Teachers and Staff; Posting on Website; Newsletter.

Signed and Certified



Name and Title

Marios Demetriou
Assistant Superintendent,
Finance & Operations



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE170567

Pioneer High School							
Date of Sampling: 08/03/17							
Sampler: Andrew Kelly							
Sample #	Location	Type ¹	Time Collected	Lead EPA Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pioneer-01	Hallway Outside Little Theatre, Water Cooler	WC	11:35 AM	15	ND ³	N	First Draw
Pioneer-02	Hallway to the Left of Auditorium, Across from Concessions, Water Cooler	WC	11:38 AM	15	ND	N	First Draw
Pioneer-03	Hallway Outside Room B-116, Bubbler	B	11:41 AM	15	ND	N	First Draw
Pioneer-04	Hallway Outside Room B-126 A, Bubbler	B	11:43 AM	15	7	N	First Draw
Pioneer-05	Hallway Outside Room S-105, Water Cooler	WC	11:50 AM	15	ND	N	First Draw
Pioneer-06	Cafeteria Prep Area Sink	KS	11:58 AM	15	ND	Y	First Draw
Pioneer-07	Hallway Outside Room C-110, Water Cooler	WC	11:59 AM	15	5	N	First Draw
Pioneer-08	Hallway Outside Room C-112, Bubbler	B	12:03 PM	15	4	N	First Draw
Pioneer-09	Hallway Outside Room C-125, Bubbler	B	12:07 PM	15	10	N	First Draw
Pioneer-10	Hallway Outside Room C-214, Bottle Fill	BT	12:10 PM	15	2	Y	First Draw
Pioneer-11	Hallway Outside Room C-310 Bubbler	B	12:13 PM	15	4	N	First Draw
Pioneer-12	Hallway Outside Room C-322, Water Cooler	WC	12:16 PM	15	8	N	First Draw

1) Type: B = Bubbler, BT = Bottle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

**Public Notification to Parents, Teachers, and Staff
Participation in School Drinking Water Quality Reimbursement Program**

School/District Name: Pittsfield Elementary, Ann Arbor Public Schools

Date: 8/30/17

This School/District is committed to protecting the health of students, teachers, and staff. We are participating in the School Drinking Water Quality Reimbursement Program, which is a program jointly administered by the Michigan Department of Education and Department of Environmental Quality. This program is designed to provide school funding for costs associated with the mitigation of potential lead exposure from drinking water. Up to \$950 per school building is available on a reimbursement basis for the cost of testing for lead in drinking water, fixture replacement, filter purchases, plumbing assessments, or technical assistance incurred between July 1, 2016, and September 30, 2017.

The School Drinking Water Quality Reimbursement Program requires that schools submit proof of public notification of the number of fixtures providing water for drinking or food preparation, testing results, number of fixtures replaced, and other corrective action plans prior to reimbursement. This information is as follows:

Number of fixtures providing water for drinking or food preparation: 12

Number of fixtures replaced: (zero if not applicable) 0

Number of filters purchased: (zero if not applicable) 0

Other Actions Taken: (if applicable) _____

Testing Results:

Number of Lead Tests Completed: (zero if not applicable) 12

Number of Lead Tests with Over 5 parts per billion of Lead: (zero if not applicable) 1

Based upon actions taken to date:

The District/School has determined that additional corrective action is not necessary.

The District/School will be taking the following additional corrective action: _____

About Lead:


Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life.

How Can I Learn More?

You can see a copy of all water testing results at the school district's central office, and on our website at (<https://www.a2schools.org>). For more information about water quality in our schools, please contact (Physical Properties) at (734-994-8118). For information about water quality and sampling for lead at home, contact your local water supplier or the Michigan DEQ (www.michigan.gov/drinkingwater).

This Public Notification is being distributed through the following means: Posting in Common Areas of School Buildings; E-mail or Letter to Parents, Teachers and Staff; Posting on Website; Newsletter.

Signed and Certified



Name and Title

Marios Demetriou
Assistant Superintendent,
Finance & Operations



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE170567

Pittsfield Elementary School							
Date of Sampling: August 1, 2017							
Sampler: Andrew Kelly							
Sample #	Location	Type ¹	Time Collected	Lead EPA Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pittsfield-01	Main Office, Clinic Sink	NS	12:11 PM	15	ND ³	Y	First Draw
Pittsfield-02	Staff Lounge, Kitchen Sink	KS	12:13 PM	15	ND	Y	First Draw
Pittsfield-03	Hallway Outside Room 101, Water Cooler	WC	12:15 PM	15	ND	N	First Draw
Pittsfield-04	Hallway Outside Room 106, Water Cooler	WC	12:18 PM	15	ND	N	First Draw
Pittsfield-05	Hallway Outside Gym, Water Cooler	WC	12:22 PM	15	ND	N	First Draw
Pittsfield-06	Room 115, Bubblers	B	12:27 PM	15	8	N	First Draw
Pittsfield-07	Room 101, Bubblers	B	12:33 PM	15	ND	N	First Draw
Pittsfield-08	Room 103, Bubblers	B	12:34 PM	15	ND	N	First Draw
Pittsfield-09	Room 106, Bubblers	B	12:35 PM	15	4	N	First Draw
Pittsfield-10	Room 107, Bubblers	B	12:37 PM	15	ND	N	First Draw
Pittsfield-11	Room 108, Bubblers	B	12:38 PM	15	ND	N	First Draw
Pittsfield-12	Room 109, Bubblers	B	12:40 PM	15	ND	N	First Draw

1) Type: B = Bubblers, BF = Bottle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

**Public Notification to Parents, Teachers, and Staff
Participation in School Drinking Water Quality Reimbursement Program**

School/District Name: Preschool and Family Center, Ann Arbor Public Schools

Date: 8/25/17

This School/District is committed to protecting the health of students, teachers, and staff. We are participating in the School Drinking Water Quality Reimbursement Program, which is a program jointly administered by the Michigan Department of Education and Department of Environmental Quality. This program is designed to provide school funding for costs associated with the mitigation of potential lead exposure from drinking water. Up to \$950 per school building is available on a reimbursement basis for the cost of testing for lead in drinking water, fixture replacement, filter purchases, plumbing assessments, or technical assistance incurred between July 1, 2016, and September 30, 2017.

The School Drinking Water Quality Reimbursement Program requires that schools submit proof of public notification of the number of fixtures providing water for drinking or food preparation, testing results, number of fixtures replaced, and other corrective action plans prior to reimbursement. This information is as follows:

Number of fixtures providing water for drinking or food preparation: 12

Number of fixtures replaced: (zero if not applicable) 0

Number of filters purchased: (zero if not applicable) 0

Other Actions Taken: (if applicable) _____

Testing Results:

Number of Lead Tests Completed: (zero if not applicable) 12

Number of Lead Tests with Over 5 parts per billion of Lead: (zero if not applicable) 2

Based upon actions taken to date:

The District/School has determined that additional corrective action is not necessary.

The District/School will be taking the following additional corrective action: _____

About Lead:


Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life.

How Can I Learn More?

You can see a copy of all water testing results at the school district's central office, and on our website at (<https://www.a2schools.org>). For more information about water quality in our schools, please contact (Physical Properties) at (734-994-8118). For information about water quality and sampling for lead at home, contact your local water supplier or the Michigan DEQ (www.michigan.gov/drinkingwater).

This Public Notification is being distributed through the following means: Posting in Common Areas of School Buildings; E-mail or Letter to Parents, Teachers and Staff; Posting on Website; Newsletter.

Signed and Certified



Name and Title

Marios Demetriou
Assistant Superintendent,
Finance & Operations



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE170567

Ann Arbor Preschool and Family Center							
Date of Sampling: August 2, 2017							
Sampler: Andrew Kelly							
Sample #	Location	Type ¹	Time Collected	EPA Action Level (ug/L) ²	Results (ug/L)	Aerator Present Y/N	Notes
PFC - 01	Orange Pod, Outside Room B112, Right Water Cooler	WC	11:40 AM	15	ND ³	N	First Draw
PFC - 02	Orange Pod, Room A102, Bubblers, Left Sink	B	11:43 AM	15	8	N	First Draw
PFC - 03	Orange Pod, Room A100 Bubblers, Right Sink	B	11:45 AM	15	7	N	First Draw
PFC - 04	Blue Pod, Room B102 Bubblers, Right Sink	B	11:48 AM	15	ND	N	First Draw
PFC - 05	Blue Pod, Room B105 Bubblers, Right Sink	B	11:52 AM	15	ND	N	First Draw
PFC - 06	Hallway Outside E100, Kitchen Sink 2-Compartment Sink	KS	12:03 PM	15	ND	Y	First Draw
PFC - 07	Orange Pod, Room A108 Bubblers, Left Sink	B	11:57 AM	15	ND	N	First Draw
PFC - 08	Yellow Pod, Room C102 Classroom Faucet, Left Sink	CF	12:07 PM	15	ND	Y	First Draw
PFC - 09	Yellow Pod, C106 Kitchen Sink, Near Door to Hallway	KS	12:10 PM	15	ND	Y	First Draw
PFC - 10	Teal Pod, D100 Bubblers, Right Sink	B	12:15 PM	15	ND	N	First Draw
PFC - 11	Teal Pod, D100 Classroom Faucet, Right Sink	CF	12:16 PM	15	1	Y	First Draw
PFC - 12	Teal Pod, D102 Bubblers, Left Sink	B	12:18 PM	15	ND	N	First Draw

1) Type: B = Bubblers, BF = Bottle Filling, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

**Public Notification to Parents, Teachers, and Staff
Participation in School Drinking Water Quality Reimbursement Program**

School/District Name: Scarlett Middle School, Ann Arbor Public Schools

Date: 8/30/17

This School/District is committed to protecting the health of students, teachers, and staff. We are participating in the School Drinking Water Quality Reimbursement Program, which is a program jointly administered by the Michigan Department of Education and Department of Environmental Quality. This program is designed to provide school funding for costs associated with the mitigation of potential lead exposure from drinking water. Up to \$950 per school building is available on a reimbursement basis for the cost of testing for lead in drinking water, fixture replacement, filter purchases, plumbing assessments, or technical assistance incurred between July 1, 2016, and September 30, 2017.

The School Drinking Water Quality Reimbursement Program requires that schools submit proof of public notification of the number of fixtures providing water for drinking or food preparation, testing results, number of fixtures replaced, and other corrective action plans prior to reimbursement. This information is as follows:

Number of fixtures providing water for drinking or food preparation: 12

Number of fixtures replaced: (zero if not applicable) 0

Number of filters purchased: (zero if not applicable) 0

Other Actions Taken: (if applicable) _____

Testing Results:

Number of Lead Tests Completed: (zero if not applicable) 12

Number of Lead Tests with Over 5 parts per billion of Lead: (zero if not applicable) 0

Based upon actions taken to date:

The District/School has determined that additional corrective action is not necessary.

The District/School will be taking the following additional corrective action: _____

About Lead:


Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life.

How Can I Learn More?

You can see a copy of all water testing results at the school district's central office, and on our website at (<https://www.a2schools.org>). For more information about water quality in our schools, please contact (Physical Properties) at (734-994-8118). For information about water quality and sampling for lead at home, contact your local water supplier or the Michigan DEQ (www.michigan.gov/drinkingwater).

This Public Notification is being distributed through the following means: Posting in Common Areas of School Buildings; E-mail or Letter to Parents, Teachers and Staff; Posting on Website; Newsletter.

Signed and Certified



Name and Title

Marios Demetriou
Assistant Superintendent,
Finance & Operations



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE170567

Scarlett Middle School							
Date of Sampling: 08/01/17							
Sampler: Andrew Kelly							
Sample #	Location	Type ¹	Time Collected	Lead EPA Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	Notes
Scarlett-01	Room 137 Classroom Faucet	CF	9:45 AM	15	ND ³	Y	First Draw
Scarlett-02	Hallway Outside Auditorium Left of Girls Bathroom, Water Cooler	WC	9:48 AM	15	ND	N	First Draw
Scarlett-03	Boys Locker Room Bubbler	B	9:53 AM	15	ND	N	First Draw
Scarlett-04	Main Lobby Water Cooler	WC	9:58 AM	15	ND	N	First Draw
Scarlett-05	Hallway Outside Media Center, Water Cooler	WC	10:06 AM	15	ND	N	First Draw
Scarlett-06	Hallway Outside Room 132, Right of Boys Bathroom, Bubbler	B	10:07 AM	15	ND	N	First Draw
Scarlett-07	Hallway Outside Room 216, Right of Boys Bathroom, Bubbler	B	10:08 AM	15	ND	N	First Draw
Scarlett-08	Room 226 West Side Kitchenette Sink Closest to Door	KS	10:31 AM	15	3	Y	First Draw
Scarlett-09	Room 228 Classroom Faucet	CF	10:40 AM	15	2	Y	First Draw
Scarlett-10	Bathroom Sink Outside RAHS - Left Bathroom	BF	10:43 AM	15	1	Y	First Draw
Scarlett-11	Main Office Clinic Sink	NS	10:48 AM	15	ND	Y	First Draw
Scarlett-12	Main Office Kitchenette Sink	KS	10:51 AM	15	ND	Y	First Draw

¹) Type: B = Bubbler, BF = Bathroom Sink, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
²) <http://www.epa.gov/your-drinking-water/cdr/lead-ugl-act-of-drinking-water-standards>
³) ND = Non Detected at Report of Detection Limit of 1 ug/L
⁴) NT = Not Tested

**Public Notification to Parents, Teachers, and Staff
Participation in School Drinking Water Quality Reimbursement Program**

School/District Name: Skyline High School, Ann Arbor Public Schools

Date: 8/30/17

This School/District is committed to protecting the health of students, teachers, and staff. We are participating in the School Drinking Water Quality Reimbursement Program, which is a program jointly administered by the Michigan Department of Education and Department of Environmental Quality. This program is designed to provide school funding for costs associated with the mitigation of potential lead exposure from drinking water. Up to \$950 per school building is available on a reimbursement basis for the cost of testing for lead in drinking water, fixture replacement, filter purchases, plumbing assessments, or technical assistance incurred between July 1, 2016, and September 30, 2017.

The School Drinking Water Quality Reimbursement Program requires that schools submit proof of public notification of the number of fixtures providing water for drinking or food preparation, testing results, number of fixtures replaced, and other corrective action plans prior to reimbursement. This information is as follows:

Number of fixtures providing water for drinking or food preparation: 12

Number of fixtures replaced: (zero if not applicable) 0

Number of filters purchased: (zero if not applicable) 0

Other Actions Taken: (if applicable) Follow up sampling performed

Testing Results:

Number of Lead Tests Completed: (zero if not applicable) 14

Number of Lead Tests with Over 5 parts per billion of Lead: (zero if not applicable) 0

Based upon actions taken to date:

The District/School has determined that additional corrective action is not necessary.

The District/School will be taking the following additional corrective action: _____

About Lead:


Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life.

How Can I Learn More?

You can see a copy of all water testing results at the school district's central office, and on our website at (<https://www.a2schools.org>). For more information about water quality in our schools, please contact (Physical Properties) at (734-994-8118). For information about water quality and sampling for lead at home, contact your local water supplier or the Michigan DEQ (www.michigan.gov/drinkingwater).

This Public Notification is being distributed through the following means: Posting in Common Areas of School Buildings; E-mail or Letter to Parents, Teachers and Staff; Posting on Website; Newsletter.

Signed and Certified



Name and Title

Marios Demetriou
Assistant Superintendent,
Finance & Operations



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE170567

Skyline High School							
Date of Sampling: July 26th, 2017							
Sampler: Amanda Peterson							
Sample #	Location	Type ¹	Time Collected	EPA Action Level (ug/L) ²	Results (ug/L)	Aerator Present Y/N	Notes
Skyline HS - 01	Water cooler in hallway to the left of Girl's bathroom outside of A227 Track	WC	10:01 AM	15	ND ³	N	First Draw
Skyline HS - 02	Right water cooler in hallway to the right of Boy's bathroom outside of A227 Track	WC	10:02 AM	15	ND	N	First Draw
Skyline HS - 03	Left water cooler in hallway to the right of Boy's bathroom outside of A227 track	WC	10:03 AM	15	ND	N	First Draw
Skyline HS - 04	Bottle Fill in hallway to the left of Girl's bathroom outside of A227 track	BT	10:20 AM	15	ND	N	First Draw
Skyline HS - 05	Staff Room A204d Kitchen Sink	KS	10:25 AM	15	3	Y	First Draw
Skyline HS - 06	4th Floor Admin Office kitchen sink	KS	10:33 AM	15	1	Y	First Draw
Skyline HS - 07	Water cooler next to bottle fill, left of B415 right of B417	WC	10:35 AM	15	ND	N	First Draw
Skyline HS - 08	Water cooler to the right of B416 and left of B418	WC	10:36 AM	15	ND	N	First Draw
Skyline HS - 09	3rd floor water cooler, left, between B317 & B315	WC	10:40 AM	15	1	N	First Draw
Skyline HS - 10	3rd Floor watercooler, right, between B317 & B315	WC	10:41 AM	15	31	N	First Draw
Skyline HS - 11	3rd floor water cooler, right, between B316 & B318	WC	10:45 AM	15	ND	N	First Draw
Skyline HS - 12	3rd Floor Admin Office B331	KS	10:46 AM	15	2	Y	First Draw

Skyline High School							
Date of Sampling: August 2, 2017							
Sampler: Andrew Kelly							
Sample #	Location	Type ¹	Time Collected	EPA Action Level (ug/L) ²	Results (ug/L)	Aerator Present Y/N	Notes
Skyline HS - 10A	3rd Floor watercooler, right, between B317 & B315	WC	4:17 PM	15	ND	N	Follow-Up Flush

1) Type: B = Bubblers, BT = Bottle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested



Ann Arbor Public Schools
Drinking Water Analysis
Project Number: AE170567

Skyline High School							
Date of Sampling: August 3, 2017							
Sampler: Andrew Kelly							
Sample #	Location	Type ¹	Time Collected	EPA Action Level (ug/L) ²	Results (ug/L)	Aerator Present Y/N	Notes
Skyline HS - 10B	3rd Floor watercooler, right, between B317 & B315	WC	8:08 AM	15	ND	N	Repeat First Draw

1) Type: B = Bubbler, BT = Bottle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
3) ND = Non Detected at Reported Detection Limit of 1 ug/L
4) NT = Not Tested

**Public Notification to Parents, Teachers, and Staff
Participation in School Drinking Water Quality Reimbursement Program**

School/District Name: Slauson Middle School, Ann Arbor Public Schools

Date: 8/30/17

This School/District is committed to protecting the health of students, teachers, and staff. We are participating in the School Drinking Water Quality Reimbursement Program, which is a program jointly administered by the Michigan Department of Education and Department of Environmental Quality. This program is designed to provide school funding for costs associated with the mitigation of potential lead exposure from drinking water. Up to \$950 per school building is available on a reimbursement basis for the cost of testing for lead in drinking water, fixture replacement, filter purchases, plumbing assessments, or technical assistance incurred between July 1, 2016, and September 30, 2017.

The School Drinking Water Quality Reimbursement Program requires that schools submit proof of public notification of the number of fixtures providing water for drinking or food preparation, testing results, number of fixtures replaced, and other corrective action plans prior to reimbursement. This information is as follows:

Number of fixtures providing water for drinking or food preparation: 12

Number of fixtures replaced: (zero if not applicable) 0

Number of filters purchased: (zero if not applicable) 0

Other Actions Taken: (if applicable) _____

Testing Results:

Number of Lead Tests Completed: (zero if not applicable) 12

Number of Lead Tests with Over 5 parts per billion of Lead: (zero if not applicable) 3

Based upon actions taken to date:

The District/School has determined that additional corrective action is not necessary.

The District/School will be taking the following additional corrective action: _____

About Lead:


Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life.

How Can I Learn More?

You can see a copy of all water testing results at the school district's central office, and on our website at (<https://www.a2schools.org>). For more information about water quality in our schools, please contact (Physical Properties) at (734-994-8118). For information about water quality and sampling for lead at home, contact your local water supplier or the Michigan DEQ (www.michigan.gov/drinkingwater).

This Public Notification is being distributed through the following means: Posting in Common Areas of School Buildings; E-mail or Letter to Parents, Teachers and Staff; Posting on Website; Newsletter.

Signed and Certified



Name and Title

Marios Demetriou
Assistant Superintendent,
Finance & Operations



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE170567

Slauson Middle School							
Date of Sampling: July 26th, 2017							
Sampler: Amanda Peterson							
Sample #	Location	Type ¹	Time Collected	EPA Action Level (ug/L) ²	Results (ug/L)	Aerator Present Y/N	Notes
Slauson MS - 01	Water Cooler in Gym Left of Girl's Locker Room	WC	11:15 AM	15	8	N	First Draw
Slauson MS - 02	Left Water Cooler to the Left of Room 248	WC	11:20 AM	15	11	N	First Draw
Slauson MS - 03	Right Water Cooler to the Left of Room 248	WC	11:21 AM	15	6	N	First Draw
Slauson MS - 04	Bubbler Across from Room 234 in Hallway	B	11:23 AM	15	2	N	First Draw
Slauson MS - 05	Bubbler to the Right of Room 205 in Hallway	B	11:25 AM	15	3	N	First Draw
Slauson MS - 06	Water Cooler in the Daniel Long Music Wing, Left of Bathroom 179a	WC	11:29 AM	15	1	N	First Draw
Slauson MS - 07	Water Cooler in the Daniel Long Music Wing, left of Boy's bathroom	WC	11:36 AM	15	2	N	First Draw
Slauson MS - 08	Water Cooler 3rd Floor Left of Room 348 in Hallway	WC	11:41 AM	15	2	N	First Draw
Slauson MS - 09	Bubbler in Hallway Across from Door 306	B	11:45 AM	15	4	N	First Draw
Slauson MS - 10	Bubbler in Hallway Across from Room 334	B	11:49 AM	15	1	N	First Draw
Slauson MS - 11	Water Cooler in Hallway Across from Room 121	WC	11:51 AM	15	ND ³	N	First Draw
Slauson MS - 12	Bubbler in Boy's Locker Room	B	12:00 PM	15	1	N	First Draw

1) Type: B = Bubbler, BT = Bottle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/table-regulate-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

**Public Notification to Parents, Teachers, and Staff
Participation in School Drinking Water Quality Reimbursement Program**

School/District Name: Steam @ Northside, Ann Arbor Public Schools

Date: 8/25/17

This School/District is committed to protecting the health of students, teachers, and staff. We are participating in the School Drinking Water Quality Reimbursement Program, which is a program jointly administered by the Michigan Department of Education and Department of Environmental Quality. This program is designed to provide school funding for costs associated with the mitigation of potential lead exposure from drinking water. Up to \$950 per school building is available on a reimbursement basis for the cost of testing for lead in drinking water, fixture replacement, filter purchases, plumbing assessments, or technical assistance incurred between July 1, 2016, and September 30, 2017.

The School Drinking Water Quality Reimbursement Program requires that schools submit proof of public notification of the number of fixtures providing water for drinking or food preparation, testing results, number of fixtures replaced, and other corrective action plans prior to reimbursement. This information is as follows:

Number of fixtures providing water for drinking or food preparation: 12

Number of fixtures replaced: (zero if not applicable) 1

Number of filters purchased: (zero if not applicable) 0

Other Actions Taken: (if applicable) Follow up sampling performed

Testing Results:

Number of Lead Tests Completed: (zero if not applicable) 18

Number of Lead Tests with Over 5 parts per billion of Lead: (zero if not applicable) 4

Based upon actions taken to date:

The District/School has determined that additional corrective action is not necessary.

The District/School will be taking the following additional corrective action: One fixture replaced and a follow-up sample collected.

About Lead:


Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life.

How Can I Learn More?

You can see a copy of all water testing results at the school district's central office, and on our website at (<https://www.a2schools.org>). For more information about water quality in our schools, please contact (Physical Properties) at (734-994-8118). For information about water quality and sampling for lead at home, contact your local water supplier or the Michigan DEQ (www.michigan.gov/drinkingwater).

This Public Notification is being distributed through the following means: Posting in Common Areas of School Buildings; E-mail or Letter to Parents, Teachers and Staff; Posting on Website; Newsletter.

Signed and Certified



Name and Title

Marios Demetriou
Assistant Superintendent,
Finance & Operations



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE170567

Ann Arbor STEAM @ Northside School							
Date of Sampling: July 27, 2017							
Sampler: Andrew Kelly							
Sample #	Location	Type ¹	Time Collected	Lead EPA Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	Notes
STEAM-01	Room 101 Bubblers	B	2:00 PM	15	30	N	First Draw
STEAM-02	Room 104 Bubblers	B	2:02 PM	15	ND	N	First Draw
STEAM-03	Staff Lounge	KS	2:05 PM	15	ND	Y	First Draw
STEAM-04	Room 503 Bubblers	B	2:08 PM	15	2	N	First Draw
STEAM-05	Room 401 Bubblers	B	2:11 PM	15	ND	N	First Draw
STEAM-06	Room 501 Bubblers	B	2:14 PM	15	33	N	First Draw
STEAM-07	Gymnasium Left Water Cooler	WC	2:16 PM	15	ND	N	First Draw
STEAM-08	Hallway Outside Gender Neutral Restrooms, Left Water Cooler	WC	2:17 PM	15	ND	N	First Draw
STEAM-09	Hallway Outside Servery	WC	2:21 PM	15	ND	N	First Draw
STEAM-10	MS-3 Classroom Faucet	CF	2:23 PM	15	110	Y	First Draw
STEAM-11	MS-2 Classroom Faucet	CF	2:24 PM	15	2	Y	First Draw
STEAM-12	Hallway Outside MS-1	WC	2:27 PM	15	1	N	First Draw

Ann Arbor STEAM @ Northside School							
Date of Sampling: August 15, 2017							
Sampler: Andrew Kelly							
Sample #	Location	Type ¹	Time Collected	Lead EPA Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	Notes
STEAM-01A	Room 101 Bubblers	B	12:35 PM	15	ND	N	Follow-up Flush
STEAM-06A	Room 501 Bubblers	B	12:20 PM	15	1	N	Follow-up Flush
STEAM-10A	MS-3 Classroom Faucet	CF	12:27 PM	15	5	Y	Follow-up Flush

Ann Arbor STEAM @ Northside School							
Date of Sampling: August 16, 2017							
Sampler: Amanda Peterson							
Sample #	Location	Type ¹	Time Collected	Lead EPA Action Level (ug/L) ²	Lead Results (ug/L)	Aerator Present Y/N	Notes
STEAM-01B	Room 101 Bubblers	B	9:44 AM	15	3	N	Repeat First Draw
STEAM-06B	Room 501 Bubblers	B	9:38 AM	15	5	N	Repeat First Draw
STEAM-10B	MS-3 Classroom Faucet	CF	9:50 AM	15	71	Y	Repeat First Draw

1) Type: B = Bubblers, BF = Bottle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/to-be-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

**Public Notification to Parents, Teachers, and Staff
Participation in School Drinking Water Quality Reimbursement Program**

School/District Name: Tappan Middle School, Ann Arbor Public Schools

Date: 8/30/17

This School/District is committed to protecting the health of students, teachers, and staff. We are participating in the School Drinking Water Quality Reimbursement Program, which is a program jointly administered by the Michigan Department of Education and Department of Environmental Quality. This program is designed to provide school funding for costs associated with the mitigation of potential lead exposure from drinking water. Up to \$950 per school building is available on a reimbursement basis for the cost of testing for lead in drinking water, fixture replacement, filter purchases, plumbing assessments, or technical assistance incurred between July 1, 2016, and September 30, 2017.

The School Drinking Water Quality Reimbursement Program requires that schools submit proof of public notification of the number of fixtures providing water for drinking or food preparation, testing results, number of fixtures replaced, and other corrective action plans prior to reimbursement. This information is as follows:

Number of fixtures providing water for drinking or food preparation: 12

Number of fixtures replaced: (zero if not applicable) 0

Number of filters purchased: (zero if not applicable) 0

Other Actions Taken: (if applicable) _____

Testing Results:

Number of Lead Tests Completed: (zero if not applicable) 12

Number of Lead Tests with Over 5 parts per billion of Lead: (zero if not applicable) 1

Based upon actions taken to date:

The District/School has determined that additional corrective action is not necessary.

The District/School will be taking the following additional corrective action: _____

About Lead:


Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life.

How Can I Learn More?

You can see a copy of all water testing results at the school district's central office, and on our website at (<https://www.a2schools.org>). For more information about water quality in our schools, please contact (Physical Properties) at (734-994-8118). For information about water quality and sampling for lead at home, contact your local water supplier or the Michigan DEQ (www.michigan.gov/drinkingwater).

This Public Notification is being distributed through the following means: Posting in Common Areas of School Buildings; E-mail or Letter to Parents, Teachers and Staff; Posting on Website; Newsletter.

Signed and Certified



Name and Title

Marios Demetriou
Assistant Superintendent,
Finance & Operations



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE170567

Tappan Middle School							
Date of Sampling: 8/2/2017							
Sampler: Andrew Kelly							
Sample #	Location	Type¹	Time Collected	EPA Action Level (ug/L)²	Results (ug/L)	Aerator Present Y/N	Notes
Tappan - 01	Hallway Outside Room 122, Water Cooler	WC	9:40 AM	15	ND ³	N	First Draw
Tappan - 02	Room 102 Classroom Faucet	CF	9:43 AM	15	ND	Y	First Draw
Tappan - 03	Hallway Outside Room 138, Water Cooler	WC	9:45 AM	15	11	N	First Draw
Tappan - 04	Cafeteria Water Cooler	WC	9:49 AM	15	3	N	First Draw
Tappan - 05	Hallway Outside Room 240, Water Cooler	WC	9:51 AM	15	4	N	First Draw
Tappan - 06	Hallway Outside Room 220, Water Cooler	WC	9:53 AM	15	ND	N	First Draw
Tappan - 07	Hallway Between Girl's and Boy's Bathrooms, East of Room 216, Water Cooler	WC	9:56 AM	15	ND	N	First Draw
Tappan - 08	Room 202 Classroom Faucet	CF	9:59 AM	15	ND	Y	First Draw
Tappan - 09	Hallway Outside Room 288, Water Cooler	WC	10:03 AM	15	ND	N	First Draw
Tappan - 10	Room 304 Classroom Faucet	CF	10:05 AM	15	3	Y	First Draw
Tappan - 11	Hallway Between Girl's and Boy's Bathrooms, West of Room 308, Water Cooler	WC	10:07 AM	15	1	N	First Draw
Tappan - 12	Hallway Outside Room 320, Water Cooler	WC	10:09 AM	15	4	N	First Draw

¹ Type: B = Bubble, BT = Ball Tip, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NT = Nurse Sink
² https://www.epa.gov/your-drinking-water/for-business/public-drinking-water-standards-report
³ ND = Non Detected or Report of Detection <= 1 ug/L
⁴ NT = Not Tested

**Public Notification to Parents, Teachers, and Staff
Participation in School Drinking Water Quality Reimbursement Program**

School/District Name: Thurston Elementary, Ann Arbor Public Schools

Date: 8/30/17

This School/District is committed to protecting the health of students, teachers, and staff. We are participating in the School Drinking Water Quality Reimbursement Program, which is a program jointly administered by the Michigan Department of Education and Department of Environmental Quality. This program is designed to provide school funding for costs associated with the mitigation of potential lead exposure from drinking water. Up to \$950 per school building is available on a reimbursement basis for the cost of testing for lead in drinking water, fixture replacement, filter purchases, plumbing assessments, or technical assistance incurred between July 1, 2016, and September 30, 2017.

The School Drinking Water Quality Reimbursement Program requires that schools submit proof of public notification of the number of fixtures providing water for drinking or food preparation, testing results, number of fixtures replaced, and other corrective action plans prior to reimbursement. This information is as follows:

Number of fixtures providing water for drinking or food preparation: 12

Number of fixtures replaced: (zero if not applicable) 0

Number of filters purchased: (zero if not applicable) 0

Other Actions Taken: (if applicable) _____

Testing Results:

Number of Lead Tests Completed: (zero if not applicable) 12

Number of Lead Tests with Over 5 parts per billion of Lead: (zero if not applicable) 0

Based upon actions taken to date:

The District/School has determined that additional corrective action is not necessary.

The District/School will be taking the following additional corrective action: _____

About Lead:

Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life.

How Can I Learn More?

You can see a copy of all water testing results at the school district's central office, and on our website at (<https://www.a2schools.org>). For more information about water quality in our schools, please contact (Physical Properties) at (734-994-8118). For information about water quality and sampling for lead at home, contact your local water supplier or the Michigan DEQ (www.michigan.gov/drinkingwater).

This Public Notification is being distributed through the following means: Posting in Common Areas of School Buildings; E-mail or Letter to Parents, Teachers and Staff; Posting on Website; Newsletter.

Signed and Certified



Name and Title

Marios Demetriou
Assistant Superintendent,
Finance & Operations



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE170567

Thurston Elementary School							
Date of Sampling: July 28th, 2017							
Sampler: Amanda Peterson							
Sample #	Location	Type ¹	Time Collected	EPA Action Level (ug/L) ²	Results (ug/L)	Aerator Present Y/N	Notes
Thurston ES-01	Water Cooler, in Hallway, in Front of Custodian Lounge	WC	9:00 AM	15	ND ³	N	First Draw
Thurston ES-02	Teachers Lounge Kitchenette, Two Compartment Sink	KS	9:02 AM	15	1	Y	First Draw
Thurston ES-03	Left Water Cooler, in Hallway, to the Left of Office	WC	9:05 AM	15	1	N	First Draw
Thurston ES-04	Right Water Cooler, in Hallway, to the Left of Office	WC	9:06 AM	15	ND	N	First Draw
Thurston ES-05	Left Water Cooler, in Hallway, Left of Multipurpose Room D103	WC	9:09 AM	15	ND	N	First Draw
Thurston ES-06	Right Water Cooler, in Hallway, Left of Multipurpose Room D103	WC	9:10 AM	15	ND	N	First Draw
Thurston ES-07	Room 2, Right Bubblers	B	9:14 AM	15	2	N	First Draw
Thurston ES-08	Room 3, Right bubbler	B	9:16 AM	15	ND	N	First Draw
Thurston ES-09	Room 4, Right Bubblers	B	9:18 AM	15	ND	N	First Draw
Thurston ES-10	Room 8, Right Bubblers	B	9:20 AM	15	ND	N	First Draw
Thurston ES-11	Room 9, Right Bubblers	B	9:23 AM	15	2	N	First Draw
Thurston ES-12	Room 10, Right Bubblers	B	9:25 AM	15	1	N	First Draw

1) Type: B = Bubblers, BT = Bottle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested

**Public Notification to Parents, Teachers, and Staff
Participation in School Drinking Water Quality Reimbursement Program**

School/District Name: Wines Elementary, Ann Arbor Public Schools

Date: 8/30/17

This School/District is committed to protecting the health of students, teachers, and staff. We are participating in the School Drinking Water Quality Reimbursement Program, which is a program jointly administered by the Michigan Department of Education and Department of Environmental Quality. This program is designed to provide school funding for costs associated with the mitigation of potential lead exposure from drinking water. Up to \$950 per school building is available on a reimbursement basis for the cost of testing for lead in drinking water, fixture replacement, filter purchases, plumbing assessments, or technical assistance incurred between July 1, 2016, and September 30, 2017.

The School Drinking Water Quality Reimbursement Program requires that schools submit proof of public notification of the number of fixtures providing water for drinking or food preparation, testing results, number of fixtures replaced, and other corrective action plans prior to reimbursement. This information is as follows:

Number of fixtures providing water for drinking or food preparation: 12

Number of fixtures replaced: (zero if not applicable) 1

Number of filters purchased: (zero if not applicable) 0

Other Actions Taken: (if applicable) Follow up sampling performed

Testing Results:

Number of Lead Tests Completed: (zero if not applicable) 16

Number of Lead Tests with Over 5 parts per billion of Lead: (zero if not applicable) 4

Based upon actions taken to date:

 The District/School has determined that additional corrective action is not necessary.

 X The District/School will be taking the following additional corrective action: One fixture replaced and follow-up sampling conducted.

About Lead:


Lead can cause serious health problems if too much enters your body from drinking water or other sources. It can cause damage to the brain and kidneys, and it can interfere with the production of red blood cells that carry oxygen to all parts of your body. The greatest risk of lead exposure is to infants, young children, and pregnant women. Scientists have linked the effects of lead on the brain with lowered IQ in children. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults. Lead is stored in the bones, and it can be released later in life.

How Can I Learn More?

You can see a copy of all water testing results at the school district's central office, and on our website at (<https://www.a2schools.org>). For more information about water quality in our schools, please contact (Physical Properties) at (734-994-8118). For information about water quality and sampling for lead at home, contact your local water supplier or the Michigan DEQ (www.michigan.gov/drinkingwater).

This Public Notification is being distributed through the following means: () Posting in Common Areas of School Buildings; () E-mail or Letter to Parents, Teachers and Staff; (X) Posting on Website; () Newsletter.

Signed and Certified



Name and Title

Marios Demetriou
Assistant Superintendent,
Finance & Operations



Ann Arbor Public Schools
 Drinking Water Analysis
 Project Number: AE170567

Wines Elementary School							
Date of Sampling: July 26th, 2017							
Sampler: Amanda Peterson							
Sample #	Location	Type ¹	Time Collected	EPA Action Level (ug/L) ²	Results (ug/L)	Aerator Present Y/N	Notes
Wines ES-01	Room 112, Right Bubbler	B	12:24 PM	15	4	N	First Draw
Wines ES-02	Room 114, Right Bubbler	B	12:26 PM	15	8	N	First Draw
Wines ES-03	Room 116, Right Bubbler	B	12:28 PM	15	12	N	First Draw
Wines ES-04	Room 115, Right Bubbler	B	12:29 PM	15	6	N	First Draw
Wines ES-05	Room 117, Right Bubbler	B	12:30 PM	15	4	N	First Draw
Wines ES-06	Room 118, Right Bubbler	B	12:31 PM	15	42	N	First Draw
Wines ES-07	Room 119, Right Bubbler	B	12:33 PM	15	ND ³	N	First Draw
Wines ES-08	Room 120, Right Bubbler	B	12:38 PM	15	1	N	First Draw
Wines ES-09	Water Cooler, in Hallway, Across from Gymnasium	WC	12:49 PM	15	ND	N	First Draw
Wines ES-10	Teachers Lounge, Left Faucet	CF	12:52 PM	15	17	Y	First Draw
Wines ES-11	Kitchen, Two Compartment Sink	KS	12:55 PM	15	2	Y	First Draw
Wines ES-12	Kitchen, Three Compartment Sink	KS	12:56 PM	15	4	Y	First Draw

Wines Elementary School							
Date of Sampling: August 2, 2017							
Sampler: Andrew Kelly							
Sample #	Location	Type ¹	Time Collected	EPA Action Level (ug/L) ²	Results (ug/L)	Aerator Present Y/N	Notes
Wines ES-06A	Room 118, Right Bubbler	B	4:55 PM	15	ND	N	Follow-Up Flush
Wines ES-10A	Teachers Lounge, Left Faucet	CF	4:51 PM	15	2	Y	Follow-Up Flush

Wines Elementary School							
Date of Sampling: August 3, 2017							
Sampler: Andrew Kelly							
Sample #	Location	Type ¹	Time Collected	EPA Action Level (ug/L) ²	Results (ug/L)	Aerator Present Y/N	Notes
Wines ES-06B	Room 118, Right Bubbler	B	9:03 AM	15	3	N	Repeat First Draw
Wines ES-10B	Teachers Lounge, Left Faucet	CF	9:00 AM	15	82	Y	Repeat First Draw

1) Type: B = Bubbler, BT = Bottle Fill, WC = Water Cooler, CF = Classroom Faucet, KS = Kitchen Sink, NS = Nurse Sink
 2) <https://www.epa.gov/your-drinking-water/to-ble-regulated-drinking-water-constituents>
 3) ND = Non Detected at Reported Detection Limit of 1 ug/L
 4) NT = Not Tested