



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

Pattengill Elementary School							
Date of Sampling: January 29, 2022							
Sampler: Victoria Vo							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pattengill-15	Hallway, Outside Room A-1, Hydration Station, Bottle Fill	HS	3:39 PM	5	ND ³	Y	First Draw, Filtered.
Pattengill-58	Cafeteria Kitchen, Combination Sink, Glass Filler	C	3:33 PM	5	ND	N	First Draw, Filtered.
Pattengill-20	Hallway, Outside Room B-3, Hydration Station, Bottle Fill	HS	3:15 PM	5	ND	Y	First Draw, Filtered.
Pattengill-21	Teacher's Lounge, Combination Sink, Glass Filler	C	3:13 PM	5	ND	N	First Draw, Filtered.
Pattengill-28	Room B-6, Combination Sink, Glass Filler	C	3:22 PM	5	ND	N	First Draw, Filtered.
Pattengill-33	Room B-9, Combination Sink, Glass Filler	C	3:28 PM	5	ND	N	First Draw, Filtered.

- 1) Type: B = Bubblers, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminants>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

Pattengill Elementary School							
Date of Sampling: January 29, 2022							
Sampler: Victoria Vo							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Pattengill-37	Room B-12, Combination Sink, Glass Filler	C	3:25 PM	5	ND	N	First Draw, Filtered.
Pattengill-40	Room B-17, Combination Sink, Glass Filler	C	3:18 PM	5	ND	N	First Draw, Filtered.
Pattengill-46	Room A-3, Combination Sink, Glass Filler	C	3:41 PM	5	ND	N	First Draw, Filtered.
Pattengill-50	Room A-6, Combination Sink, Glass Filler	C	3:44 PM	5	ND	N	First Draw, Filtered.

- 1) Type: B = Bubler, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb