



**Ann Arbor Public Schools  
Lead Drinking Water Analysis  
Project Number: AE220030**

STEAM at Northside							
Date of Sampling: January 23, 2022							
Sampler: Sabrina Fouche							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
STEAM - 01	Room 101, Combination Sink, Glass Filler	C	11:26 AM	5	ND <sup>3</sup>	N	First Draw, Filtered.
STEAM - 05	Room 401, Combination Sink, Glass Filler	C	11:41 AM	5	ND	N	First Draw, Filtered.
STEAM - 13	Room K-3, Combinaton Sink, Bottle Fill	C	11:30 AM	5	ND	N	First Draw, Filtered.
STEAM - 23	Room K-1, Combinaton Sink, Glass Filler	C	11:21 AM	5	ND	N	First Draw, Filtered.
STEAM - 31	Room 502, Combinaton Sink, Glass Filler	C	11:37 AM	5	ND	N	First Draw, Filtered.
STEAM - 42	Hallway, Outside Kitchen, Hydration Station, Bottle Fill	HS	11:43 AM	5	ND	Y	First Draw, Filtered.
STEAM - 46	Room 303, Combinaton Sink, Glass Filler	C	11:47 AM	5	ND	N	First Draw, Filtered.
STEAM - 52	Room 203, Combinaton Sink, Glass Filler	C	11:51 AM	5	ND	N	First Draw, Filtered.
STEAM - 56	Room 201, Combinaton Sink, Glass Filler	C	11:53 AM	5	ND	N	First Draw, Filtered.

- 1) Type: B = Bubblers, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools**  
**Lead Drinking Water Analysis**  
**Project Number: AE220030**

STEAM at Northside							
Date of Sampling: January 23, 2022							
Sampler: Sabrina Fouche							
Sample #	Location	Type <sup>1</sup>	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
STEAM - 66	Hallway, Outside Teachers Lounge, Hydration Station, Bottle Fill	HS	11:33 AM	5	ND	Y	First Draw, Filtered.

- 1) Type: B = Bubblers, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb