



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

Tappan Middle School							
Date of Sampling: January 29, 2022							
Sampler: Sabrina Fouche							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Tappan-10	Room 304, Combination Sink, Glass Filler	C	12:17 PM	5	ND ³	Y	First Draw, Filtered.
Tappan-19	Pool, Bubbler on East Wall & Boys Locker Room, Porcelian, Glass Filler	B	12:39 PM	5	ND	N	First Draw, Filtered.
Tappan-23	Room 191, Refridgerated, Glass Filler	GF	12:45 PM	5	ND	Y	First Draw, Filtered.
Tappan-30	Media Center, Combination Sink, Glass Filler	C	12:10 PM	5	ND	Y	First Draw, Filtered.
Tappan-33	Room 204, Combination Sink, Glass Filler	C	12:30 PM	5	ND	Y	First Draw, Filtered.
Tappan-49	Hallway, Outside Room 138, Hydration Station, Bottle Fill	HS	12:35 PM	5	ND	Y	First Draw, Filtered.
Tappan-53	Hallway, Adjacent to Boiler Room Across Stairwell, Hydration Station, Bottle Fill	HS	12:32 PM	5	ND	Y	First Draw, Filtered.

- 1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb



**Ann Arbor Public Schools
Lead Drinking Water Analysis
Project Number: AE220030**

Tappan Middle School							
Date of Sampling: January 29, 2022							
Sampler: Sabrina Fouche							
Sample #	Location	Type ¹	Time Collected	Internal Action Level (ug/L)	Lead Results (ug/L)	Aerator Present Y/N	Notes
Tappan-16	Kitchen, 2-Compartment Sink, Far Right Faucet, Kitchen Faucet	KF	12:56 PM	5	ND	Y	First Draw, Filtered.
Tappan-20	Girl's Locker Room, Porcelain, Glass Filler	GF	12:59 PM	5	ND	Y	First Draw, Filtered.
Tappan-13	Nurse's Clinic, Combination Sink, Glass Filler	C	1:03 PM	5	ND	Y	First Draw, Filtered.

- 1) Type: B = Bubbler, HS = Hydration Station, BT = Single Bottle Fill, G = Glass Filler, WC = Water Cooler, C = Combination Sink,
- 2) PB = Potable Bathroom Faucet, F = Faucet, KF = Kitchen Faucet, I = Ice Machine, KK = Kitchen Kettle, PC = Plumbed Coffee Machine
- 3) <https://www.epa.gov/your-drinking-water/table-regulated-drinking-water-contaminant>
- 4) ND = Non Detected at Reported Detection Limit of 1 ug/L
- 5) NT = Not Tested

Action Level >5ppb