

Site Radon Inspection Report

Date : 11/21/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Oakdale M.S. Main
Test Location: 815 South Oakdale Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2913664 Test Start : 11/14/2023 @ 06:15
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 06:53
Location : 1st FL=101 Auditorium 1 Received: 11/21/2023 @ 09:42
Radon Level : 2.8 pCi/L Analyzed: 11/21/2023 @ 12:56
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2896375 Test Start : 11/14/2023 @ 06:15
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 06:54
Location : 1st FL=101 Aud. 3 DP Received: 11/21/2023 @ 09:42
Radon Level : 2.4 pCi/L Analyzed: 11/21/2023 @ 10:39
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2989247 Test Start : 11/14/2023 @ 06:15
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 06:54
Location : 1st FL=101 Aud. 3 DP Received: 11/21/2023 @ 09:42
Radon Level : 3.4 pCi/L Analyzed: 11/21/2023 @ 09:52

Average of Side by Side Canisters 2.9 pCi/L
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2896346 Test Start : 11/14/2023 @ 06:16
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 06:54
Location : 1st FL=101 Auditorium 2 Received: 11/21/2023 @ 09:42
Radon Level : 2.9 pCi/L Analyzed: 11/21/2023 @ 12:56
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2989241 Test Start : 11/14/2023 @ 06:21
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 06:55
Location : Bsmt=101 Under Stage 1 Received: 11/21/2023 @ 09:42
Radon Level : 2.4 pCi/L Analyzed: 11/21/2023 @ 10:39
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2989252 Test Start : 11/14/2023 @ 06:22
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 06:55
Location : Bsmt=101 Under Stage 2 Received: 11/21/2023 @ 09:42
Radon Level : 3.4 pCi/L Analyzed: 11/21/2023 @ 13:09



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/21/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Oakdale M.S. Main
Test Location: 815 South Oakdale Avenue
Medford, OR 97501-

Individual Canister Results

Error for Measurement is: \pm 0.5 pCi/L

Canister ID# :	2896368	Test Start :	11/14/2023 @ 06:22
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/16/2023 @ 06:56
Location :	Bsmt=101 Under Stage 3	Received:	11/21/2023 @ 09:42
Radon Level :	3.1 pCi/L	Analyzed:	11/21/2023 @ 12:07
Error for Measurement is: \pm	0.5 pCi/L		

Canister ID# :	2896341	Test Start :	11/14/2023 @ 06:27
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/16/2023 @ 06:58
Location :	1st FL = 100 Room	Received:	11/21/2023 @ 09:42
Radon Level :	1.2 pCi/L	Analyzed:	11/21/2023 @ 13:13
Error for Measurement is: \pm	0.5 pCi/L		

Canister ID# :	2989240	Test Start :	11/14/2023 @ 06:28
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/16/2023 @ 06:59
Location :	1st FL = 102 Room	Received:	11/21/2023 @ 09:42
Radon Level :	1.1 pCi/L	Analyzed:	11/21/2023 @ 10:59
Error for Measurement is: \pm	0.5 pCi/L		

Canister ID# :	2913721	Test Start :	11/14/2023 @ 06:29
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/16/2023 @ 06:59
Location :	1st FL = 104 Room	Received:	11/21/2023 @ 09:42
Radon Level :	1.0 pCi/L	Analyzed:	11/21/2023 @ 13:26
Error for Measurement is: \pm	0.4 pCi/L		

Canister ID# :	2913346	Test Start :	11/14/2023 @ 06:29
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/16/2023 @ 07:00
Location :	1st FL = 106 Room	Received:	11/21/2023 @ 09:42
Radon Level :	1.6 pCi/L	Analyzed:	11/21/2023 @ 13:13
Error for Measurement is: \pm	0.5 pCi/L		

Canister ID# :	2913744	Test Start :	11/14/2023 @ 06:33
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/16/2023 @ 07:00
Location :	1st FL = 108 Room	Received:	11/21/2023 @ 09:42
Radon Level :	1.3 pCi/L	Analyzed:	11/21/2023 @ 09:36
Error for Measurement is: \pm	0.5 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/21/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Oakdale M.S. Main
Test Location: 815 South Oakdale Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2896340 Test Start : 11/14/2023 @ 06:34
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:01
Location : 1st FL = 110 Room Received: 11/21/2023 @ 09:42
Radon Level : 1.5 pCi/L Analyzed: 11/21/2023 @ 13:33
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2913379 Test Start : 11/14/2023 @ 06:35
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:01
Location : 1st FL = 110-A Room Received: 11/21/2023 @ 09:42
Radon Level : 1.5 pCi/L Analyzed: 11/21/2023 @ 13:09
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2990059 Test Start : 11/14/2023 @ 06:36
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:02
Location : 1st FL = 112 Room Received: 11/21/2023 @ 09:42
Radon Level : 1.5 pCi/L Analyzed: 11/21/2023 @ 12:42
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2896347 Test Start : 11/14/2023 @ 06:37
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:03
Location : 1st FL = 114 Room Received: 11/21/2023 @ 09:42
Radon Level : 0.4 pCi/L Analyzed: 11/21/2023 @ 12:56
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2989323 Test Start : 11/14/2023 @ 06:39
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:04
Location : 1st FL = 116 Room Received: 11/21/2023 @ 09:42
Radon Level : 0.8 pCi/L Analyzed: 11/21/2023 @ 10:56
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2913746 Test Start : 11/14/2023 @ 06:40
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:05
Location : 1st FL = 116 Rm BLANK Received: 11/21/2023 @ 09:42
Radon Level : 0.1 pCi/L Analyzed: 11/21/2023 @ 12:17
Error for Measurement is: ± 0.1 pCi/L



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/21/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Oakdale M.S. Main
Test Location: 815 South Oakdale Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2913703 Test Start : 11/14/2023 @ 06:41
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:05
Location : 1st FL = 118 Room Received: 11/21/2023 @ 09:42
Radon Level : 0.8 pCi/L Analyzed: 11/21/2023 @ 10:56
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2896336 Test Start : 11/14/2023 @ 06:42
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:06
Location : 1st FL = 120 Room Received: 11/21/2023 @ 09:42
Radon Level : 0.5 pCi/L Analyzed: 11/21/2023 @ 09:52
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2913726 Test Start : 11/14/2023 @ 06:43
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:06
Location : 1st FL = 122 Room Received: 11/21/2023 @ 09:42
Radon Level : 0.9 pCi/L Analyzed: 11/21/2023 @ 12:42
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2913369 Test Start : 11/14/2023 @ 06:44
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:08
Location : 1st FL = 124 Room Received: 11/21/2023 @ 09:42
Radon Level : 0.7 pCi/L Analyzed: 11/21/2023 @ 12:20
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2913733 Test Start : 11/14/2023 @ 06:45
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:09
Location : 1st FL = 126 Room Received: 11/21/2023 @ 09:42
Radon Level : 0.2 pCi/L Analyzed: 11/21/2023 @ 13:30
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2989200 Test Start : 11/14/2023 @ 06:47
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:10
Location : 1st FL = 128 Room Received: 11/21/2023 @ 09:42
Radon Level : 1.0 pCi/L Analyzed: 11/21/2023 @ 12:00
Error for Measurement is: \pm 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/21/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Oakdale M.S. Main
Test Location: 815 South Oakdale Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2913761 Test Start : 11/14/2023 @ 06:49
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:12
Location : 1st FL = 103 Room Received: 11/21/2023 @ 09:42
Radon Level : 1.2 pCi/L Analyzed: 11/21/2023 @ 13:09
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2899240 Test Start : 11/14/2023 @ 06:50
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:12
Location : 1st FL = 105 Room Received: 11/21/2023 @ 09:42
Radon Level : 0.3 pCi/L Analyzed: 11/21/2023 @ 09:29
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2989304 Test Start : 11/14/2023 @ 06:52
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:13
Location : 1st FL = 107 Room Received: 11/21/2023 @ 09:42
Radon Level : 1.9 pCi/L Analyzed: 11/21/2023 @ 13:16
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2913757 Test Start : 11/14/2023 @ 06:53
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:14
Location : 1st FL = 109 Room Received: 11/21/2023 @ 09:42
Radon Level : 1.9 pCi/L Analyzed: 11/21/2023 @ 13:26
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2989324 Test Start : 11/14/2023 @ 06:53
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:15
Location : 1st FL = 111 Room Received: 11/21/2023 @ 09:42
Radon Level : 2.0 pCi/L Analyzed: 11/21/2023 @ 09:29
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2913717 Test Start : 11/14/2023 @ 06:54
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:15
Location : 1st FL = 113 Room Received: 11/21/2023 @ 09:42
Radon Level : 1.1 pCi/L Analyzed: 11/21/2023 @ 09:36
Error for Measurement is: ± 0.4 pCi/L



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/21/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Oakdale M.S. Main
Test Location: 815 South Oakdale Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2896339 Test Start : 11/14/2023 @ 06:55
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:16
Location : 1st FL = 115 Room Received: 11/21/2023 @ 09:42
Radon Level : 1.4 pCi/L Analyzed: 11/21/2023 @ 13:33
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2913756 Test Start : 11/14/2023 @ 06:56
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:17
Location : 1st FL = 117 Media 1 Received: 11/21/2023 @ 09:42
Radon Level : 0.9 pCi/L Analyzed: 11/21/2023 @ 09:53
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2913702 Test Start : 11/14/2023 @ 06:56
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:17
Location : 1st FL = 117 Media 2 Received: 11/21/2023 @ 09:42
Radon Level : 1.2 pCi/L Analyzed: 11/21/2023 @ 12:20
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2913748 Test Start : 11/14/2023 @ 06:57
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:18
Location : 1st FL = 117 Media 3 Received: 11/21/2023 @ 09:42
Radon Level : 0.9 pCi/L Analyzed: 11/21/2023 @ 12:20
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2913343 Test Start : 11/14/2023 @ 06:58
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:19
Location : 1st FL = 119 Room Received: 11/21/2023 @ 09:42
Radon Level : 1.3 pCi/L Analyzed: 11/21/2023 @ 12:23
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2896363 Test Start : 11/14/2023 @ 07:00
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:21
Location : 1st FL = 130 Room Received: 11/21/2023 @ 09:42
Radon Level : 0.5 pCi/L Analyzed: 11/21/2023 @ 12:17
Error for Measurement is: ± 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/21/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Oakdale M.S. Main
Test Location: 815 South Oakdale Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2913685 Test Start : 11/14/2023 @ 07:02
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:22
Location : 1st FL = 132 Room DP Received: 11/21/2023 @ 09:42
Radon Level : 0.8 pCi/L Analyzed: 11/21/2023 @ 09:33
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2913709 Test Start : 11/14/2023 @ 07:02
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:22
Location : 1st FL = 132 Room DP Received: 11/21/2023 @ 09:42
Radon Level : 0.9 pCi/L Analyzed: 11/21/2023 @ 13:30

Average of Side by Side Canisters 0.9 pCi/L
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2913764 Test Start : 11/14/2023 @ 07:03
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:23
Location : 1st FL = 134 Room Received: 11/21/2023 @ 09:42
Radon Level : 1.4 pCi/L Analyzed: 11/21/2023 @ 13:26
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2913731 Test Start : 11/14/2023 @ 07:03
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:23
Location : 1st FL = 136 Room Received: 11/21/2023 @ 09:42
Radon Level : 1.4 pCi/L Analyzed: 11/21/2023 @ 12:23
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2896361 Test Start : 11/14/2023 @ 07:06
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:24
Location : 1st FL = 138 Room Received: 11/21/2023 @ 09:42
Radon Level : 1.6 pCi/L Analyzed: 11/21/2023 @ 12:59
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2896349 Test Start : 11/14/2023 @ 07:06
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:26
Location : 1st FL = 138-A Rm Off.A Received: 11/21/2023 @ 09:42
Radon Level : 0.9 pCi/L Analyzed: 11/21/2023 @ 12:52



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/21/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Oakdale M.S. Main
Test Location: 815 South Oakdale Avenue
Medford, OR 97501-

Individual Canister Results

Error for Measurement is: ± 0.4 pCi/L

Canister ID# :	2896377	Test Start :	11/14/2023 @ 07:07
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/16/2023 @ 07:27
Location :	1st FL = 138-B Rm Off.B	Received:	11/21/2023 @ 09:42
Radon Level :	1.4 pCi/L	Analyzed:	11/21/2023 @ 12:42
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	2913695	Test Start :	11/14/2023 @ 07:08
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/16/2023 @ 07:28
Location :	1st FL = 141 Room	Received:	11/21/2023 @ 09:42
Radon Level :	1.7 pCi/L	Analyzed:	11/21/2023 @ 12:59
Error for Measurement is: ±	0.5 pCi/L		

Canister ID# :	2913373	Test Start :	11/14/2023 @ 07:09
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/16/2023 @ 07:28
Location :	1st FL = 142 Room DP	Received:	11/21/2023 @ 09:42
Radon Level :	0.7 pCi/L	Analyzed:	11/21/2023 @ 12:23
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	2913715	Test Start :	11/14/2023 @ 07:09
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/16/2023 @ 07:28
Location :	1st FL = 142 Room DP	Received:	11/21/2023 @ 09:42
Radon Level :	0.4 pCi/L	Analyzed:	11/21/2023 @ 09:36

Average of Side by Side Canisters 0.6 pCi/L

Error for Measurement is: ± 0.4 pCi/L

Canister ID# :	2913767	Test Start :	11/14/2023 @ 07:10
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/16/2023 @ 07:30
Location :	1st FL = 142-B Room	Received:	11/21/2023 @ 09:42
Radon Level :	27.3 pCi/L	Analyzed:	11/21/2023 @ 13:13
Error for Measurement is: ±	0.9 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/21/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Oakdale M.S. Main
Test Location: 815 South Oakdale Avenue
Medford, OR 97501-

Individual Canister Results

The results indicate that at least one testing device registered at or above the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends mitigation if the average of two short-term tests taken in the lowest level of the building suitable for occupancy show radon levels that are equal to or greater than 4.0 pCi/L.

For information on how to reduce radon levels in your home, please review the EPA booklet: Consumer's Guide to Radon Reduction (www.epa.gov/radon/pdfs/consguid.pdf) and contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.



Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201