

Site Radon Inspection Report

Date : 11/21/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Annex to Oakdale School
Test Location: 900 Kenyon Street
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2990022 Test Start : 11/14/2023 @ 06:15
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 06:49
Location : 101 Warehouse 1 Front Received: 11/21/2023 @ 09:35
Radon Level : 1.4 pCi/L Analyzed: 11/21/2023 @ 10:07
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2916926 Test Start : 11/14/2023 @ 06:17
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 06:50
Location : 101 Warehouse 2 Received: 11/21/2023 @ 09:35
Radon Level : 0.8 pCi/L Analyzed: 11/21/2023 @ 10:01
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2989306 Test Start : 11/14/2023 @ 06:20
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 06:52
Location : 101 Warehouse 3 Received: 11/21/2023 @ 09:35
Radon Level : 1.4 pCi/L Analyzed: 11/21/2023 @ 09:49
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2987445 Test Start : 11/14/2023 @ 06:22
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 06:51
Location : 101 Warehouse 4 Received: 11/21/2023 @ 09:35
Radon Level : 1.2 pCi/L Analyzed: 11/21/2023 @ 10:07
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2987466 Test Start : 11/14/2023 @ 06:24
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 06:52
Location : 101 Warehouse 5 Received: 11/21/2023 @ 09:35
Radon Level : 1.0 pCi/L Analyzed: 11/21/2023 @ 09:49
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2987273 Test Start : 11/14/2023 @ 06:26
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 06:54
Location : 101 Warehouse 6 DP Received: 11/21/2023 @ 09:35
Radon Level : 1.4 pCi/L Analyzed: 11/21/2023 @ 10:25
Error for Measurement is: \pm 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/21/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Annex to Oakdale School
Test Location: 900 Kenyon Street
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2987470 Test Start : 11/14/2023 @ 06:37
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 06:58
Location : 107 Room Received: 11/21/2023 @ 09:35
Radon Level : 0.7 pCi/L Analyzed: 11/21/2023 @ 10:04
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2987508 Test Start : 11/14/2023 @ 06:38
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 06:59
Location : 108 Carpentry Off. Received: 11/21/2023 @ 09:35
Radon Level : 0.6 pCi/L Analyzed: 11/21/2023 @ 10:25
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2989266 Test Start : 11/14/2023 @ 06:40
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 06:59
Location : 109 Grounds Off. Received: 11/21/2023 @ 09:35
Radon Level : 0.4 pCi/L Analyzed: 11/21/2023 @ 10:01
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2913765 Test Start : 11/14/2023 @ 06:42
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:00
Location : 110 Room/Andy Received: 11/21/2023 @ 09:35
Radon Level : 0.5 pCi/L Analyzed: 11/21/2023 @ 10:24
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2987437 Test Start : 11/14/2023 @ 06:44
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:01
Location : 112A Mech Conf. Rm Received: 11/21/2023 @ 09:35
Radon Level : 0.6 pCi/L Analyzed: 11/21/2023 @ 10:23
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2987358 Test Start : 11/14/2023 @ 06:45
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:01
Location : 112B Mech Off. Received: 11/21/2023 @ 09:35
Radon Level : 0.6 pCi/L Analyzed: 11/21/2023 @ 10:23
Error for Measurement is: \pm 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/21/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Annex to Oakdale School
Test Location: 900 Kenyon Street
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2989228 Test Start : 11/14/2023 @ 06:46
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:03
Location : 113 Facilities Conf.Rm Received: 11/21/2023 @ 09:35
Radon Level : 0.9 pCi/L Analyzed: 11/21/2023 @ 10:07
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2987302 Test Start : 11/14/2023 @ 06:48
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:03
Location : 116 Mail Rm Received: 11/21/2023 @ 09:35
Radon Level : 0.4 pCi/L Analyzed: 11/21/2023 @ 10:25
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2989290 Test Start : 11/14/2023 @ 06:49
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:04
Location : 111 Custodial Off. Received: 11/21/2023 @ 09:35
Radon Level : 0.7 pCi/L Analyzed: 11/21/2023 @ 10:17
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2989196 Test Start : 11/14/2023 @ 06:51
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:05
Location : 119 Facilities Break Rm Received: 11/21/2023 @ 09:35
Radon Level : 0.7 pCi/L Analyzed: 11/21/2023 @ 10:09
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2987289 Test Start : 11/14/2023 @ 06:53
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:07
Location : 120A Metal Shop 1 Received: 11/21/2023 @ 09:36
Radon Level : 0.7 pCi/L Analyzed: 11/21/2023 @ 10:09
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2987296 Test Start : 11/14/2023 @ 06:54
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:07
Location : 120A Metal Shop 2 Received: 11/21/2023 @ 09:36
Radon Level : 1.1 pCi/L Analyzed: 11/21/2023 @ 10:04
Error for Measurement is: ± 0.4 pCi/L



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/21/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Annex to Oakdale School
Test Location: 900 Kenyon Street
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2989308 Test Start : 11/14/2023 @ 07:14
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:18
Location : 141 IT Break Rm Received: 11/21/2023 @ 09:36
Radon Level : 0.7 pCi/L Analyzed: 11/21/2023 @ 10:09
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2990060 Test Start : 11/14/2023 @ 07:16
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:21
Location : 146 Print Shop Received: 11/21/2023 @ 09:36
Radon Level : 0.3 pCi/L Analyzed: 11/21/2023 @ 10:25
MAIN AREA

Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2989255 Test Start : 11/14/2023 @ 07:19
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:23
Location : 150 Band/Main Area DP Received: 11/21/2023 @ 09:36
Radon Level : 0.7 pCi/L Analyzed: 11/21/2023 @ 10:09
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2990050 Test Start : 11/14/2023 @ 07:19
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:23
Location : 150 Band/Main Area DP Received: 11/21/2023 @ 09:36
Radon Level : 0.6 pCi/L Analyzed: 11/21/2023 @ 09:52

Average of Side by Side Canisters 0.7 pCi/L

Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2990014 Test Start : 11/14/2023 @ 07:22
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:24
Location : 159 NTS Received: 11/21/2023 @ 09:36
Radon Level : 0.9 pCi/L Analyzed: 11/21/2023 @ 10:20
Error for Measurement is: ± 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/21/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Annex to Oakdale School
Test Location: 900 Kenyon Street
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2990015 Test Start : 11/14/2023 @ 07:23
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:25
Location : 170 NTS Off./Mike Received: 11/21/2023 @ 09:36
Radon Level : 0.6 pCi/L Analyzed: 11/21/2023 @ 09:49
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2987425 Test Start : 11/14/2023 @ 07:25
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:25
Location : 171 NTS Office Received: 11/21/2023 @ 09:36
Radon Level : 0.8 pCi/L Analyzed: 11/21/2023 @ 10:20
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2989991 Test Start : 11/14/2023 @ 07:27
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:28
Location : 172 NTS Break Rm Received: 11/21/2023 @ 09:36
Radon Level : 0.6 pCi/L Analyzed: 11/21/2023 @ 10:59
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2987350 Test Start : 11/14/2023 @ 07:28
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:28
Location : 175 NTS Office Received: 11/21/2023 @ 09:36
Radon Level : 1.0 pCi/L Analyzed: 11/21/2023 @ 09:45
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2989989 Test Start : 11/14/2023 @ 07:29
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:30
Location : 176 NTS Office Received: 11/21/2023 @ 09:36
Radon Level : 0.6 pCi/L Analyzed: 11/21/2023 @ 10:09
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2987497 Test Start : 11/14/2023 @ 07:31
Canister Type : Charcoal Canister 3 inch Test Stop : 11/16/2023 @ 07:31
Location : 177 NTS Office Received: 11/21/2023 @ 09:36
Radon Level : 0.8 pCi/L Analyzed: 11/21/2023 @ 10:17
Error for Measurement is: \pm 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/21/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Annex to Oakdale School
Test Location: 900 Kenyon Street
Medford, OR 97501-
Individual Canister Results

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201