

Bergen Meadow Elementary - Sampled 6/16/16				Resampled * 8/16/16		Resampled ‡ 5/24/18	
SampleNumber	Description	Lead Result	Units	Lead Result	Units	Lead Result	Units
04700-172H-DF	Hallway Drinking Fountain	3.6	ppb			2.1	ppb
04700-219-SWBL	Clinic Sink with Bubbler/Left	8.7	ppb			3.4	ppb
04700-219-SWBR	Clinic Sink with Bubbler/Right	15.3	ppb	5.5	ppb	5.7	ppb
04700-221-S	Clinic Bathroom Sink	6.9	ppb			1.6	ppb
04700-211-S	Kindergarten Classroom Sink	1.5	ppb				
04700-213H-DF	Hallway Drinking Fountain	0.5	ppb			0.5	ppb
04700-210-S	Kindergarten Classroom Sink	0.4	ppb				
04700-201-SWB	Sink with Bubbler in Room 201	19.9	ppb	3.0	ppb	3.7	ppb
04700-197-SWB1	Sink with Bubbler Near Room 195/Left	1.3	ppb			0.6	ppb
04700-197-SWB2	Sink with Bubbler Near Room 195/Right	1.5	ppb			2.6	ppb
04700-186-S1	Art Room Sink	1.4	ppb				
04700-186-S2	Art Room Sink	2.5	ppb				
04700-181-SWB	Sink with Bubbler in Cafeteria	5.3	ppb			3.9	ppb
04700-146-S1	Food Prep Sink	27.4	ppb	2.2	ppb	0.4	ppb
04700-146-S2	Food Service Sink - Hose Connection Spigot	8.3	ppb				
04700-146-S3	Food Service Sink	8.8	ppb				
04700-146-S4	Food Service Sink - Wash/Rinse	3.9	ppb				
04700-146-S5	Food Service Sink - Hand Sink	5.7	ppb				
04700-108H-SWB	Hallway Sink with Bubbler	0.7	ppb			0.9	ppb
04700-108H-S	Hallway Sink	0.9 †	ppb				
04700-109-SWB	Sink with Bubbler Near Room 104	0.9	ppb			0.9	ppb
04700-112-SWB	Sink with Bubbler in Classroom 112	3.3	ppb				Fixture Removed
04700-112-S	Sink in Classroom 112	3.0 †	ppb				
04700-1118H-SWB	Hallway Sink with Bubbler	0.6	ppb				Fixture Removed
04700-1118H-S	Hallway Sink	1.1 †	ppb				
04700-152-SWB	Sink with Bubbler in Music Room	17.8	ppb	0.9 **	ppb		Fixture Removed
04700-152-S	Sink in Music Room	12.4 †	ppb				
04700-120-SWB	Sink with Bubbler Near Room 115	1.0	ppb				Fixture Removed
04700-120-S	Sink Near Room 115	0.8 †	ppb				
04700-123-SWB	Sink with Bubbler in Pre-K Room	8.6	ppb			11.5	ppb
04700-128H-SWB	Hallway Sink with Bubbler	3.2	ppb				Fixture Removed
04700-128H-S	Hallway Sink	0.6 †	ppb				
04700-131-SWB	Sink with Bubbler Near Pre-K Room	2.3	ppb				Fixture Removed
04700-131-S	Sink Near Pre-K Room	0.6 †	ppb				
04700-158-SWB	Sink with Bubbler in Teacher's Lounge	3.9	ppb				Fixture Removed
04700-158-S	Sink in Teacher's Lounge	0.7 †	ppb				
04700-232-S	Sink in Teacher's Lounge Restroom	2.1	ppb				
04700-163-S	Sink in Library Workroom	26.7	ppb	23.0 ***	ppb		
* Resampling results after elevated fixtures were removed and replaced.							
** On 8/16/16, this result was measured after running the water for a short time.							
*** On 8/16/16, this result was measured after running the water for a short time.							
This sink is an adult-use only area, and is signed for hand washing only.							
† These fixtures were sampled for the first time on 5/24/18. All other results in this column were from samples collected on 6/16/16.							
‡ Resampling results were from samples collected on 5/24/18 as part of an ongoing rotation of lead testing.							