

Bear Creek High School - Sampled 10/12/16				Resampled** 1/26/17		Resampled† 5/1/19	
SampleNumber	Description	Lead Result	Unit	Lead Result	Unit	Lead Result	Unit
73000-1520-S	Sink in Store	2.4	ppb			1.2	ppb
73000-1438-S	Sink in Storage Room 1438	0.5	ppb				
73000-1439-S	Sink in Clinic	0.6	ppb			0.5	ppb
73000-1405-IM	Ice Machine in Training Room 1405	<0.1 *	ppb			<0.1 *	ppb
73000-1405-S	Sink in Training Room 1405	0.3	ppb				
73000-1443-DFL1	Hallway Drinking Fountain outside of Large Gym/Left 1	<0.1 *	ppb			<0.1 *	ppb
73000-1443-DFR1	Hallway Drinking Fountain outside of Large Gym/Right 1	<0.1 *	ppb			<0.1 *	ppb
73000-1443-DFL2	Hallway Drinking Fountain outside of Large Gym/Left 2	<0.1 *	ppb			0.1	ppb
73000-1443-DFR2	Hallway Drinking Fountain outside of Large Gym/Right 2	<0.1 *	ppb			0.1	ppb
73000-1419-DF	Drinking Fountain in Weight Room	0.3	ppb			<0.1 *	ppb
73000-1403-S	Sink in Concessions	0.6	ppb			1.6	ppb
73000-1304H-DFL	Hallway Drinking Fountain outside of Small Gym/Left	0.2	ppb			0.2	ppb
73000-1304H-DFR	Hallway Drinking Fountain outside of Small Gym/Right	0.2	ppb			0.1	ppb
73000-S102-S	Sink in Classroom S102	0.9	ppb				
73000-S102-SWB	Sink with Bubbler in Classroom S102	0.3	ppb			0.7	ppb
73000-S103-S	Sink in Classroom S103	1.2	ppb				
73000-S103-SWB	Sink with Bubbler in Classroom S103	0.3	ppb			0.2	ppb
73000-S104-S	Sink in Classroom S104	1.0	ppb				
73000-S104-SWB	Sink with Bubbler in Classroom S104	0.5	ppb			0.9	ppb
73000-S105-S	Sink in Classroom S105	0.4	ppb				
73000-S105-SWB	Sink with Bubbler in Classroom S105	0.3	ppb			0.2	ppb
73000-S106-S	Sink in Classroom S106	1.1	ppb				
73000-S106-SWB	Sink with Bubbler in Classroom S106	0.3	ppb			0.7	ppb
73000-S107-S	Sink in Classroom S107	0.4	ppb				
73000-S107-SWB	Sink with Bubbler in Classroom S107	0.3	ppb			0.4	ppb
73000-S108-S	Sink in Classroom S108	0.4	ppb				
73000-S108-SWB	Sink with Bubbler in Classroom S108	0.7	ppb			0.6	ppb
73000-S113-S	Sink in Office S113	0.6	ppb				
73000-1117H-DF	Hallway Drinking Fountain outside of Office S113	0.2	ppb			0.7	ppb
73000-S109-S	Sink in Classroom S109	0.4	ppb				
73000-S109-SWB	Sink with Bubbler in Classroom S109	0.4	ppb			0.3	ppb
73000-S110-S1	Sink in Classroom S110/1	0.5	ppb				
73000-S110-S2	Sink in Classroom S110/2	0.7	ppb				
73000-S110-SWB	Sink with Bubbler in Classroom S110	0.2	ppb			0.3	ppb
73000-1101H-DFL1	Hallway Drinking Fountain across from Art Room S117/Left 1	0.3	ppb			0.1	ppb
73000-1101H-DFR1	Hallway Drinking Fountain across from Art Room S117/Right 1	0.3	ppb			0.1	ppb
73000-1101H-DFL2	Hallway Drinking Fountain across from Art Room S117/Left 2	0.3	ppb			0.2	ppb
73000-1101H-DFR2	Hallway Drinking Fountain across from Art Room S117/Right 2	0.3	ppb			0.2	ppb
73000-S115-S	Sink in Art Room S115	0.4	ppb				
73000-1201-S	Sink in Instrument/Band Room	0.3	ppb				
73000-1201-SWB	Sink with Bubbler in Instrument/Band Room	0.3	ppb			0.3	ppb
73000-1203-S	Sink in Vocal Room 1203	0.3	ppb				
73000-1203-SWB	Sink with Bubbler in Vocal Room 1203	0.3	ppb			0.5	ppb
73000-1217H-DF	Hallway Drinking Fountain outside of Vocal Room 1203	0.2	ppb			0.2	ppb
73000-1531-S	Food Service Sink-Hand Sink	2.1	ppb				
73000-1532-S1	Food Service Sink-Wash Sprayer	11.5	ppb				
73000-1532-S3	Food Service Sink-Wash/Rinse	3.6	ppb				
73000-1532-S4	Food Service Sink-Rinse/Sanitize	4.2	ppb				
73000-1534-S1	Food Service Sink-Hand Sink	0.3	ppb				
73000-1534-S2	Food Service Sink-Food Prep	1.3	ppb			0.8	ppb
73000-1534-S3	Food Service Sink-Food Prep Sprayer	7.8	ppb			32.2	ppb
73000-1503-S	Sink in Office 1503	0.2	ppb				
73000-1614-S	Sink in Teacher's Lounge 1614	0.8	ppb			0.9	ppb
73000-1601-S	Sink in Teacher's Lounge 1601	0.9	ppb			0.7	ppb
73000-1719H-DFL	Hallway Drinking Fountain across from Main Offices/Left	0.2	ppb			0.2	ppb
73000-1791H-DFR	Hallway Drinking Fountain across from Main Offices/Right	0.7	ppb			0.1	ppb
73000-N102-S	Sink in Office N102	0.8	ppb				
73000-N106-S	Sink in Office N106	0.5	ppb				
73000-N108-S	Sink in Office N108	16.3	ppb	2.1	ppb		
73000-N115-S9	Sink in Laboratory N115	2.6	ppb				
73000-1917-DFL	Hallway Drinking Fountain across from Classroom N112/Left	0.5	ppb			0.3	ppb
73000-1917-DFR	Hallway Drinking Fountain across from Classroom N112/Right	0.8	ppb			0.7	ppb
73000-2605H-DFR	Hallway Drinking Fountain across from Laboratory W202/Right	0.2	ppb			0.1	ppb
73000-2605H-DFL	Hallway Drinking Fountain near Science Room W-202/Left	0.3 ***	ppb				

73000-2603H-DFL	Hallway Drinking Fountain outside of Library/Left	0.2	ppb		0.1	ppb
73000-2603H-DFR	Hallway Drinking Fountain outside of Library/Right	0.3	ppb		0.2	ppb
73000-2604-S	Sink in Library Workroom	0.6	ppb			
73000-2926-DFL	Hallway Drinking Fountain across from Classroom N212/Left	0.4	ppb		0.3	ppb
73000-2926-DFR	Hallway Drinking Fountain across from Classroom N212/Right	0.5	ppb		0.6	ppb
73000-S202-S	Sink in Classroom S202	0.4	ppb			
73000-S202-SWB	Sink with Bubbler in Classroom S202	0.5	ppb		1.0	ppb
73000-S203-S	Sink in Classroom S203	28.6	ppb	10.2		ppb
73000-S203-SWB	Sink with Bubbler in Classroom S203	3.9	ppb		0.9	ppb
73000-2111H-DF	Hallway Drinking Fountain across from Classroom S205	0.3	ppb		0.2	ppb
73000-2125H-DF	Hallway Drinking Fountain outside of Classroom S201	0.2	ppb		0.2	ppb
73000-S204-S	Sink in Classroom S204	1.3	ppb			
73000-S204-SWB	Sink with Bubbler in Classroom S204	0.6	ppb		0.7	ppb
73000-S205-S	Sink in Classroom S205	1.1	ppb			
73000-S205-SWB	Sink with Bubbler in Classroom S205	0.5	ppb		0.4	ppb
73000-S206-S	Sink in Classroom S206	1.1	ppb			
73000-S206-SWB	Sink with Bubbler in Classroom S206	0.5	ppb		0.7	ppb
73000-S208-S	Sink in Classroom S208	0.8	ppb			
73000-S209-S	Sink in Consumer Science Room S209	1.0	ppb		0.7	ppb
73000-2105-S	Sink in Office 2015	0.4	ppb			
73000-S207-S	Sink in Classroom S207	0.3	ppb			
73000-S207-SWB	Sink with Bubbler in Classroom S207	0.5	ppb		0.7	ppb
73000-S210-S1	Sink in Kitchen Classroom S210	0.3	ppb		0.3	ppb
73000-S210-S2	Sink in Kitchen Classroom S210	0.4	ppb		0.4	ppb
73000-S210-S3	Sink in Kitchen Classroom S210	0.2	ppb		0.4	ppb
73000-S210-S4	Sink in Kitchen Classroom S210	0.3	ppb		0.4	ppb
73000-S210-S5	Sink in Kitchen Classroom S210	0.5	ppb		0.6	ppb
73000-S210-S6	Sink in Kitchen Classroom S210	0.3	ppb		0.7	ppb
73000-S210-S7	Sink in Kitchen Classroom S210	0.2	ppb		0.2	ppb

* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.

** Resampling results after elevated fixtures were repaired, or removed and replaced.

*** This fixture was sampled on 1/26/17.

† Resampling results were from samples collected on 5/1/19 as part of an ongoing rotation of lead testing.