

| Arvada High School - Sampled 10/6/16 | | | | Resampled*** 1/18/17, 3/10/17 or 3/24/17 | | Resampled† 5/11/18 | |
|--------------------------------------|---|-------------|-------|--|-------|-----------------------|-------|
| SampleNumber | Description | Lead Result | Units | Lead Result | Units | Lead Result | Units |
| 72000-A039-S | Sink in Storage Room A039 near Counseling Offices | 1.9 | ppb | | | | |
| 72000-A006H-DF | Hallway Drinking Fountain outside of Cafeteria | 0.2 | ppb | | | 0.2 | ppb |
| 72000-A045-S | Sink in Store A045 | 5.5 | ppb | | | | |
| 72000-A048-S | Sink in Teacher's Lounge | 0.9 | ppb | | | 0.8 | ppb |
| 72000-A061-S3 | Food Service Sink-Sprayer in Clean-up Area | 2.6 | ppb | | | | |
| 72000-A061-S4 | Food Service Sink-Sanitize/Rinse | 2.7 | ppb | | | | |
| 72000-A061-S5 | Food Service Sink-Rinse/Wash | 2.4 | ppb | | | | |
| 72000-A061-S7 | Food Service Sink-Sprayer in Food Prep Area | 21.4 | ppb | 2.1 | ppb | 8.8 | ppb |
| 72000-A061-S8 | Food Service Sink-Double Sink in Food Prep Area | 2.3 | ppb | | | 2.1 | ppb |
| 72000-A073-DF | Drinking Fountain in Weight Room | 0.4 | ppb | | | 1.1 | ppb |
| 72000-A116-S | Sink in Planning Room A116 | 1.9 | ppb | | | 3.9 | ppb |
| 72000-A117-S | Sink in Clinic | 3.5 | ppb | | | 12.8 | ppb |
| 72000-A081H-DF | Hallway Drinking Fountain in Boy's Locker Room | 2.2 | ppb | | | 2.7 | ppb |
| 72000-A086-DF | Drinking Fountain in Storage Area in Boy's Locker Room | 4.5 | ppb | | | 4.4 | ppb |
| 72000-A091-S | Sink in Training Room A091 | 0.6 | ppb | | | 0.6 | ppb |
| 72000-A091-IM | Ice Machine in Training Room A091 | <0.1* | ppb | | | | |
| 72000-A095-DF | Drinking Fountain in Women's Locker Room A095 | 0.6** | ppb | | | | |
| 72000-A111-DF | Drinking Fountain in Girl's Locker Room A111 | 0.6 | ppb | | | | |
| 72000-A111-S | Sink in Girl's Locker Room A111 | 0.7** | ppb | | | | |
| 72000-A106X-S | Sink in Girl's Locker Room Office | 1.9 | ppb | | | 1.5 | ppb |
| 72000-A094H-DF | Hallway Drinking Fountain outside of Girl's Locker Room | 94.8 | ppb | 9.0 | ppb | 55.2† | ppb |
| 72000-A218H-DF | Hallway Drinking Fountain outside of Auditorium | 1.0 | ppb | | | 1.5 | ppb |
| 72000-A217H-DF | Hallway Drinking Fountain outside of Auditorium | 1.6 | ppb | | | 2.0 | ppb |
| 72000-A215-DF | Drinking Fountain in Vocal Room A215 | 1.2 | ppb | | | 1.2 | ppb |
| 72000-A009-DF | Drinking Fountain in Green Room A009 | 9.5 | ppb | | | 8.8 | ppb |
| 72000-A252-DF | Drinking Fountain in Boy's Varsity Locker Room | 0.3 | ppb | | | 0.5 | ppb |
| 72000-B202H-DF | Hallway Drinking Fountain outside of Library | 0.1 | ppb | | | 0.4 | ppb |
| 72000-B232-S | Sink in Processing Room B232 | 0.2 | ppb | | | | |
| 72000-B232-IM | Ice Machine in Processing Room B232 | 0.3 | ppb | | | | |
| 72000-B326H-DF | Hallway Drinking Fountain across from Classroom B307 | 5.3 | ppb | | | | |
| 72000-B307XH-DF | Hallway Drinking Fountain across from Classroom B308 | 11.0 | ppb | | | 6.1 | ppb |
| 72000-B303XH-DF | Hallway Drinking Fountain across from Classroom B321 | 15.3 | ppb | 2.2 | ppb | 1.6 | ppb |
| 72000-B318XH-DF | Hallway Drinking Fountain across from Classroom B319 | 8.3 | ppb | | | 3.7 | ppb |
| 72000-B111XH-DF | Hallway Drinking Fountain across from Laboratory B113 | 1.5 | ppb | | | 1.6 | ppb |
| 72000-B154-S | Sink in Science Prep Room B154 | 5.3 | ppb | | | | |
| 72000-B120H-DF | Hallway Drinking Fountain across from Science Prep Room B153 | 3.9 | ppb | | | 3.8 | ppb |
| 72000-B120-S1 | Sink in Laboratory B120 | 4.8 | ppb | | | | |
| 72000-B120-S2 | Sink in Laboratory B120 | 3.3 | ppb | | | | |
| 72000-B120-S3 | Sink in Laboratory B120 | 3.5 | ppb | | | | |
| 72000-B120-S4 | Sink in Laboratory B120 | 6.9 | ppb | | | | |
| 72000-B118-S1 | Sink in Laboratory B118 | 7.0 | ppb | | | | |
| 72000-B118-S2 | Sink in Laboratory B118 | 6.8 | ppb | | | | |
| 72000-B118-S3 | Sink in Laboratory B118 (sink nearest to the door) | 171.6 | ppb | 2.9 | ppb | | |
| 72000-B117-S1 | Sink in Classroom B117 | 6.9 | ppb | | | | |
| 72000-B117-S2 | Sink in Classroom B117 (middle sink) | 60.6 | ppb | 2.6 | ppb | | |
| 72000-B117-S3 | Sink in Classroom B117 | 10.0 | ppb | | | | |
| 72000-B160-S | Sink in Science Prep Room B160 | 5.2 | ppb | | | | |
| 72000-B116-S1 | Sink in Laboratory B116 | 5.7 | ppb | | | | |
| 72000-B116-S2 | Sink in Laboratory B116 | 3.4 | ppb | | | | |
| 72000-B116-S3 | Sink in Laboratory B116 | 4.0 | ppb | | | | |
| 72000-B116-S4 | Sink in Laboratory B116 | 2.5 | ppb | | | | |
| 72000-B115-S1 | Sink in Laboratory B115 | 10.9 | ppb | | | | |
| 72000-B115-S2 | Sink in Laboratory B115 (middle sink on back wall) | 15.6 | ppb | 2.0 | ppb | | |
| 72000-B115-S3 | Sink in Laboratory B115 | 9.3 | ppb | | | | |
| 72000-B115-S4 | Sink in Laboratory B115 | 10.7 | ppb | | | | |
| 72000-B115-S5 | Sink in Laboratory B115 | 12.5 | ppb | | | | |
| 72000-B115-S6 | Sink in Laboratory B115 | 10.4 | ppb | | | | |
| 72000-B115-S7 | Sink in Laboratory B115 | 9.1 | ppb | | | | |
| 72000-B164-S | Sink in Science Prep B164 | 1.9 | ppb | | | | |
| 72000-B113-S1 | Sink in Laboratory B113 | 10.1 | ppb | | | | |
| 72000-B113-S2 | Sink in Laboratory B113 | 8.4 | ppb | | | | |
| 72000-B113-S3 | Sink in Laboratory B113 | 13.4 | ppb | | | | |
| 72000-B113-S4 | Sink in Laboratory B113 (4th sink in from the door) | 15.2 | ppb | 2.0 | ppb | | |
| 72000-B113-S5 | Sink in Laboratory B113 | 7.1 | ppb | | | | |
| 72000-B113-S6 | Sink in Laboratory B113 | 7.0 | ppb | | | | |
| 72000-B113-S7 | Sink in Laboratory B113 | 11.7 | ppb | | | | |
| 72000-B122-S1 | Sink in Laboratory B122 | 11.0 | ppb | | | | |
| 72000-B122-S2 | Sink in Laboratory B122 | 3.7 | ppb | | | | |
| 72000-B122-S3 | Sink in Laboratory B122 | 6.5 | ppb | | | | |
| 72000-B122-S4 | Sink in Laboratory B122 | 5.8 | ppb | | | | |
| 72000-B106XH-DF | Hallway Drinking Fountain across from Classroom B101 | 1.7 | ppb | | | 1.5 | ppb |
| 72000-B121-S1 | Sink in Laboratory B121 (first sink on left as you enter the room) | 56.3 | ppb | 6.2 | ppb | | |
| 72000-B121-S2 | Sink in Laboratory B121 (second sink on left as you enter the room) | 133.7 | ppb | 2.5 | ppb | | |
| 72000-B121-S3 | Sink in Laboratory B121 | 5.5 | ppb | | | | |
| 72000-B121-S4 | Sink in Laboratory B121 | 10.4 | ppb | | | | |
| 72000-B153-S | Sink in Science Prep B153 | 77.1 | ppb | 3.2 | ppb | | |
| 72000-B119-S1 | Sink in Laboratory B119 (first sink on left as you enter the room) | 16.0 | ppb | 6.5 | ppb | | |
| 72000-B119-S2 | Sink in Laboratory B119 | 10.3 | ppb | | | | |
| 72000-B119-S3 | Sink in Laboratory B119 | 5.8 | ppb | | | | |
| 72000-B119-S4 | Sink in Laboratory B119 | 13.5 | ppb | | | | |
| 72000-B110XH-DF | Hallway Drinking Fountain across from Classroom B111 | 4.4 | ppb | | | 3.7 | ppb |
| 72000-B109-S | Sink in Classroom B109 | 0.8 | ppb | | | | |
| 72000-B108-S | Sink in Classroom B108 | 8.6 | ppb | | | | |
| 72000-B105A-S | Sink in Classroom B105A | 3.5 | ppb | | | | |
| 72000-B130-S | Sink in Classroom B130 | 0.8 | ppb | | | 1.1 | ppb |
| 72000-B103A-S | Sink in Office B103A | 14.9 | ppb | | | | |
| 72000-109-DF | Drinking Fountain in Classroom 109 | 2.3 | ppb | | | 0.5 | ppb |
| 72000-C101XH-DF | Hallway Drinking Fountain near Art Room C101 | 0.6 | ppb | | | 1.1 | ppb |

| | | | | | | |
|---|-------------------------------------|--------|-----|-----|-----|-----|
| 72000-C105A-S1 | Sink in Kitchen Classroom C105 | 13.7 | ppb | | 6.1 | ppb |
| 72000-C105A-S2 | Sink in Kitchen Classroom C105 | 7.7 | ppb | | 4.7 | ppb |
| 72000-C105A-S3 | Sink in Kitchen Classroom C105 | 11.6 | ppb | | 8.2 | ppb |
| 72000-C105A-S4 | Sink in Kitchen Classroom C105 | 6.5 | ppb | | 2.8 | ppb |
| 72000-C105A-S5 | Sink in Kitchen Classroom C105 | 5.5 | ppb | | 4.3 | ppb |
| 72000-C105A-S6 | Sink in Kitchen Classroom C105 | 6.9 | ppb | | 6.8 | ppb |
| 72000-C105B-S | Sink in Consumer Science Room C105B | 15.9 | ppb | 5.0 | ppb | |
| 72000-C106-S | Sink in Art Room C106 | 8.5 | ppb | | | |
| 72000-C117-S | Sink in Art Room C117 | 5.2 | ppb | | | |
| 72000-C108-S1 | Sink in Art Room C108 | 1.8 | ppb | | | |
| 72000-C108-S2 | Sink in Art Room C108 | 3.9 | ppb | | | |
| 72000-C103B-S | Sink in Art Room C103B | 18.2 | ppb | 9.1 | ppb | |
| 72000-C101-S | Sink in Art Room C101 | 7.5 | ppb | | | |
| 72000-C102-S | Sink in Technology Lab C102 | 11.5 | ppb | | | |
| 72000-C104-DF | Drinking Fountain in Voc Lab C104 | 6.6 | ppb | | 8.0 | ppb |
| 72000-A012-S | Sink in Dressing Room | 20.4** | ppb | 0.6 | ppb | |
| 72000-A013-S | Sink in Dressing Room | 2.7** | ppb | | | |
| 72000-A208-S | Sink in Room A208 | 3.4** | ppb | | | |
| 72000-B204-DF | Drinking Fountain | 0.7** | ppb | | | |
| * This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab. | | | | | | |
| ** This fixture was sampled for the first time on 1/18/17 or 5/11/18. | | | | | | |
| *** Resampling results after elevated fixtures were repaired, or removed and replaced. | | | | | | |
| † Resampling results were from samples collected on 5/11/18 as part of an ongoing rotation of lead testing. | | | | | | |
| ‡ This fixture is signed, "Fountain Out of Service. Do Not Drink." and is shut off. | | | | | | |