

Bergen Valley Elementary School - Sampled 11/1/16				Resampled ** 5/24/18	
SampleNumber	Description	Lead Result	Unit	Lead Result	Unit
04600-143-S	Sink in Clinic	4.7	ppb	4.5	ppb
04600-140-S	Sink in Work Room 140 near Principal's Office	5.2	ppb		
04600-101-S	Sink in Classroom 101	<0.1 *	ppb		
04600-101-SWB	Sink with Bubblers in Classroom 101	<0.1 *	ppb	0.3	ppb
04600-102-S	Sink in Classroom 102	<0.1 *	ppb		
04600-102-SWB	Sink with Bubblers in Classroom 102	<0.1 *	ppb	0.3	ppb
04600-103-S	Sink in Classroom 103	<0.1 *	ppb		
04600-103-SWB	Sink with Bubblers in Classroom 103	<0.1 *	ppb	0.2	ppb
04600-104-S	Sink in Classroom 104	<0.1 *	ppb		
04600-104-SWB	Sink with Bubblers in Classroom 104	<0.1 *	ppb	0.2	ppb
04600-105-S	Sink in Classroom 105	0.1	ppb		
04600-105-SWB	Sink with Bubblers in Classroom 105	<0.1 *	ppb	0.3	ppb
04600-106-S	Sink in Classroom 106	<0.1 *	ppb		
04600-106-SWB	Sink with Bubblers in Classroom 106	0.1	ppb	0.3	ppb
04600-117H-DF	Hallway Drinking Fountain between Classrooms 106 and 101	<0.1 *	ppb	<0.1 *	ppb
04600-122-S	Sink in Teacher's Lounge	1.3	ppb	1.6	ppb
04600-201-S	Sink in Classroom 201	<0.1 *	ppb		
04600-201-SWB	Sink with Bubblers in Classroom 201	0.6	ppb	0.6	ppb
04600-125H-DF	Hallway Drinking Fountain between Classrooms 201 and 202	<0.1 *	ppb	0.3	ppb
04600-202-S	Sink in Classroom 202	0.4	ppb		
04600-202-SWB	Sink with Bubblers in Classroom 202	0.8	ppb	1.2	ppb
04600-172-S	Sink in Music Room 172	1.4	ppb		
04600-191-S1	Food Service Sink-Sprayer	6.9	ppb		
04600-191-S2	Food Service Sink-Hand Sink	1.6	ppb		
04600-192-S3	Food Service Sink-Sprayer	3.4	ppb		
04600-192-S4	Food Service Sink-Wash/Rinse	6.0	ppb		
04600-192-S5	Food Service Sink-Rinse/Sanitize	14.6	ppb	6.1	ppb
04600-192-S6	Food Service Sink-Hand Sink	<0.1 *	ppb		
04600-192-S7	Food Service Sink	3.3	ppb	6.3	ppb
04600-181H-DF	Hallway Drinking Fountain outside of Cafeteria	<0.1 *	ppb	0.1	ppb
04600-174-S1	Art Room Sink	1.3	ppb		
04600-174-S2	Art Room Sink	9.2	ppb		
04600-301-S	Sink in Classroom 301	0.4	ppb		
04600-301-SWB	Sink with Bubblers in Classroom 301	1.8	ppb	2.2	ppb
04600-302-S	Sink in Classroom 302	0.2	ppb		
04600-302-SWB	Sink with Bubblers in Classroom 302	0.1	ppb	0.4	ppb
04600-303-S	Sink in Classroom 303	0.4	ppb		
04600-303-SWB	Sink with Bubblers in Classroom 303	0.5	ppb	0.5	ppb
04600-304-S	Sink in Classroom 304	<0.1 *	ppb		
04600-304-SWB	Sink with Bubblers in Classroom 304	<0.1 *	ppb	0.3	ppb
04600-305-S	Sink in Classroom 305	<0.1 *	ppb		
04600-305-SWB	Sink with Bubblers in Classroom 305	0.6	ppb	0.7	ppb
04600-306-S	Sink in Classroom 306	<0.1 *	ppb		
04600-306-SWB	Sink with Bubblers in Classroom 306	1.8	ppb	1.9	ppb
04600-159H-DF	Hallway Drinking Fountain across from Classrooms 306 and 301	<0.1 *	ppb	0.2	ppb
04600-142-S	Sink in Library Work Room	8.4	ppb	8.6	ppb

\* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.

\*\* Resample results were from samples collected 5/24/18 as part of an ongoing rotation of lead testing.