

Anderson Preschool Sampled - 7/28/16				Resampled** 5/4/18	
SampleNumber	Description	Lead Result	Units	Lead Result	Units
17095-104-S	Sink in Clinic	0.7	ppb	0.4	ppb
17095-114-S	Sink in Pre-K Classroom 114	0.2	ppb	0.1	ppb
17095-120A-S	Sink between Pre-K Classrooms 114 & 115	0.2	ppb		
17095-115-S	Sink in Pre-K Classroom 115	0.2	ppb	0.1	ppb
17095-115XH-DFL	Hallway Drinking Fountain across from Offices/Left	0.2	ppb	0.1	ppb
17095-115XH-DFR	Hallway Drinking Fountain across from Offices/Right	0.2	ppb		
17095-116-S	Sink in Pre-K Classroom 116	0.2	ppb	<0.1 *	ppb
17095-123A-S	Sink in between Pre-K Classrooms 116 & 117	0.3	ppb		
17095-117-S	Sink in Pre-K Classroom 117	0.2	ppb	<0.1 *	ppb
17095-108-S	Sink in Teacher's Lounge	0.4	ppb	0.7	ppb
* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.					
** Resampling results were from samples collected on 5/4/18 as part of an ongoing rotation of lead testing.					